
ADDRESS . . : 25 ALBERT CT
 CONTRACTOR : WYNN CONSTRUCTION, INC.
 OWNER . . . : WYNN CONSTRUCTION INC
 PARCEL . . . : 03-9586- - -0024- -51-
 APPL NUMBER: 10-50024601 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 06/15/2010 12:53 PM VBROWN ----
 25 ALBERT COURT, CAMERON PINES SUB DIV
 #13. 27W, LEFT ON BUFFAOL LAKES RD,
 1/2MI ON LEFT.

STRUCTURE: 000 000 37X42 3BDR 2BATH SFD W GAR, DECK, CRAWL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00
 SEPTIC - EXISTING? : NEW TANK

PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED	INSP	DESCRIPTION
	COMPLETED	RESULT	RESULTS/COMMENTS
B101 01	7/06/10	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001949752
	<u>7.6.10</u>	<u>AP-MR</u>	

COMMENTS AND NOTES

ADDRESS . . : 25 ALBERT CT
CONTRACTOR : WYNN CONSTRUCTION, INC.
OWNER . . . : WYNN CONSTRUCTION INC
PARCEL . . . : 03-9586- - -0024- -51-
APPL NUMBER: 10-50024601 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 06/15/2010 12:53 PM VBROWN ----
25 ALBERT COURT, CAMERON PINES SUB DIV
#13. 27W, LEFT ON BUFFAOL LAKES RD,
1/2MI ON LEFT.

SUBDIV: CAMERON PINES 19 LOTS
PHONE : (919) 528-1347
PHONE :

STRUCTURE: 000 000 37X42 3BDR 2BATH SFD W GAR, DECK, CRAWL

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW TANK
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/06/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001949752
	7/06/10	AP	T/S: 07/06/2010 12:22 PM MREARIC -----
B103 01	7/16/10	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001954978
	<u>7-16-10</u>	<u>AP-MR</u>	

----- COMMENTS AND NOTES -----

ADDRESS . . : 25 ALBERT CT
CONTRACTOR : WYNN CONSTRUCTION, INC.
OWNER . . . : WYNN CONSTRUCTION INC
PARCEL . . . : 03-9586- - -0024- -51-
APPL NUMBER: 10-50024601 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 06/15/2010 12:53 PM VBROWN ----
25 ALBERT COURT, CAMERON PINES SUB DIV
#13. 27W, LEFT ON BUFFAOL LAKES RD,
1/2MI ON LEFT.

SUBDIV: CAMERON PINES 19 LOTS
PHONE : (919) 528-1347
PHONE :

STRUCTURE: 000 000 37X42 3BDR 2BATH SFD W GAR, DECK, CRAWL

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW TANK
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/06/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001949752
	7/06/10	AP	T/S: 07/06/2010 12:22 PM MREARIC -----
B103 01	7/16/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001954978
	7/16/10	AP	T/S: 07/16/2010 01:56 PM MREARIC -----
B105 01	7/20/10	TI	R*OPEN FLOOR VRU #: 001956413
	<u>7-20-10</u>	<u>AP-NR</u>	

----- COMMENTS AND NOTES -----

ADDRESS . . : 25 ALBERT CT
CONTRACTOR : WYNN CONSTRUCTION, INC.
OWNER . . . : WYNN CONSTRUCTION INC
PARCEL . . . : 03-9586- - -0024- -51-
APPL NUMBER: 10-50024601 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 06/15/2010 12:53 PM VBROWN ----
25 ALBERT COURT, CAMERON PINES SUB DIV
#13. 27W, LEFT ON BUFFAOL LAKES RD,
1/2MI ON LEFT.

SUBDIV: CAMERON PINES 19 LOTS
PHONE : (919) 528-1347
PHONE :

STRUCTURE: 000 000 37X42 3BDR 2BATH SFD W GAR, DECK, CRAWL

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/06/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001949752
	7/06/10	AP	T/S: 07/06/2010 12:22 PM MREARIC -----
B103 01	7/16/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001954978
	7/16/10	AP	T/S: 07/16/2010 01:56 PM MREARIC -----
B105 01	7/20/10	MR	R*OPEN FLOOR VRU #: 001956413
	7/20/10	AP	T/S: 07/20/2010 12:57 PM MREARIC -----
R425 01	8/10/10	TI	FOUR TRADE ROUGH IN VRU #: 001967223
	<u>8/10/10</u>	<u>DA DT</u>	

----- COMMENTS AND NOTES -----

ADDRESS : 25 ALBERT CT
CONTRACTOR : WYNN CONSTRUCTION, INC.
OWNER : WYNN CONSTRUCTION INC
PARCEL : 03-9586- - -0024- -51-
APPL NUMBER: 10-50024601 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 06/15/2010 12:53 PM VBROWN ----
25 ALBERT COURT, CAMERON PINES SUB DIV
#13. 27W, LEFT ON BUFFAOL LAKES RD,
1/2MI ON LEFT.

SUBDIV: CAMERON PINES 19 LOTS
PHONE : (919) 528-1347
PHONE :

STRUCTURE: 000 000 37X42 3BDR 2BATH SFD W GAR, DECK, CRAWL

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/06/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001949752
	7/06/10	AP	T/S: 07/06/2010 12:22 PM MREARIC -----
B103 01	7/16/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001954978
	7/16/10	AP	T/S: 07/16/2010 01:56 PM MREARIC -----
B105 01	7/20/10	MR	R*OPEN FLOOR VRU #: 001956413
	7/20/10	AP	T/S: 07/20/2010 12:57 PM MREARIC -----
R425 01	8/10/10	DT	FOUR TRADE ROUGH IN VRU #: 001967223
	8/10/10	DA	1. Need fire block at bay window in nook 2. Need engineer repair for bored truss above bottom of steps 3. Need 10 psi on gas line. 4. Need fire caulk at back bedroom by left window. T/S:08/10/2010 11:11 AM DETAYLOR -----
A814 01	8/17/10	TI	ADDRESS CONFIRMATION VRU #: 001970185
R425 02	8/17/10	TI	FOUR TRADE ROUGH IN VRU #: 001970193
	8-17-10	AP-MR	

COMMENTS AND NOTES

ADDRESS : 25 ALBERT CT
CONTRACTOR : WYNN CONSTRUCTION, INC.
OWNER : WYNN CONSTRUCTION INC
PARCEL : 03-9586- - -0024- -51-
APPL NUMBER: 10-50024601 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 06/15/2010 12:53 PM VBROWN ----
25 ALBERT COURT, CAMERON PINES SUB DIV
#13. 27W, LEFT ON BUFFAOL LAKES RD,
1/2MI ON LEFT.

SUBDIV: CAMERON PINES 19 LOTS
PHONE : (919) 528-1347
PHONE :

STRUCTURE: 000 000 37X42 3BDR 2BATH SFD W GAR, DECK, CRAWL

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW TANK
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/06/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001949752
	7/06/10	AP	T/S: 07/06/2010 12:22 PM MREARIC
B103 01	7/16/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001954978
	7/16/10	AP	T/S: 07/16/2010 01:56 PM MREARIC
B105 01	7/20/10	MR	R*OPEN FLOOR VRU #: 001956413
	7/20/10	AP	T/S: 07/20/2010 12:57 PM MREARIC
R425 01	8/10/10	DT	FOUR TRADE ROUGH IN VRU #: 001967223
	8/10/10	DA	1. Need fire block at bay window in nook 2. Need engineer repair for bored truss above bottom of steps 3. Need 10 psi on gas line. 4. Need fire caulk at back bedroom by left window. T/S: 08/10/2010 11:11 AM DETAYLOR
R425 02	8/17/10	MR	FOUR TRADE ROUGH IN VRU #: 001970193
	8/17/10	AP	T/S: 08/17/2010 02:04 PM MREARIC
A814 01	8/17/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001970185
	8/17/10	AP	T/S: 08/17/2010 04:37 PM TWARD 25 ALBERT CT LOT 13 SANFORD 27332 T/S: 08/17/2010 04:38 PM TWARD
I129 01	8/19/10	TI	R*INSULATION INSPECTION VRU #: 001971803
	<u>8-19-10</u>	<u>AP-MR</u>	

COMMENTS AND NOTES

Harnett County

INSPECTOR: IVR

DATE 10/13/10

ADDRESS . . : 25 ALBERT CT SUBDIV: CAMERON PINES 19 LOTS
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
 OWNER . . : WYNN CONSTRUCTION INC PHONE :
 PARCEL . . : 03-9586- - -0024- -51-
 APPL NUMBER: 10-50024601 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 06/15/2010 12:53 PM VBROWN ----
 25 ALBERT COURT, CAMERON PINES SUB DIV
 #13. 27W, LEFT ON BUFFAOL LAKES RD,
 1/2MI ON LEFT.

STRUCTURE: 000 000 37X42 3BDR 2BATH SFD W GAR, DECK, CRAWL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/06/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001949752
	7/06/10	AP	T/S: 07/06/2010 12:22 PM MREARIC -----
B103 01	7/16/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001954978
	7/16/10	AP	T/S: 07/16/2010 01:56 PM MREARIC -----
B105 01	7/20/10	MR	R*OPEN FLOOR VRU #: 001956413
	7/20/10	AP	T/S: 07/20/2010 12:57 PM MREARIC -----
R425 01	8/10/10	DT	FOUR TRADE ROUGH IN VRU #: 001967223
	8/10/10	DA	1. Need fire block at bay window in nook 2. Need engineer repair for bored truss above bottom of steps 3. Need 10 psi on gas line. 4. Need fire caulk at back bedroom by left window. T/S:08/10/2010 11:11 AM DETAYLOR -----
R425 02	8/17/10	MR	FOUR TRADE ROUGH IN VRU #: 001970193
	8/17/10	AP	T/S: 08/17/2010 02:04 PM MREARIC -----
A814 01	8/17/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001970185
	8/17/10	AP	T/S: 08/17/2010 04:37 PM TWARD ----- ✓ 25 ALBERT CT LOT 13 SANFORD 27332 T/S: 08/17/2010 04:38 PM TWARD -----
I129 01	8/19/10	MR	R*INSULATION INSPECTION VRU #: 001971803
	8/19/10	AP	T/S: 08/19/2010 11:20 AM MREARIC -----
H824 01	9/22/10	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001985712
	9/22/10	DA	PUMP AND ALARM TO BE CHECKED. T/S: 09/22/2010 11:34 AM SZIMMER ----- T/S: 09/22/2010 11:35 AM SZIMMER -----
H824 02	10/07/10	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001991058
	10/07/10	AP	T/S: 10/07/2010 08:34 AM SZIMMER ----- T/S: 10/07/2010 08:35 AM SZIMMER -----
R431 01	10/13/10	TI	FOUR TRADE FINAL >2500 VRU #: 001992825

10-13-10 DP-IVR

----- COMMENTS AND NOTES -----

Plastic

ADDRESS : 25 ALBERT CT
 CONTRACTOR : WYNN CONSTRUCTION, INC.
 OWNER : WYNN CONSTRUCTION INC
 PARCEL : 03-9586- - -0024- -51-
 APPL NUMBER: 10-50024601 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 06/15/2010 12:53 PM VBROWN ----
 25 ALBERT COURT, CAMERON PINES SUB DIV
 #13. 27W, LEFT ON BUFFAOL LAKES RD,
 1/2MI ON LEFT.

SUBDIV: CAMERON PINES 19 LOTS
 PHONE : (919) 528-1347
 PHONE :

STRUCTURE: 000 000 37X42 3BDR 2BATH SFD W GAR, DECK, CRAWL

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

SEPTIC - EXISTING? : NEW TANK

PROPOSED USE : SFD

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/06/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001949752
	7/06/10	AP	T/S: 07/06/2010 12:22 PM MREARIC -----
B103 01	7/16/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001954978
	7/16/10	AP	T/S: 07/16/2010 01:56 PM MREARIC -----
B105 01	7/20/10	MR	R*OPEN FLOOR VRU #: 001956413
	7/20/10	AP	T/S: 07/20/2010 12:57 PM MREARIC -----
R425 01	8/10/10	DT	FOUR TRADE ROUGH IN VRU #: 001967223
	8/10/10	DA	1. Need fire block at bay window in nook 2. Need engineer repair for bored truss above bottom of steps 3. Need 10 psi on gas line. 4. Need fire caulk at back bedroom by left window.
R425 02	8/17/10	MR	T/S: 08/10/2010 11:11 AM DETAYLOR -----
	8/17/10	AP	FOUR TRADE ROUGH IN VRU #: 001970193
A814 01	8/17/10	TW	T/S: 08/17/2010 02:04 PM MREARIC -----
	8/17/10	AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001970185
			✓ T/S: 08/17/2010 04:37 PM TWARD ----- 25 ALBERT CT LOT 13 SANFORD 27332
I129 01	8/19/10	MR	T/S: 08/17/2010 04:38 PM TWARD -----
	8/19/10	AP	R*INSULATION INSPECTION VRU #: 001971803
H824 01	9/22/10	OT	T/S: 08/19/2010 11:20 AM MREARIC -----
	9/22/10	DA	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001985712 PUMP AND ALARM TO BE CHECKED.
H824 02	10/07/10	OT	T/S: 09/22/2010 11:34 AM SZIMMER -----
	10/07/10	AP	✓ T/S: 09/22/2010 11:35 AM SZIMMER ----- ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001991058
R431 01	10/13/10	MR	T/S: 10/07/2010 08:34 AM SZIMMER -----
	10/13/10	DP	T/S: 10/07/2010 08:35 AM SZIMMER ----- FOUR TRADE FINAL >2500 VRU #: 001992825
			T/S: 10/13/2010 01:25 PM MREARIC ----- no plastic under house no sec. drain line from ahu
R429 01	10/15/10	TI	T/S: 10/14/2010 07:56 AM NTART -----
	10/15/10	AP-MR	FOUR TRADE FINAL VRU #: 001994698

COMMENTS AND NOTES

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: X Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: R-3

Permit Numbers

Name: _____

Building: 10-50024601

Address: 25 Albert Ct.

Electrical: 11

Insulation: 11

Plumbing: 11

Mechanical: 11

MFG Home: _____

Date: 10-15-10

Building Official: T. Michael Reine