Harnett County Department of Public Heartn

Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: Micro Tower Ld. SUBDIVISION The Junnit LOT # 111 EXPANSION Site Improvements required prior to Construction Authorization Issuance: Type of Structure: 5F 0 60 x50 Proposed Wastewater System Type: _ Conventional Projected Daily Flow: 360 Number of Occupants: Number of bedrooms: Basement Yes May be required based on final location and elevations of facilities Pump Required: ☐Yes ☐ No Type of Water Supply:

Community Public Well Distance from well feet Five years Permit valid for: ■ No expiration Permit conditions: SEE ATTACHED SITE SKETCH The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1954, .1955, .1956, .1955, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. PROPERTY LOCATION: Micro Tower Rd.

SUBDIVISION The Junit

Expansion Repair Basement? Yes No Basement Fixtures? Yes No (Initial) Wastewater Flow: 360 Conventional Type of Wastewater System** (See note below, if applicable 25% Leduction System (Repair)
Number of trenches Installation Requirements/Conditions Exact length of each trench 150 feet Trench Spacing: 9 Feet on Center Septic Tank Size /000 gallons Soil Cover: 12 Pump Tank Size gallons Trenches shall be installed on contour at a Maximum Trench Depth of: 24 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) inches below pipe Pump Requirements: ft. TDH vs. 2 __ inches above pipe Aggregate Depth: Conditions: Run drain line on contour. No utilities allowed in the system for repair oreas. All water lines must be at least From any part of septic system

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Authorized State Agent;/ Construction Authorization Expiration Date: 7/9/2015

Harnett County Department of Public Health Site Sketch

ISSUED TO: Blackwell Homes	PERTY LOCATON:	Micro Tou The Jonnie	ver Ld.	LOT # ///
Authorized State Agent: Suyan Mc Loin, REHS			7/9/2010	

