

SCANNED  
12/14/10  
DATE

ADDRESS . . : 40 CAMERON PINES DR  
CONTRACTOR : WYNN CONSTRUCTION, INC.  
OWNER . . . : WYNN CONSTRUCTION  
PARCEL . . . : 03-9586- - -0024- -57-  
APPL NUMBER: 10-50024734 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 06/30/2010 01:28 PM RDCONTE ---  
40 CAMERON PINES DR / CAMERON PINES #19  
TAKE 27W, T/L ON BUFFALO LAKES RD. GO  
APPROX 1/4MI, T/L INTO SUBDIVISION  
\*\*\*PWR CO: CEMC\*\*\*

SUBDIV: CAMERON PINES 19 LOTS  
PHONE : (919) 528-1347  
PHONE : (919) 539-2077

**STRUCTURE: 000 000 60X60 CRAWL 3BD/3BA W/GAR & DECK**

FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : 3.00  
SEPTIC - EXISTING? . . . . : NEW TANK  
PROPOSED USE . . . . . : SFD  
WATER SUPPLY . . . . . : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS	VRU #:
B101 01	12/14/10 <i>12-14-10</i>	TI <i>AP-IVR</i>	R*BLDG FOOTING / TEMP SVC POLE	002017929

COMMENTS AND NOTES



-----  
ADDRESS . . : 40 CAMERON PINES DR SUBDIV: CAMERON PINES 19 LOTS  
CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347  
OWNER . . . : WYNN CONSTRUCTION PHONE : (919) 539-2077  
PARCEL . . : 03-9586- - -0024- -57-  
APPL NUMBER: 10-50024734 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 06/30/2010 01:28 PM RDCONTE ---  
40 CAMERON PINES DR / CAMERON PINES #19  
TAKE 27W, T/L ON BUFFALO LAKES RD. GO  
APPROX 1/4MI, T/L INTO SUBDIVISION  
\*\*\*PWR CO: CEMC\*\*\*  
-----

**STRUCTURE: 000 000 60X60 CRAWL 3BD/3BA W/GAR & DECK**  
FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . : 3.00 PROPOSED USE . . . . : SFD  
SEPTIC - EXISTING? . . . . : NEW TANK WATER SUPPLY . . . . : COUNTY  
-----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/14/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002017929
	12/14/10	AP	T/S: 12/14/2010 12:34 PM MREARIC -----
A814 01	12/17/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002019958
	12/16/10	AP	40 CAMERON PINES DR LOT 19 SANFORD 273323----- T/S: 12/16/2010 03:47 PM TWARD ----- 40 CAMERON PINES DR LOT 19 SANFORD 27332----- -----
B103 01	12/20/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002019974
	12/20/10	AP	T/S: 12/20/2010 01:25 PM MREARIC -----
B105 01	12/22/10	TI	R*OPEN FLOOR VRU #: 002021590

12-22-10 IVR-MR

----- COMMENTS AND NOTES -----



ADDRESS : 40 CAMERON PINES DR SUBDIV: CAMERON PINES 19 LOTS  
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347  
 OWNER : WYNN CONSTRUCTION PHONE : (919) 539-2077  
 PARCEL : 03-9586- - -0024- -57-  
 APPL NUMBER: 10-50024734 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 06/30/2010 01:28 PM RDCONTE ---  
 40 CAMERON PINES DR / CAMERON PINES #19  
 TAKE 27W, T/L ON BUFFALO LAKES RD. GO  
 APPROX 1/4MI, T/L INTO SUBDIVISION  
 \*\*\*PWR CO: CEMC\*\*\*

STRUCTURE: 000 000 60X60 CRAWL 3BD/3BA W/GAR & DECK  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/14/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002017929
	12/14/10	AP	T/S: 12/14/2010 12:34 PM MREARIC -----
A814 01	12/17/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002019958
	12/16/10	AP	40 CAMERON PINES DR LOT 19 SANFORD 273323----- T/S: 12/16/2010 03:47 PM TWARD ----- 40 CAMERON PINES DR LOT 19 SANFORD 27332-----
B103 01	12/20/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002019974
	12/20/10	AP	T/S: 12/20/2010 01:25 PM MREARIC -----
B105 01	12/22/10	MR	R*OPEN FLOOR VRU #: 002021590
	12/22/10	AP	T/S: 12/22/2010 12:20 PM MREARIC -----
R425 01	1/18/11	MR	FOUR TRADE ROUGH IN VRU #: 002029478
	1/18/11	DA	T/S: 01/18/2011 12:21 PM MREARIC ----- support valley sheathing drain test low leak at tub drain, 2nd fl boots on roof ok to side and ins.
I129 01	1/20/11	TI	R*INSULATION INSPECTION VRU #: 002030245
	1-20-11	AP-MR	
R425 02	1/20/11	TI	FOUR TRADE ROUGH IN VRU #: 002030492
	1-20-11	AP-MR	

COMMENTS AND NOTES

ADDRESS : 40 CAMERON PINES DR SUBDIV: CAMERON PINES 19 LOTS  
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347  
 OWNER : WYNN CONSTRUCTION PHONE : (919) 539-2077  
 PARCEL : 03-9586- - -0024- -57-  
 APPL NUMBER: 10-50024734 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 06/30/2010 01:28 PM RDCONTE ---  
 40 CAMERON PINES DR / CAMERON PINES #19  
 TAKE 27W, T/L ON BUFFALO LAKES RD. GO  
 APPROX 1/4MI, T/L INTO SUBDIVISION  
 \*\*\*PWR CO: CEMC\*\*\*

STRUCTURE: 000 000 60X60 CRAWL 3BD/3BA W/GAR & DECK  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/14/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002017929
	12/14/10	AP	T/S: 12/14/2010 12:34 PM MREARIC -----
A814 01	12/17/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002019958
	12/16/10	AP	40 CAMERON PINES DR LOT 19 SANFORD 273323----- T/S: 12/16/2010 03:47 PM TWARD ----- ✓40 CAMERON PINES DR LOT 19 SANFORD 27332-----
B103 01	12/20/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002019974
	12/20/10	AP	T/S: 12/20/2010 01:25 PM MREARIC -----
B105 01	12/22/10	MR	R*OPEN FLOOR VRU #: 002021590
	12/22/10	AP	T/S: 12/22/2010 12:20 PM MREARIC -----
R425 01	1/18/11	MR	FOUR TRADE ROUGH IN VRU #: 002029478
	1/18/11	DA	T/S: 01/18/2011 12:21 PM MREARIC ----- support valley sheathing drain test low leak at tub drain, 2nd fl boots on roof ok to side and ins.
I129 01	1/20/11	MR	R*INSULATION INSPECTION VRU #: 002030245
	1/20/11	AP	T/S: 01/20/2011 12:26 PM MREARIC -----
R425 02	1/20/11	MR	FOUR TRADE ROUGH IN VRU #: 002030492
	1/20/11	AP	T/S: 01/20/2011 12:26 PM MREARIC -----
H824 01	1/31/11	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002036481
	1/31/11	AP	T/S: 02/01/2011 09:56 AM SZIMMER ----- T/S: 02/01/2011 09:57 AM SZIMMER -----
R429 01	3/03/11	TI	FOUR TRADE FINAL VRU #: 002047629

3-3-11 DP-MR

COMMENTS AND NOTES

above kitch Ⓟ  
 install Breaker  
 Kitch ASCI ?

ADDRESS : 40 CAMERON PINES DR SUBDIV: CAMERON PINES 19 LOTS  
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347  
 OWNER : WYNN CONSTRUCTION PHONE : (919) 539-2077  
 PARCEL : 03-9586- - -0024- -57-  
 APPL NUMBER: 10-50024734 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 06/30/2010 01:28 PM RDCONTE ---  
 40 CAMERON PINES DR / CAMERON PINES #19  
 TAKE 27W, T/L ON BUFFALO LAKES RD. GO  
 APPROX 1/4MI, T/L INTO SUBDIVISION  
 \*\*\*PWR CO: CEMC\*\*\*

**STRUCTURE: 000 000 60X60 CRAWL 3BD/3BA W/GAR & DECK**

FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/14/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002017929
	12/14/10	AP	T/S: 12/14/2010 12:34 PM MREARIC -----
A814 01	12/17/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002019958
	12/16/10	AP	40 CAMERON PINES DR LOT 19 SANFORD 273323----- T/S: 12/16/2010 03:47 PM TWARD ----- ✓40 CAMERON PINES DR LOT 19 SANFORD 27332-----
B103 01	12/20/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002019974
	12/20/10	AP	T/S: 12/20/2010 01:25 PM MREARIC -----
B105 01	12/22/10	MR	R*OPEN FLOOR VRU #: 002021590
	12/22/10	AP	T/S: 12/22/2010 12:20 PM MREARIC -----
R425 01	1/18/11	MR	FOUR TRADE ROUGH IN VRU #: 002029478
	1/18/11	DA	T/S: 01/18/2011 12:21 PM MREARIC ----- support valley sheathing drain test low leak at tub drain, 2nd fl boots on roof ok to side and ins.
I129 01	1/20/11	MR	R*INSULATION INSPECTION VRU #: 002030245
	1/20/11	AP	T/S: 01/20/2011 12:26 PM MREARIC -----
R425 02	1/20/11	MR	FOUR TRADE ROUGH IN VRU #: 002030492
	1/20/11	AP	T/S: 01/20/2011 12:26 PM MREARIC -----
H824 01	1/31/11	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002036481
	1/31/11	AP	T/S: 02/01/2011 09:56 AM SZIMMER ----- T/S: 02/01/2011 09:57 AM SZIMMER -----
R429 01	3/03/11	MR	FOUR TRADE FINAL VRU #: 002047629
	3/03/11	DP	T/S: 03/03/2011 12:10 PM MREARIC ----- move kitchen outlet install breaker on air handler install afci on kitchen light circuit
R429 02	3/04/11	TI	FOUR TRADE FINAL VRU #: 002049328

*3-9-11 AP-IVR*

COMMENTS AND NOTES

County of Harnett  
Building Inspections Department  
Planning Services

**Certificate of Compliance: X Occupancy: X**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: R-3

**Permit Numbers**

Name: Wynn Construction

Building: 10-50024734

Address: 40 Cameron Pines Dr.

Electrical: 11

Insulation: 11

Plumbing: 11

Mechanical: i

MFG Home: \_\_\_\_\_

Date: 3-4-11

Building Official: G. Michael Ream