
ADDRESS . . : 549 POPE LAKE RD
CONTRACTOR :
OWNER . . . : SEBA C & JOYCE H JONES
PARCEL . . . : 04-0692- - -0006- -05-
APPL NUMBER: 10-50024761 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 07/06/2010 03:59 PM RDCONTE ---
549 POPE LAKE RD / POPES LAKE #4
TAKE MAIN ST NORTH, T/L TOWARDS
CAMPBELL UNIV. T/L ON LESLIE CAMPBELL
AVE. T/L ON NC #55 IN COATS. T/R ON OLD
STAGE RD. T/R ON LANGDON RD. TAKE 1ST
LEFT ON POPE LAKE RD. GO APPROX .5 MI.
TURN INTO S/D 1ST LOT ON LEFT
CONTAINING S/D SIGN.
PWR CO: WAITING ON CUS

SUBDIV:
PHONE :
PHONE :

STRUCTURE: 000 000 70.2X56 CRAWL 3BD/3BA W/GAR & FIN BN RM

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00
SEPTIC - EXISTING? : NEW TANK
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/07/10 <u>9-7</u>	TI <u>AP</u> KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001979112

----- COMMENTS AND NOTES -----



Harnett County

INSPECTOR: IVR

DATE 9/15/10

ADDRESS . . : 549 POPE LAKE RD
 CONTRACTOR :
 OWNER . . . : SEBA C & JOYCE H JONES
 PARCEL . . . : 04-0692- - -0006- -05-
 APPL NUMBER: 10-50024761 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 07/06/2010 03:59 PM RDCONTE ---
 549 POPE LAKE RD / POPES LAKE #4
 TAKE MAIN ST NORTH, T/L TOWARDS
 CAMPBELL UNIV. T/L ON LESLIE CAMPBELL
 AVE. T/L ON NC #55 IN COATS. T/R ON OLD
 STAGE RD. T/R ON LANGDON RD. TAKE 1ST
 LEFT ON POPE LAKE RD. GO APPROX .5 MI.
 TURN INTO S/D 1ST LOT ON LEFT
 CONTAINING S/D SIGN.
 PWR CO: WAITING ON CUS
 T/S: 09/13/2010 03:23 PM NTART -----

SUBDIV:
 PHONE :
 PHONE :

18592388

STRUCTURE: 000 000 70.2X56 CRAWL 3BD/3BA W/GAR & FIN BN RM

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00
 SEPTIC - EXISTING? : NEW TANK

PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/07/10	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001979112
	9/07/10	AP	T/S: 09/13/2010 03:14 PM NTART -----
B103 01	9/15/10	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001982304

9-15 AP

COMMENTS AND NOTES

ADDRESS . : 549 POPE LAKE RD
CONTRACTOR :
OWNER . . : SEBA C & JOYCE H JONES
PARCEL . . : 04-0692- - -0006- -05-
APPL NUMBER: 10-50024761 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 07/06/2010 03:59 PM RDCONTE ---
549 POPE LAKE RD / POPES LAKE #4
TAKE MAIN ST NORTH, T/L TOWARDS
CAMPBELL UNIV. T/L ON LESLIE CAMPBELL
AVE. T/L ON NC #55 IN COATS. T/R ON OLD
STAGE RD. T/R ON LANGDON RD. TAKE 1ST
LEFT ON POPE LAKE RD. GO APPROX .5 MI.
TURN INTO S/D 1ST LOT ON LEFT
CONTAINING S/D SIGN.
PWR CO: WAITING ON CUS
T/S: 09/13/2010 03:23 PM NTART -----

SUBDIV:
PHONE :
PHONE :

STRUCTURE: 000 000 70.2X56 CRAWL 3BD/3BA W/GAR & FIN BN RM

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00
SEPTIC - EXISTING? : NEW TANK
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/07/10	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001979112
	9/07/10	AP	T/S: 09/13/2010 03:14 PM NTART -----
B103 01	9/15/10	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001982304
	9/15/10	AP	
B105 01	9/20/10	TI	R*OPEN FLOOR VRU #: 001983811

9-20 AP

KS

COMMENTS AND NOTES -----

ADDRESS . . : 549 POPE LAKE RD
CONTRACTOR :
OWNER . . : SEBA C & JOYCE H JONES
PARCEL . . : 04-0692- - -0006- -05-
APPL NUMBER: 10-50024761 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 07/06/2010 03:59 PM RDCONTE ---
549 POPE LAKE RD / POPES LAKE #4
TAKE MAIN ST NORTH, T/L TOWARDS
CAMPBELL UNIV. T/L ON LESLIE CAMPBELL
AVE. T/L ON NC #55 IN COATS. T/R ON OLD
STAGE RD. T/R ON LANGDON RD. TAKE 1ST
LEFT ON POPE LAKE RD. GO APPROX .5 MI.
TURN INTO S/D 1ST LOT ON LEFT
CONTAINING S/D SIGN.
PWR CO: WAITING ON CUS
T/S: 09/13/2010 03:23 PM NTART -----

SUBDIV:
PHONE :
PHONE :

STRUCTURE: 000 000 70.2X56 CRAWL 3BD/3BA W/GAR & FIN BN RM

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00
SEPTIC - EXISTING? : NEW TANK
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/07/10	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001979112
	9/07/10	AP	T/S: 09/13/2010 03:14 PM NTART -----
B103 01	9/15/10	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001982304
	9/15/10	AP	
B105 01	9/20/10	KS	R*OPEN FLOOR VRU #: 001983811
	9/20/10	AP	
A814 01	9/23/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001983802
	9/20/10	AP	T/S: 09/20/2010 09:54 AM TWARD ----- 549 pope lake rd angier 27501 T/S: 09/20/2010 09:55 AM TWARD -----
H824 01	10/13/10	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001993773
	10/13/10	DA	OPERATIONS PERMIT ON HOLD FOR WATER LINE TO BE CHECKED PER JAMES MANHART. T/S: 10/13/2010 08:34 AM SSTEWARD ----- T/S: 10/13/2010 08:35 AM SSTEWARD -----
R427 01	10/14/10	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001993922

10-14-10 DABS

COMMENTS AND NOTES

ADDRESS . . : 549 POPE LAKE RD SUBDIV:
 CONTRACTOR : PHONE :
 OWNER . . . : SEBA C & JOYCE H JONES PHONE :
 PARCEL . . . : 04-0692- - -0006- -05-
 APPL NUMBER: 10-50024761 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 07/06/2010 03:59 PM RDCONTE ---
 549 POPE LAKE RD / POPES LAKE #4
 TAKE MAIN ST NORTH, T/L TOWARDS
 CAMPBELL UNIV. T/L ON LESLIE CAMPBELL
 AVE. T/L ON NC #55 IN COATS. T/R ON OLD
 STAGE RD. T/R ON LANGDON RD. TAKE 1ST
 LEFT ON POPE LAKE RD. GO APPROX .5 MI.
 TURN INTO S/D 1ST LOT ON LEFT
 CONTAINING S/D SIGN.
 PWR CO: WAITING ON CUS
 T/S: 09/13/2010 03:23 PM NTART -----

STRUCTURE: 000 000 70.2X56 CRAWL 3BD/3BA W/GAR & FIN BN RM
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/07/10	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001979112
	9/07/10	AP	T/S: 09/13/2010 03:14 PM NTART -----
B103 01	9/15/10	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001982304
	9/15/10	AP	
B105 01	9/20/10	KS	R*OPEN FLOOR VRU #: 001983811
	9/20/10	AP	
A814 01	9/23/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001983802
	9/20/10	AP	T/S: 09/20/2010 09:54 AM TWARD ----- 549 pope lake rd angier 27501 T/S: 09/20/2010 09:55 AM TWARD -----
H824 01	10/13/10	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001993773
	10/13/10	DA	OPERATIONS PERMIT ON HOLD FOR WATER LINE TO BE CHECKED PER JAMES MANHART. T/S: 10/13/2010 08:34 AM SSTEWARD ----- T/S: 10/13/2010 08:35 AM SSTEWARD -----
R427 01	10/14/10	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001993922
	10/14/10	DA	1. Firestop all penetrations top plate and bottom plate/floors. 2. Install insulation baffles in all cathedrals. 3. Install fireplace and all gas lines and test. 4. Need support in garage ceiling for valley load points from above. 5. Complete roofing installation/roof boots. OK TO SIDE (Brick) DO NOT INSULATE
R427 02	10/26/10	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001998111

10/26/10 TI

COMMENTS AND NOTES

ADDRESS : 549 POPE LAKE RD SUBDIV:
 CONTRACTOR : PHONE :
 OWNER : SEBA C & JOYCE H JONES PHONE :
 PARCEL : 04-0692- - -0006- -05-
 APPL NUMBER: 10-50024761 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 07/06/2010 03:59 PM RDCONTE ---
 549 POPE LAKE RD / POPES LAKE #4
 TAKE MAIN ST NORTH, T/L TOWARDS
 CAMPBELL UNIV. T/L ON LESLIE CAMPBELL
 AVE. T/L ON NC #55 IN COATS. T/R ON OLD
 STAGE RD. T/R ON LANGDON RD. TAKE 1ST
 LEFT ON POPE LAKE RD. GO APPROX .5 MI.
 TURN INTO S/D 1ST LOT ON LEFT
 CONTAINING S/D SIGN.
 PWR CO: WAITING ON CUS
 T/S: 09/13/2010 03:23 PM NTART -----

STRUCTURE: 000 000 70.2X56 CRAWL 3BD/3BA W/GAR & FIN BN RM
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/07/10	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001979112
	9/07/10	AP	T/S: 09/13/2010 03:14 PM NTART -----
B103 01	9/15/10	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001982304
	9/15/10	AP	
B105 01	9/20/10	KS	R*OPEN FLOOR VRU #: 001983811
	9/20/10	AP	
A814 01	9/23/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001983802
	9/20/10	AP	T/S: 09/20/2010 09:54 AM TWARD ----- 549 pope lake rd angier 27501 T/S: 09/20/2010 09:55 AM TWARD -----
H824 01	10/13/10	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001993773
	10/13/10	DA	OPERATIONS PERMIT ON HOLD FOR WATER LINE TO BE CHECKED PER JAMES MANHART. T/S: 10/13/2010 08:34 AM SSTEWARD ----- T/S: 10/13/2010 08:35 AM SSTEWARD -----
R427 01	10/14/10	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001993922
	10/14/10	DA	1. Firestop all penetrations top plate and bottom plate/floors. 2. Install insulation baffles in all cathedrals. 3. Install fireplace and all gas lines and test. 4. Need support in garage ceiling for valley load points from above. 5. Complete roofing installation/roof boots. OK TO SIDE (Brick) DO NOT INSULATE
R427 02	10/26/10	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001998111
	10/26/10	DA	Gas piping incomplete/ no test. will check gas piping at insulation inspection. Recall 1 trade roughin and insulation
I129 01	10/29/10	TI	R*INSULATION INSPECTION VRU #: 002000156
	<u>10-29-10</u>	<u>APBS</u>	We would prefer an afternoon inspection if possible.
R127 01	10/29/10	TI	ONE TRADE ROUGH IN > 2500 VRU #: 002000131

CONTINUED ONTO NEXT PAGE

ADDRESS . : 549 POPE LAKE RD
CONTRACTOR :
OWNER . . : SEBA C & JOYCE H JONES
PARCEL . . : 04-0692- - -0006- -05-
APPL NUMBER: 10-50024761 CP NEW RESIDENTIAL (SFD)

SUBDIV:
PHONE :
PHONE :

REQUESTED INSP DESCRIPTION
TYP/SQ COMPLETED RESULT RESULTS/COMMENTS

10-29-10 APBS We would prefer an afternoon inspection if possible.

----- COMMENTS AND NOTES -----

ADDRESS : 549 POPE LAKE RD SUBDIV:
 CONTRACTOR : PHONE :
 OWNER : SEBA C & JOYCE H JONES PHONE :
 PARCEL : 04-0692- - -0006- -05-
 APPL NUMBER: 10-50024761 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 07/06/2010 03:59 PM RDCONTE ---
 549 POPE LAKE RD / POPES LAKE #4
 TAKE MAIN ST NORTH, T/L TOWARDS
 CAMPBELL UNIV. T/L ON LESLIE CAMPBELL
 AVE. T/L ON NC #55 IN COATS. T/R ON OLD
 STAGE RD. T/R ON LANGDON RD. TAKE 1ST
 LEFT ON POPE LAKE RD. GO APPROX .5 MI.
 TURN INTO S/D 1ST LOT ON LEFT
 CONTAINING S/D SIGN.
 PWR CO: WAITING ON CUS
 T/S: 09/13/2010 03:23 PM NTART -----

STRUCTURE: 000 000 70.2X56 CRAWL 3BD/3BA W/GAR & FIN BN RM
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/07/10	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001979112
	9/07/10	AP	T/S: 09/13/2010 03:14 PM NTART -----
B103 01	9/15/10	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001982304
	9/15/10	AP	
B105 01	9/20/10	KS	R*OPEN FLOOR VRU #: 001983811
	9/20/10	AP	
A814 01	9/23/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001983802
	9/20/10	AP	T/S: 09/20/2010 09:54 AM TWARD ----- ✓ 549 pope lake rd angier 27501 T/S: 09/20/2010 09:55 AM TWARD -----
H824 01	10/13/10	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001993773
	10/13/10	DA	OPERATIONS PERMIT ON HOLD FOR WATER LINE TO BE CHECKED PER JAMES MANHART. T/S: 10/13/2010 08:34 AM SSTEWARD ----- T/S: 10/13/2010 08:35 AM SSTEWARD -----
R427 01	10/14/10	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001993922
	10/14/10	DA	1. Firestop all penetrations top plate and bottom plate/floors. 2. Install insulation baffles in all cathedrals. 3. Install fireplace and all gas lines and test. 4. Need support in garage ceiling for valley load points from above. 5. Complete roofing installation/roof boots. OK TO SIDE (Brick) DO NOT INSULATE
R427 02	10/26/10	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001998111
	10/26/10	DA	Gas piping incomplete/ no test. will check gas piping at insulation inspection. Recall 1 trade roughin and insulation
I129 01	10/29/10	BS	R*INSULATION INSPECTION VRU #: 002000156
	10/29/10	AP	We would prefer an afternoon inspection if possible. T/S: October 29, 2010 12:26 PM BSUTTON -----

----- CONTINUED ONTO NEXT PAGE -----

ADDRESS : 549 POPE LAKE RD
CONTRACTOR :
OWNER : SEBA C & JOYCE H JONES
PARCEL : 04-0692- - -0006- -05-
APPL NUMBER: 10-50024761 CP NEW RESIDENTIAL (SFD)

SUBDIV:
PHONE :
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R127 01	10/29/10 10/29/10	BS AP	ONE TRADE ROUGH IN > 2500 VRU #: 002000131 We would prefer an afternoon inspection if possible. T/S: October 29, 2010 12:26 PM BSUTTON -----
H824 02	12/14/10 12/14/10	JM AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002018901 T/S: 12/14/2010 09:54 AM SZIMMER ----- T/S: 12/14/2010 09:54 AM SZIMMER -----
R431 01	12/16/10 <u>12-16-10</u>	TI <u>DPBS</u>	FOUR TRADE FINAL >2500 VRU #: 002019370 Final inspection on house for C/O. If at all possible morning inspection. Thank you

----- COMMENTS AND NOTES -----

ADDRESS : 549 POPE LAKE RD SUBDIV:
CONTRACTOR : PHONE :
OWNER : SEBA C & JOYCE H JONES PHONE :
PARCEL : 04-0692- - -0006- -05-
APPL NUMBER: 10-50024761 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 07/06/2010 03:59 PM RDCONTE ---
549 POPE LAKE RD / POPES LAKE #4
TAKE MAIN ST NORTH, T/L TOWARDS
CAMPBELL UNIV. T/L ON LESLIE CAMPBELL
AVE. T/L ON NC #55 IN COATS. T/R ON OLD
STAGE RD. T/R ON LANGDON RD. TAKE 1ST
LEFT ON POPE LAKE RD. GO APPROX .5 MI.
TURN INTO S/D 1ST LOT ON LEFT
CONTAINING S/D SIGN.
PWR CO: WAITING ON CUS
T/S: 09/13/2010 03:23 PM NTART -----

STRUCTURE: 000 000 70.2X56 CRAWL 3BD/3BA W/GAR & FIN BN RM
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/07/10	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001979112
	9/07/10	AP	T/S: 09/13/2010 03:14 PM NTART -----
B103 01	9/15/10	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001982304
	9/15/10	AP	
B105 01	9/20/10	KS	R*OPEN FLOOR VRU #: 001983811
	9/20/10	AP	
A814 01	9/23/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001983802
	9/20/10	AP	T/S: 09/20/2010 09:54 AM TWARD ----- √ 549 pope lake rd angier 27501 T/S: 09/20/2010 09:55 AM TWARD -----
H824 01	10/13/10	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001993773
	10/13/10	DA	OPERATIONS PERMIT ON HOLD FOR WATER LINE TO BE CHECKED PER JAMES MANHART. T/S: 10/13/2010 08:34 AM SSTEWARD ----- T/S: 10/13/2010 08:35 AM SSTEWARD -----
R427 01	10/14/10	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001993922
	10/14/10	DA	1. Firestop all penetrations top plate and bottom plate/floors. 2. Install insulation baffles in all cathedrals. 3. Install fireplace and all gas lines and test. 4. Need support in garage ceiling for valley load points from above. 5. Complete roofing installation/roof boots. OK TO SIDE (Brick) DO NOT INSULATE
R427 02	10/26/10	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001998111
	10/26/10	DA	Gas piping incomplete/ no test. will check gas piping at insulation inspection. Recall 1 trade roughin and insulation
I129 01	10/29/10	BS	R*INSULATION INSPECTION VRU #: 002000156
	10/29/10	AP	We would prefer an afternoon inspection if possible. T/S: October 29, 2010 12:26 PM BSUTTON -----

----- CONTINUED ONTO NEXT PAGE -----

ADDRESS . : 549 POPE LAKE RD
CONTRACTOR :
OWNER . . : SEBA C & JOYCE H JONES
PARCEL . . : 04-0692- - -0006- -05-
APPL NUMBER: 10-50024761 CP NEW RESIDENTIAL (SFD)

SUBDIV:
PHONE :
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R127 01	10/29/10 10/29/10	BS AP	ONE TRADE ROUGH IN > 2500 VRU #: 002000131 We would prefer an afternoon inspection if possible. T/S: October 29, 2010 12:26 PM BSUTTON -----
H824 02	12/14/10 12/14/10	JM AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002018901 T/S: 12/14/2010 09:54 AM SZIMMER ----- T/S: 12/14/2010 09:54 AM SZIMMER -----
R431 01	12/16/10 12/16/10	BS DP	FOUR TRADE FINAL >2500 VRU #: 002019370 Final inspection on house for C/O. If at all possible morning inspection. Thank you 1. Caulk toilets 2. Insulate around attic access doors. 3. Must have plastic under house (including under porches) 4. Circuit for network must be AFCI protected 5. Mark air handler under house for heat kit installed. 6. Repair insulation on return duct under house at splice. 7. Return duct under house in contact with ground. Must maintain 4 inches clearance. 8. Front porch must have 30 inches or less to grade or install guard rails. 9. Must have handrail on front stairs or grade so there are only 3 steps. 10. Handrail on rear porch must be continuous to bottom step. Change rail or change grade. \$50 re fee (NOTE: KITCHEN ISLAND IS NOT FIXED IN PLACE)
R431 02	12/22/10 <u>12-22-10</u>	TI <u>BSAD</u>	FOUR TRADE FINAL >2500 VRU #: 002021954

----- COMMENTS AND NOTES -----

**County of Harnett
Building Inspections Department
Planning Services**

Certificate of Compliance: ___ Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

Permit Numbers

Name: John D Maia

Building: 10-50024761

Electrical: 10-50024761

Address: 549 Pope Lake Road

Insulation: 10-50024761

Anqier NC 27501

Plumbing: 10-50024761

Mechanical: 10-50024761

MFG Home: NANANANANANA

Date: 12-22-10

Building Official: BSutton