Department of Environment, Health and Natural Resources
Division of Environmental Health
On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:
Address:
Proposed Facility: 3 BEDROOMS
Location of Site:
Water Supply: ☒ Public ☐ Individual ☐ Well ☐ Spring ☐ Other
Evaluation Method: ☒ Auger Boring ☐ Pit ☐ Cut
Type of Wastewater: ☒ Sewage ☐ Industrial Process ☐ Mixed

Date Evaluated: 8/2/10
Design Flow (.1949): 360 gpd
Property Recorded:
Property Size:

PROFILE #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 5-7%	0-36"	G LS	VFR NS/NP					
		36-48"	G S	VFR NS/NP					S &
2		0-24"	G LS	VFR NS/NP					
		24-48"	G S	VFR NS/NP					S &

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	CON	CON
Site LTAR	.8	.8

Other Factors (.1946):
Site Classification (.1948): S
Evaluated By: OT
Others Present:

1x150' @ 36"
PUMP IF NEEDED