Department of Environment, Health and Natural Resources
Division of Environmental Health
On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:
Address: Date Evaluated: 8/2/10
Proposed Facility: 4 [illegible] Design Flow (.1949): 480 gpd Property Size:
Location of Site: Property Recorded:
Water Supply: ☒ Public ☐ Individual ☐ Well ☐ Spring ☐ Other
Evaluation Method: ☒ Auger Boring ☐ Pit ☐ Cut
Type of Wastewater: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 5-7%	0-48"	G S	VFR NS/NP					S.8
2		0-30"	G S	VFR NS/NP					
		30-48"	G LS	VFR NS/NP					S8

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	ODN	ODN
Site LTAR	.8	.8

Other Factors (.1946):
Site Classification (.1948): S
Evaluated By: OC
Others Present: –

4×50' @ 24"-36"