HTE# 10-5-24885

## Harnett County Department of Public Health

## **Improvement Permit**

26257

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: WILL LUCAS RO SUBDIVISION CAROLINA CAKS NEW REPAIR SFD (59 × 3) Site Improvements required prior to Construction Authorization Issuance: Projected Daily Flow: 360 GPD Number of bedrooms: 3 Number Number of Occupants: Basement Tyes No Pump Required: ☐Yes ☐ No ☐May be required based on final location and elevations of facilities Type of Water Supply: 
Community Public Well Distance from well 106 feet Permit valid for: Permit conditions: Date: 8 25 10 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. **Construction Authorization** (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: BILL CLASE HONES PROPERTY LOCATION: WILL LUCPS RO
SUBDIVISION CAROLINA DAYS LOT # 52 Facility Type: SFD (59'×34') New 🗆 Expansion 🗆 Repair Basement? Yes No Basement Fixtures? Yes No (Initial) Wastewater Flow: 360 GPD CONVENTIONAL Type of Wastewater System\*\* (See note below, if applicable CONVENTIONAL Installation Requirements/Conditions Number of trenches Septic Tank Size 1000 gallons Exact length of each trench 370 feet Trench Spacing: \_\_\_\_\_ Feet on Center Pump Tank Size gallons Trenches shall be installed on contour at a Soil Cover: 6-10 inches Maximum Trench Depth of: 18-22 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: \_\_\_\_\_\_ft. TDH vs. \_\_\_\_\_ GPM WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. \*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the positions of this permit. SEE ATTACHED SITE SKETCH Authorized State Agent:

Construction Authorization Expiration Date:

## Harnett County Department of Public Health Site Sketch

PROPERTY LOCATON: WILL LUCAS RO

ISSUED TO: BILL CLARK HOMES SUBDIVISION CAROLINA DAYS LOT # 52

Authorized State Agent: Date: 8/25/10

DRAWING

BASEMENT 100'

15' SETBACX

CONVENTIONAL

REPAIR

ACEA

59'X34'

20' 36'

2 36'

4 4

CAROLINA DAKS CIRCLE