

SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:

Address:

Date Evaluated:

Proposed Facility: 3 BEO ROOM

Design Flow (.1949): 360 gpd

Property Size:

Location of Site:

Property Recorded:

Water Supply:

Public Individual Well Spring Other

Evaluation Method:

Auger Boring Pit Cut

Type of Wastewater:

Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (in.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	15 0-2%	0-6"	G S	VFL NS/NP					
		6"	SBK C	FR S/P	101R7he 6"				US
2		0-24"	G S	VFL NS/NP					
		24-40"	SBK SCL	FR S/P					PS .5
3		0-6"	G S	VFL NS/NP					
		6-36"	SBK SCL	FR S/P	101R7he 32"				PS .4
4		0-12"	G S	VFL NS/NP					
		12-36"	SBK SCL	FR S/P	101R7he 34"				PS .45
5		0-10"	G S	VFL NS/NP					
		10-36"	SBK SCL	FR S/P					PS .45

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): P 3 Evaluated By: [Signature] Others Present: -
Available Space (.1945)			
System Type(s)	PUMP 25%	PUMP 25%	
Site LTAR	.45	.4	