
ADDRESS . . : 117 HONOR LN
 CONTRACTOR : GARY ROBINSON HOMES LLC
 OWNER . . . : H LEIGH BALLANCE
 PARCEL . . . : 01-0547- - -0024- -54-
 APPL NUMBER: 10-50024999 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 08/08/2010 09:55 AM VBROWN -----
 HONOR LANE, GWEN OAKS SUB DIV #54.
 210S, LEFT INTO SUB DIV TACTICLE DR,
 HONOR LANE.

STRUCTURE: 000 000 50X30 3BDR 2.5BATH SFD W DECK, CRAWL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00
 SEPTIC - EXISTING? : NEW SEPTIC

PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/26/10 <u>10/26/10</u>	TI <u>AP DT</u>	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001998483 T/S: 10/25/2010 12:45 PM VBROWN -----

----- COMMENTS AND NOTES -----

ADDRESS . . : 117 HONOR LN
CONTRACTOR : GARY ROBINSON HOMES LLC
OWNER . . . : H LEIGH BALLANCE
PARCEL . . . : 01-0547- - -0024- -54-
APPL NUMBER: 10-50024999 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 08/08/2010 09:55 AM VBROWN ----
HONOR LANE, GWEN OAKS SUB DIV #54.
210S, LEFT INTO SUB DIV TACTICLE DR,
HONOR LANE.

STRUCTURE: 000 000 50X30 3BDR 2.5BATH SFD W DECK, CRAWL
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW SEPTIC
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/26/10	DT	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001998483
	10/26/10	AP	T/S: 10/25/2010 12:45 PM VBROWN -----
B103 01	11/03/10	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 002001576
	<u>11/3/10</u>	<u>AP DT</u>	

----- COMMENTS AND NOTES -----

ADDRESS . . : 117 HONOR LN SUBDIV: GWEN OAKS 63 LOTS
CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
OWNER . . . : H LEIGH BALLANCE PHONE : (910) 977-2562
PARCEL . . . : 01-0547- - -0024- -54-
APPL NUMBER: 10-50024999 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 08/08/2010 09:55 AM VBROWN ----
HONOR LANE, GWEN OAKS SUB DIV #54.
210S, LEFT INTO SUB DIV TACTICLE DR,
HONOR LANE.

STRUCTURE: 000 000 50X30 3BDR 2.5BATH SFD W DECK, CRAWL
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED	INSP	DESCRIPTION
	COMPLETED	RESULT	RESULTS/COMMENTS
B101 01	10/26/10	DT	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001998483
	10/26/10	AP	T/S: 10/25/2010 12:45 PM VBROWN -----
B103 01	11/03/10	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 002001576
	11/03/10	AP	
A814 01	11/05/10	TI	ADDRESS CONFIRMATION VRU #: 002003077
A814 02	11/05/10	TI	ADDRESS CONFIRMATION VRU #: 002003085
B105 01	11/05/10	TI	R*OPEN FLOOR VRU #: 002003093
	<u>11/5/10</u>	<u>AP DT</u>	

----- COMMENTS AND NOTES -----

ADDRESS . . : 117 HONOR LN SUBDIV: GWEN OAKS 63 LOTS
CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
OWNER . . . : H LEIGH BALLANCE PHONE : (910) 977-2562
PARCEL . . . : 01-0547- - -0024- -54-
APPL NUMBER: 10-50024999 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 08/08/2010 09:55 AM VBROWN -----
HONOR LANE, GWEN OAKS SUB DIV #54.
210S, LEFT INTO SUB DIV TACTICLE DR,
HONOR LANE.

STRUCTURE: 000 000 50X30 3BDR 2.5BATH SFD W DECK, CRAWL
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/26/10	DT	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001998483
	10/26/10	AP	T/S: 10/25/2010 12:45 PM VBROWN -----
B103 01	11/03/10	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 002001576
	11/03/10	AP	
B105 01	11/05/10	TW	R*OPEN FLOOR VRU #: 002003093
	11/05/10	AP	T/S: 11/09/2010 02:37 PM TWARD ----- 117 honor ln
A814 02	11/05/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002003085
	11/09/10	AP	T/S: 11/09/2010 02:39 PM TWARD ----- 117 honor ln
			T/S: 11/09/2010 02:40 PM TWARD -----
B105 02	11/10/10	TI	R*OPEN FLOOR TIME: 17:00 VRU #: 002005254
R425 01	11/30/10	TI	FOUR TRADE ROUGH IN VRU #: 002012573

11-30-10 OA JH

----- COMMENTS AND NOTES -----

ADDRESS . . : 117 HONOR LN
 SUBDIV: GWEN OAKS 63 LOTS
 CONTRACTOR : GARY ROBINSON HOMES LLC
 PHONE : (910) 977-2562
 OWNER . . : H LEIGH BALLANCE
 PHONE : (910) 977-2562
 PARCEL . . : 01-0547- - -0024- -54-
 APPL NUMBER: 10-50024999 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 08/08/2010 09:55 AM VBROWN ----
 HONOR LANE, GWEN OAKS SUB DIV #54.
 210S, LEFT INTO SUB DIV TACTICLE DR,
 HONOR LANE.

STRUCTURE: 000 000 50X30 3BDR 2.5BATH SFD W DECK, CRAWL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/26/10	DT	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001998483
	10/26/10	AP	T/S: 10/25/2010 12:45 PM VBROWN -----
B103 01	11/03/10	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 002001576
	11/03/10	AP	
B105 01	11/05/10	TW	R*OPEN FLOOR VRU #: 002003093
	11/05/10	AP	T/S: 11/09/2010 02:37 PM TWARD ----- 117 honor ln
A814 02	11/05/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002003085
	11/09/10	AP	T/S: 11/09/2010 02:39 PM TWARD ----- 117 honor ln
			T/S: 11/09/2010 02:40 PM TWARD -----
B105 02	11/10/10	TI <i>7</i>	R*OPEN FLOOR TIME: 17:00 VRU #: 002005254
R425 01	11/30/10	JH	FOUR TRADE ROUGH IN VRU #: 002012573
	11/30/10	DA	1)This is the wrong address for this house it is on Tactical Dr. <i>Q</i>)Replace notched studs in garage @ anchor bolts. <i>Q</i>)King stud @ porch beam in garage needs to bear all the way to bottom plate. <i>Q</i>)B1A roof truss needs strapping @ point 4. <i>Q</i>)Replace all 10D short nails in 45 degree holes in hangers. <i>Q</i>)3' head of water on drain lines. <i>Q</i>)Support wires in bed 2 on end wall per code.
R425 02	12/01/10	TI	FOUR TRADE ROUGH IN VRU #: 002013100

12-1-10 APJB

COMMENTS AND NOTES

ADDRESS : 117 HONOR LN SUBDIV: GWEN OAKS 63 LOTS
 CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
 OWNER : H LEIGH BALLANCE PHONE : (910) 977-2562
 PARCEL : 01-0547- - -0024- -54-
 APPL NUMBER: 10-50024999 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 08/08/2010 09:55 AM VBROWN ----
 HONOR LANE, GWEN OAKS SUB DIV #54.
 210S, LEFT INTO SUB DIV TACTICLE DR,
 HONOR LANE.

STRUCTURE: 000 000 50X30 3BDR 2.5BATH SFD W DECK, CRAWL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/26/10	DT	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001998483
	10/26/10	AP	T/S: 10/25/2010 12:45 PM VBROWN -----
B103 01	11/03/10	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 002001576
	11/03/10	AP	
B105 01	11/05/10	TW	R*OPEN FLOOR VRU #: 002003093
	11/05/10	AP	T/S: 11/09/2010 02:37 PM TWARD ----- 117 honor ln
A814 02	11/05/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002003085
	11/09/10	AP	T/S: 11/09/2010 02:39 PM TWARD ----- 117 honor ln
			T/S: 11/09/2010 02:40 PM TWARD -----
B105 02	11/10/10	TI	R*OPEN FLOOR TIME: 17:00 VRU #: 002005254
R425 01	11/30/10	JH	FOUR TRADE ROUGH IN VRU #: 002012573
	11/30/10	DA	1)This is the wrong address for this house it is on Tactical Dr. 2)Replace notched studs in garage @ anchor bolts. 3)King stud @ porch beam in garage needs to bear all the way to bottom plate. 4)B1A roof truss needs strapping @ point 4. 5)Replace all 10D short nails in 45 degree holes in hangers. 6)3' head of water on drain lines. 7)Support wires in bed 2 on end wall per code.
R425 02	12/01/10	JH	FOUR TRADE ROUGH IN VRU #: 002013100
	12/01/10	AP	
I129 01	12/02/10	TI	R*INSULATION INSPECTION VRU #: 002013639

12-2-10 APTU

COMMENTS AND NOTES

ADDRESS : 300 TACTICAL DR SUBDIV: GWEN OAKS 63 LOTS
 CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
 OWNER : 210 HIGHWAY DEVELOPMENT LLC PHONE :
 PARCEL : 01-0547- - -0024- -40-
 APPL NUMBER: 10-50024999 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 08/08/2010 09:55 AM VBROWN -----
 HONOR LANE, GWEN OAKS SUB DIV #54.
 210S, LEFT INTO SUB DIV TACTICLE DR,
 HONOR LANE.

STRUCTURE: 000 000 50X30 3BDR 2.5BATH SFD W DECK, CRAWL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/26/10	DT	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001998483
	10/26/10	AP	T/S: 10/25/2010 12:45 PM VBROWN -----
B103 01	11/03/10	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 002001576
	11/03/10	AP	
B105 01	11/05/10	TW	R*OPEN FLOOR VRU #: 002003093
	11/05/10	AP	T/S: 11/09/2010 02:37 PM TWARD ----- 117 honor ln
A814 02	11/05/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002003085
	11/09/10	DA	T/S: 11/09/2010 02:39 PM TWARD ----- 117 honor ln T/S: 11/09/2010 02:40 PM TWARD ----- T/S: 01/10/2011 11:30 AM TWARD -----
B105 02	11/10/10	JH	R*OPEN FLOOR TIME: 17:00 VRU #: 002005254
	1/07/11	AP	
R425 01	11/30/10	JH	FOUR TRADE ROUGH IN VRU #: 002012573
	11/30/10	DA	1)This is the wrong address for this house it is on Tactical Dr. 2)Replace notched studs in garage @ anchor bolts. 3)King stud @ porch beam in garage needs to bear all the way to bottom plate. 4)BIA roof truss needs strapping @ point 4. 5)Replace all 10D short nails in 45 degree holes in hangers. 6)3' head of water on drain lines. 7)Support wires in bed 2 on end wall per code.
R425 02	12/01/10	JH	FOUR TRADE ROUGH IN VRU #: 002013100
	12/01/10	AP	
I129 01	12/02/10	JH	R*INSULATION INSPECTION VRU #: 002013639
	12/02/10	AP	
H824 01	12/21/10	OT	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002022515
	12/21/10	AP	T/S: 12/22/2010 10:09 AM SZIMMER ----- T/S: 12/22/2010 10:10 AM SZIMMER -----
R429 01	1/07/11	RD	FOUR TRADE FINAL VRU #: 002027191
	1/07/11	CA	T/S: 01/07/2011 07:57 AM RDCONTE ----- CUSTOMER ROLLED TO 1/10/11
A814 03	1/10/11	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002028173
	1/10/11	AP	✓300 TACTICAL DR LOT 54 BUNNLEVEL 28323----- T/S: 01/10/2011 11:31 AM TWARD -----
R429 02	1/10/11	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002027506
	1/10/11	CA	T/S: 01/07/2011 07:58 AM RDCONTE -----

CONTINUED ONTO NEXT PAGE

9 # 40449695

ADDRESS : 300 TACTICAL DR
CONTRACTOR : GARY ROBINSON HOMES LLC
OWNER : 210 HIGHWAY DEVELOPMENT LLC
PARCEL : 01-0547- - -0024- -40-
APPL NUMBER: 10-50024999 CP NEW RESIDENTIAL (SFD)

SUBDIV: GWEN OAKS 63 LOTS
PHONE : (910) 977-2562
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
			T/S: 01/10/2011 09:28 AM NTART -----
			T/S: 01/12/2011 10:06 AM NTART -----
			T/S: 01/12/2011 10:07 AM NTART -----
R429 03	1/13/11 <u>1-13-11</u>	TI <u>APJH</u>	FOUR TRADE FINAL TIME: 17:00 VRU #: 002028413
			T/S: 01/12/2011 10:31 AM VBROWN -----
			ADDRESS CONF WAS CONFIRMED NOV 10, 2010. THIS WAS CHECKED OUT BY TAMMY.

----- COMMENTS AND NOTES -----

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: _____ Occupancy:

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

Permit Numbers

Name: Gary Robin Son Homes LLC

Building: _____

Electrical: _____

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: _____

Address: 300 Tactical Dr

Date: 1-13-11

Building Official: _____

James Hall

66648005-01