

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant:

Address:

Date Evaluated:

Proposed Facility: 3 Bedroom

Design Flow (.1949): 360 gpd

Property Size:

Location of Site:

Property Recorded:

Water Supply:  Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR	
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz		
1	LS 7-10%	0-18	G S	VF2 N3/HP					PS .3	
		18-30	SBK SC2	FR SS/SP	REDOX START @ 26"					
		30-40	SBK C	F1 S/P	10YR 7/2 @ 30"	MIX OF SOILS				
		40-58	SBK SC2	FR SS/SP						
		0-19	G S	VF2 N3/HP					PS .3	
		19-23	SBK SC2	FR SS/SP						
		0-18	G S	VF2 N3/HP					PS .3	
		18-40	SBK SC2	FR SS/SP						

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	CON	CON
Site LTAR	.5	.3

Other Factors (.1946): \_\_\_\_\_  
 Site Classification (.1948): PS  
 Evaluated By: JT  
 Others Present: BM