



ADDRESS : 236 EMMA CT  
CONTRACTOR : RAMBEAUT, WAYNE THOMAS  
OWNER : ABJ INVESTMENTS LLC  
PARCEL : 12-0555- - -0216- -25-  
APPL NUMBER: 10-50025082 CP NEW RESIDENTIAL (SFD)

SUBDIV: KENLAN FARMS PH1 SET1 41LOTS  
PHONE : (910) 237-5006  
PHONE :

DIRECTIONS : T/S: 08/20/2010 10:25 AM RDCONTE ---  
236 EMMA COURT / KENLAN FARMS #25  
TAKE 401S. T/R ON JOSEY WILLIAMS. T/L  
ON WIRE RD. T/R INTO KENLAN FARMS ON  
EMMA COURT. LOT IS ON RIGHT.  
\*\*\*PREMISE # WAITING ON CUS\*\*\*

STRUCTURE: 000 000 66X38 CRAWL 3BD/2BA W/GAR,DECK, FIN BN

FLOOD ZONE : FLOOD ZONE X

# BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW TANK

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/09/10 9/09/10	JH DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001980011 1)Missing footing in between garage doors mark on plans if changing to single garage door. 2)Remove all roots from bottom of footing. 3)Remove all stumps in footing to undisterbed soil circled on plans in black ink.
B101 03	9/10/10 <i>9-10-10</i>	TI <i>APJH</i>	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001981596 T/S: 09/13/2010 07:33 AM NTART -----
B101 02	9/10/10 9/10/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001981281 T/S: 09/10/2010 11:08 AM NTART -----

----- COMMENTS AND NOTES -----

-----  
ADDRESS . . : 236 EMMA CT SUBDIV: KENLAN FARMS PH1 SET1 41LOTS  
CONTRACTOR : RAMBEAUT, WAYNE THOMAS PHONE : (910) 237-5006  
OWNER . . . : ABJ INVESTMENTS LLC PHONE :  
PARCEL . . . : 12-0555- - -0216- -25-  
APPL NUMBER: 10-50025082 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 08/20/2010 10:25 AM RDCONTE ---  
236 EMMA COURT / KENLAN FARMS #25  
TAKE 401S. T/R ON JOSEY WILLIAMS. T/L  
ON WIRE RD. T/R INTO KENLAN FARMS ON  
EMMA COURT. LOT IS ON RIGHT.  
\*\*\*PREMISE # WAITING ON CUS\*\*\*  
-----

STRUCTURE: 000 000 66X38 CRAWL 3BD/2BA W/GAR, DECK, FIN BN  
FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
SEPTIC - EXISTING? . . . . : NEW TANK WATER SUPPLY . . . . . : COUNTY  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/09/10 9/09/10	JH DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001980011 1)Missing footing in between garage doors mark on plans if changing to single garage door. 2)Remove all roots from bottom of footing. 3)Remove all stumps in footing to undisterbed soil circled on plans in black ink.
B101 03	9/10/10 9/10/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001981596 T/S: 09/13/2010 07:33 AM NTART ----- T/S: 09/13/2010 07:35 AM NTART -----
B101 02	9/10/10 9/10/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001981281 T/S: 09/10/2010 11:08 AM NTART -----
B103 01	9/14/10 <i>9/14/10</i>	TI <i>APJH</i>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001981661
A814 01	9/14/10 9/13/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001981653 T/S: 09/13/2010 02:07 PM TWARD ----- 236 EMMA CT LOT 25 LINDEN 28356 T/S: 09/13/2010 02:07 PM TWARD -----

----- COMMENTS AND NOTES -----  
-----

-----  
ADDRESS . . : 236 EMMA CT SUBDIV: KENLAN FARMS PH1 SET1 41LOTS  
CONTRACTOR : RAMBEAUT, WAYNE THOMAS PHONE : (910) 237-5006  
OWNER . . : ABJ INVESTMENTS LLC PHONE :  
PARCEL . . : 12-0555- - -0216- -25-  
APPL NUMBER: 10-50025082 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 08/20/2010 10:25 AM RDCONTE ---  
236 EMMA COURT / KENLAN FARMS #25  
TAKE 401S. T/R ON JOSEY WILLIAMS. T/L  
ON WIRE RD. T/R INTO KENLAN FARMS ON  
EMMA COURT. LOT IS ON RIGHT.  
\*\*\*PREMISE # WAITING ON CUS\*\*\*  
-----

STRUCTURE: 000 000 66X38 CRAWL 3BD/2BA W/GAR, DECK, FIN BN  
FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
SEPTIC - EXISTING? . . . . : NEW TANK WATER SUPPLY . . . . . : COUNTY  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/09/10 9/09/10	JH DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001980011 1)Missing footing in between garage doors mark on plans if changing to single garage door. 2)Remove all roots from bottom of footing. 3)Remove all stumps in footing to undisturbed soil circled on plans in black ink.
B101 03	9/10/10 9/10/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001981596 T/S: 09/13/2010 07:33 AM NTART ----- T/S: 09/13/2010 07:35 AM NTART -----
B101 02	9/10/10 9/10/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001981281 T/S: 09/10/2010 11:08 AM NTART ----- -----
B103 01	9/14/10 9/14/10	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001981661 -----
A814 01	9/14/10 9/13/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001981653 T/S: 09/13/2010 02:07 PM TWARD ----- 236 EMMA CT LOT 25 LINDEN 28356 T/S: 09/13/2010 02:07 PM TWARD -----
B105 01	8/27/10 <u>9-27-10</u>	TI <u>AP JV</u>	R*OPEN FLOOR VRU #: 001986959 WOULD LIKE THIS IN THE MORNING.

----- COMMENTS AND NOTES -----

ADDRESS . . : 236 EMMA CT  
 CONTRACTOR : RAMBEAUT, WAYNE THOMAS  
 OWNER . . . : ABJ INVESTMENTS LLC  
 PARCEL . . . : 12-0555- - -0216- -25-  
 APPL NUMBER: 10-50025082 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 08/20/2010 10:25 AM RDCONTE ---  
 236 EMMA COURT / KENLAN FARMS #25  
 TAKE 401S. T/R ON JOSEY WILLIAMS. T/L  
 ON WIRE RD. T/R INTO KENLAN FARMS ON  
 EMMA COURT. LOT IS ON RIGHT.  
 \*\*\*PREMISE # WAITING ON CUS\*\*\*

SUBDIV: KENLAN FARMS PH1 SET1 41LOTS  
 PHONE : (910) 237-5006  
 PHONE :

-----  
**STRUCTURE: 000 000 66X38 CRAWL 3BD/2BA W/GAR, DECK, FIN BN**

FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . : 3.00  
 SEPTIC - EXISTING? . . . . : NEW TANK  
 PROPOSED USE . . . . . : SFD  
 WATER SUPPLY . . . . . : COUNTY

-----  
**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/09/10 9/09/10	JH DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001980011 1)Missing footing in between garage doors mark on plans if changing to single garage door. 2)Remove all roots from bottom of footing. 3)Remove all stumps in footing to undisturbed soil circled on plans in black ink.
B101 03	9/10/10 9/10/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001981596 T/S: 09/13/2010 07:33 AM NTART ----- T/S: 09/13/2010 07:35 AM NTART -----
B101 02	9/10/10 9/10/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001981281 T/S: 09/10/2010 11:08 AM NTART -----
B103 01	9/14/10 9/14/10	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001981661
A814 01	9/14/10 9/13/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001981653 T/S: 09/13/2010 02:07 PM TWARD ----- 236 EMMA CT LOT 25 LINDEN 28356 T/S: 09/13/2010 02:07 PM TWARD -----
B105 01	9/27/10 9/27/10	JH AP	R*OPEN FLOOR VRU #: 001986959 WOULD LIKE THIS IN THE MORNING.
R425 01	10/15/10 <i>10-15-10</i>	TI <i>DAJH</i>	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001993195

-----  
 COMMENTS AND NOTES  
 -----

ADDRESS : 236 EMMA CT  
CONTRACTOR : RAMBEAUT, WAYNE THOMAS  
OWNER : ABJ INVESTMENTS LLC  
PARCEL : 12-0555- - -0216- -25-  
APPL NUMBER: 10-50025082 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 08/20/2010 10:25 AM RDCONTE ---  
236 EMMA COURT / KENLAN FARMS #25  
TAKE 401S. T/R ON JOSEY WILLIAMS. T/L  
ON WIRE RD. T/R INTO KENLAN FARMS ON  
EMMA COURT. LOT IS ON RIGHT.  
\*\*\*PREMISE # WAITING ON CUS\*\*\*

SUBDIV: KENLAN FARMS PH1 SET1 41LOTS  
PHONE : (910) 237-5006  
PHONE :

STRUCTURE: 000 000 66X38 CRAWL 3BD/2BA W/GAR, DECK, FIN BN

FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3.00  
SEPTIC - EXISTING? : NEW TANK

PROPOSED USE : SFD  
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/09/10 9/09/10	JH DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001980011 1)Missing footing in between garage doors mark on plans if changing to single garage door. 2)Remove all roots from bottom of footing. 3)Remove all stumps in footing to undisterbed soil circled on plans in black ink.
B101 03	9/10/10 9/10/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001981596 T/S: 09/13/2010 07:33 AM NTART ----- T/S: 09/13/2010 07:35 AM NTART -----
B101 02	9/10/10 9/10/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001981281 T/S: 09/10/2010 11:08 AM NTART -----
B103 01	9/14/10 9/14/10	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001981661
A814 01	9/14/10 9/13/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001981653 T/S: 09/13/2010 02:07 PM TWARD ----- 236 EMMA CT LOT 25 LINDEN 28356 T/S: 09/13/2010 02:07 PM TWARD -----
B105 01	9/27/10 9/27/10	JH AP	R*OPEN FLOOR VRU #: 001986959 WOULD LIKE THIS IN THE MORNING.
R425 01	10/15/10 10/15/10	JH DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001993195 missing ridge cap on house & shingles are not complete. 2)Need 3' head of water on drain lines. 3)Baffels need to bein house @ roughin inspection.
R425 02	10/18/10 <i>10-18-10 AP JH</i>	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001995083 T/S: 10/15/2010 09:26 AM JBROCK -----

COMMENTS AND NOTES

ADDRESS . . : 236 EMMA CT  
CONTRACTOR : RAMBEAUT, WAYNE THOMAS  
OWNER . . . : ABJ INVESTMENTS LLC  
PARCEL . . . : 12-0555- - -0216- -25-  
APPL NUMBER: 10-50025082 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 08/20/2010 10:25 AM RDCONTE ---  
236 EMMA COURT / KENLAN FARMS #25  
TAKE 401S. T/R ON JOSEY WILLIAMS. T/L  
ON WIRE RD. T/R INTO KENLAN FARMS ON  
EMMA COURT. LOT IS ON RIGHT.  
\*\*\*PREMISE # WAITING ON CUS\*\*\*

**STRUCTURE: 000 000 66X38 CRAWL 3BD/2BA W/GAR, DECK, FIN BN**

FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . : 3.00  
SEPTIC - EXISTING? . . . . : NEW TANK

PROPOSED USE . . . . . : SFD  
WATER SUPPLY . . . . . : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/09/10 9/09/10	JH DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001980011 1)Missing footing in between garage doors mark on plans if changing to single garage door. 2)Remove all roots from bottom of footing. 3)Remove all stumps in footing to undisterbed soil circled on plans in black ink.
B101 03	9/10/10 9/10/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001981596 T/S: 09/13/2010 07:33 AM NTART ----- T/S: 09/13/2010 07:35 AM NTART -----
B101 02	9/10/10 9/10/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001981281 T/S: 09/10/2010 11:08 AM NTART -----
B103 01	9/14/10 9/14/10	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001981661
A814 01	9/14/10 9/13/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001981653 T/S: 09/13/2010 02:07 PM TWARD ----- 236 EMMA CT LOT 25 LINDEN 28356 T/S: 09/13/2010 02:07 PM TWARD -----
B105 01	9/27/10 9/27/10	JH AP	R*OPEN FLOOR VRU #: 001986959 WOULD LIKE THIS IN THE MORNING.
R425 01	10/15/10 10/15/10	JH DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001993195 missing ridge cap on house & shingles are not complete. 2)Need 3' head of water on drain lines. 3)Baffels need to bein house @ roughin inspection.
R425 02	10/18/10 10/18/10	JH AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001995083 T/S: 10/15/2010 09:26 AM JBROCK -----
I129 01	10/20/10 <i>10-20-10</i>	TI <i>AP Td</i>	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001996164 T/S: 10/19/2010 10:24 AM JBROCK -----

----- COMMENTS AND NOTES -----

ADDRESS . . : 236 EMMA CT  
CONTRACTOR : RAMBEAUT, WAYNE THOMAS  
OWNER . . . : ABJ INVESTMENTS LLC  
PARCEL . . . : 12-0555- - -0216- -25-  
APPL NUMBER: 10-50025082 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 08/20/2010 10:25 AM RDCONTE ---  
236 EMMA COURT / KENLAN FARMS #25  
TAKE 401S. T/R ON JOSEY WILLIAMS. T/L  
ON WIRE RD. T/R INTO KENLAN FARMS ON  
EMMA COURT. LOT IS ON RIGHT.  
\*\*\*PREMISE # WAITING ON CUS\*\*\*

SUBDIV: KENLAN FARMS PH1 SET1 41LOTS  
PHONE : (910) 237-5006  
PHONE :

STRUCTURE: 000 000 66X38 CRAWL 3BD/2BA W/GAR, DECK, FIN BN

FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . : 3.00 PROPOSED USE . . . . : SFD  
SEPTIC - EXISTING? . . . : NEW TANK WATER SUPPLY . . . . : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/09/10 9/09/10	JH DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001980011 1)Missing footing in between garage doors mark on plans if changing to single garage door. 2)Remove all roots from bottom of footing. 3)Remove all stumps in footing to undisterbed soil circled on plans in black ink.
B101 03	9/10/10 9/10/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001981596 T/S: 09/13/2010 07:33 AM NTART ----- T/S: 09/13/2010 07:35 AM NTART -----
B101 02	9/10/10 9/10/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001981281 T/S: 09/10/2010 11:08 AM NTART -----
B103 01	9/14/10 9/14/10	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001981661
A814 01	9/14/10 9/13/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001981653 T/S: 09/13/2010 02:07 PM TWARD ----- 236 EMMA CT LOT 25 LINDEN 28356 T/S: 09/13/2010 02:07 PM TWARD -----
B105 01	9/27/10 9/27/10	JH AP	R*OPEN FLOOR VRU #: 001986959 WOULD LIKE THIS IN THE MORNING.
R425 01	10/15/10 10/15/10	JH DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001993195 missing ridge cap on house & shingles are not complete. 2)Need 3' head of water on drain lines. 3)Baffels need to bein house @ roughin inspection.
R425 02	10/18/10 10/18/10	JH AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001995083 T/S: 10/15/2010 09:26 AM JBROCK -----
I129 01	10/20/10 10/20/10	JH AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001996164 T/S: 10/19/2010 10:24 AM JBROCK -----
M305 01	10/29/10	TI	R*PLUMB SEWER CONNECTION VRU #: 001999945
P307 01	10-29-10	TI	R*PLUMB WATER CONNECTION VRU #: 001999937



ADDRESS . . : 236 EMMA CT  
CONTRACTOR : RAMBEAUT, WAYNE THOMAS  
OWNER . . : ABJ INVESTMENTS LLC  
PARCEL . . : 12-0555- - -0216- -25-  
APPL NUMBER: 10-50025082 CP NEW RESIDENTIAL (SFD)

SUBDIV: KENLAN FARMS PH1 SET1 41LOTS  
PHONE : (910) 237-5006  
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
--------	------------------------	----------------	---------------------------------

10-29-10 APJW

----- COMMENTS AND NOTES -----

ADDRESS : 236 EMMA CT SUBDIV: KENLAN FARMS PH1 SET1 41LOTS  
 CONTRACTOR : RAMBEAUT, WAYNE THOMAS PHONE : (910) 237-5006  
 OWNER : ABJ INVESTMENTS LLC PHONE :  
 PARCEL : 12-0555- - -0216- -25-  
 APPL NUMBER: 10-50025082 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 08/20/2010 10:25 AM RDCONTE ---  
 236 EMMA COURT / KENLAN FARMS #25  
 TAKE 401S. T/R ON JOSEY WILLIAMS. T/L  
 ON WIRE RD. T/R INTO KENLAN FARMS ON  
 EMMA COURT. LOT IS ON RIGHT.  
 \*\*\*PREMISE # 63831315\*\*\*\*\*  
 11/17/2010 12:33 PM DJOHNSON --

STRUCTURE: 000 000 66X38 CRAWL 3BD/2BA W/GAR,DECK, FIN BN  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/09/10 9/09/10	JH DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001980011 1)Missing footing in between garage doors mark on plans if changing to single garage door. 2)Remove all roots from bottom of footing. 3)Remove all stumps in footing to undisterbed soil circled on plans in black ink.
B101 03	9/10/10 9/10/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001981596 T/S: 09/13/2010 07:33 AM NTART ----- T/S: 09/13/2010 07:35 AM NTART -----
B101 02	9/10/10 9/10/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001981281 T/S: 09/10/2010 11:08 AM NTART -----
B103 01	9/14/10 9/14/10	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001981661
A814 01	9/14/10 9/13/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001981653 T/S: 09/13/2010 02:07 PM TWARD ----- ✓ 236 EMMA CT LOT 25 LINDEN 28356 T/S: 09/13/2010 02:07 PM TWARD -----
B105 01	9/27/10 9/27/10	JH AP	R*OPEN FLOOR VRU #: 001986959 WOULD LIKE THIS IN THE MORNING.
R425 01	10/15/10 10/15/10	JH DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001993195 missing ridge cap on house & shingles are not complete. 2)Need 3' head of water on drain lines. 3)Baffels need to bein house @ roughin inspection.
R425 02	10/18/10 10/18/10	JH AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001995083 T/S: 10/15/2010 09:26 AM JBROCK -----
I129 01	10/20/10 10/20/10	JH AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001996164 T/S: 10/19/2010 10:24 AM JBROCK -----
H824 01	10/28/10 10/28/10	OT AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002000529 T/S: 10/29/2010 09:47 AM SZIMMER -----

ADDRESS : 236 EMMA CT  
CONTRACTOR : RAMBEAUT, WAYNE THOMAS  
OWNER : ABJ INVESTMENTS LLC  
PARCEL : 12-0555- - -0216- -25-  
APPL NUMBER: 10-50025082 CP NEW RESIDENTIAL (SFD)

SUBDIV: KENLAN FARMS PH1 SET1 41LOTS  
PHONE : (910) 237-5006  
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
M305 01	10/29/10	JH	T/S: 10/29/2010 09:47 AM SZIMMER R*PLUMB SEWER CONNECTION VRU #: 001999945
	10/29/10	AP	
P307 01	10/29/10	JH	R*PLUMB WATER CONNECTION VRU #: 001999937
	10/29/10	AP	
R429 01	11/18/10	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002008373
	<i>11-18-10</i>	<i>APJH</i>	T/S: 11/17/2010 12:28 PM DJOHNSON

----- COMMENTS AND NOTES -----

County of Harnett  
Building Inspections Department  
Planning Services

**Certificate of Compliance: \_\_\_ Occupancy:**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

Name: Ranbeant Constaction

Address: 236 Emma Ct

Date: 11-18-10

Building Official: James T. Bell

**Permit Numbers**

Building: \_\_\_\_\_

Electrical: \_\_\_\_\_

Insulation: \_\_\_\_\_

Plumbing: \_\_\_\_\_

Mechanical: \_\_\_\_\_

MFG Home: \_\_\_\_\_

28052005-01