

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: X Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: R-3

Permit Numbers

Name: Wynn Construction, Inc

Building: 10-50025102

Address: 47 Juno Dr.

Electrical: 11

Insulation: 11

Plumbing: 11

Mechanical: _____

MFG Home: _____

Date: 11-3-11

Building Official: T. Michael Reavis

#8-1792239

ADDRESS . : 47 JUNO DR SUBDIV: TINGEN POINTE 86LOTS
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
 OWNER . . : WYNN CONSTRUCTION INC PHONE : (919) 603-7965
 PARCEL . . : 03-9576- - -0088- -35-
 APPL NUMBER: 10-50025102 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 08/25/2010 02:31 PM JBROCK ----
 TAKE NC 27 W TO OMAHA DR TAKE LEFT ONTO
 OMAHA ITO TINGEN POINTE LEFT ONTO JUNO
 2ND LOT ON LEFT LOT 35

STRUCTURE: 000 000 40X40 3BDR CRAWL W/ DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/11 7/26/11	VC CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002114064 T/S: 07/26/2011 02:48 PM VBROWN ----- cust called and ca insp emmit will reschedule at later date.
B101 02	7/29/11 7/29/11	MR DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002116069 T/S: 07/29/2011 10:33 AM MREARIC ----- need sealed eng letter approving footer support
B101 03	8/02/11 8/02/11	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002117190 T/S: 08/02/2011 09:15 AM MREARIC ----- rec'd eng letter
R427 01	8/09/11 8/08/11	TI CA	FOUR TRADE ROUGH IN >2500 VRU #: 002120046
A814 01	8/09/11 8/08/11	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002120038 47 JUNO DR LOT 35 BROADWAY 27505 --- T/S: 08/08/2011 09:25 AM TWARD -----
B103 01	8/16/11 8/16/11	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 002123784 T/S: 08/16/2011 12:46 PM MREARIC -----
B105 01	8/19/11 8/19/11	MR AP	R*OPEN FLOOR VRU #: 002125219 T/S: 08/19/2011 12:31 PM MREARIC -----
R425 01	9/01/11 9/01/11	FS AP	FOUR TRADE ROUGH IN VRU #: 002130284 T/S: 09/01/2011 02:53 PM FSPIVEY -----
I129 01	9/06/11 9/06/11	FS AP	R*INSULATION INSPECTION VRU #: 002132843 T/S: 09/06/2011 02:52 PM FSPIVEY -----
H824 01	10/05/11 10/05/11	OT AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002145753 T/S: 10/06/2011 10:02 AM SZIMMER ----- T/S: 10/06/2011 10:03 AM SZIMMER -----
R429 01	10/10/11 10/07/11	TI CA	FOUR TRADE FINAL VRU #: 002146397
R429 03	10/28/11 10/28/11	MR DP	FOUR TRADE FINAL VRU #: 002154482 T/S: 10/28/2011 12:29 PM MREARIC ----- exterior not finished under cantilever the float switch must be wired on air handler
R429 02	10/28/11 10/28/11	MR CA	FOUR TRADE FINAL VRU #: 002154474 T/S: 10/28/2011 12:28 PM MREARIC -----
R429 04	11/03/11	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002157097 T/S: 11/02/2011 01:36 PM VBROWN -----

COMMENTS AND NOTES