



North Carolina State Laboratory Public Health  
 Environmental Sciences  
**Microbiology**  
 Certificate of Analysis

P.O. Box 28047  
 306 N. Wilmington St.  
 Raleigh, NC 27611-8047  
<http://slph.ncpublichealth.com>  
 Phone: 919-733-7834  
 Fax: 919-733-8695

**Report To:**  
**HARNETT CO ENVIRONMENTAL HEALTH**  
**307 CORNELIUS HARNETT BLVD**

**Name of System:**  
**DARYLL ROBERTS**  
  
**HWY 27 E**

**LILLINGTON, NC 27546**  
**EIN:566000306EH**

**COURIER #: 14-73-01**

StarLiMS Sample ID: **ES041912-0095001**



Collected: 04/18/2012 15:00  
 Received: 04/19/2012 08:36

**James Manhart**  
**Angela Heybroek**

ES Microbiology ID: **35988**  
 GPS Number:

Sample Source: **New Well**  
 Sampling Point: **Well head**

Well Permit Number:  
**10-5-25146**

Sample Description:  
 Comment: No permit # given with sample.

**Environmental Microbiology - Colilert Profile**

**Method:** SM 9223B

**Test Name: Colilert**

Analyte	Test Result	Analyst	Date
Total Coliform, Colilert	Absent	Joy Hayes	04/20/2012
<i>E. coli</i> , Colilert	Absent	Joy Hayes	04/20/2012

**Report Date:** 04/23/2012

**Reported By:** Joy Hayes

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.