
ADDRESS . . : 34 DIVISION DR
CONTRACTOR : GARY ROBINSON HOMES LLC
OWNER . . . : 210 HIGHWAY DEVELOPMENT LLC
PARCEL . . . : 01-0547- - -0024- -16-
APPL NUMBER: 10-50025190 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 09/13/2010 03:40 PM JBROCK ----
HWY 210 S TURN LEFT INTO S/D ONTO HONOR
LN LOT 14

SUBDIV: GWEN OAKS 63 LOTS
PHONE : (910) 977-2562
PHONE :

STRUCTURE: 000 000 40X50 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00
SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

REQUESTED INSP DESCRIPTION
TYP/SQ COMPLETED RESULT RESULTS/COMMENTS

B101 01 11/30/10 TI R*BLDG FOOTING / TEMP SVC POLE VRU #: 002012565
11-30-10 DA-JH
Premise Number: 45311378

Bottom of footing is not 12" below grade

COMMENTS AND NOTES

ADDRESS : 34 DIVISION DR
CONTRACTOR : GARY ROBINSON HOMES LLC
OWNER : 210 HIGHWAY DEVELOPMENT LLC
PARCEL : 01-0547- - -0024- -16-
APPL NUMBER: 10-50025190 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 09/13/2010 03:40 PM JBROCK ----
HWY 210 S TURN LEFT INTO S/D ONTO HONOR
LN LOT 14

SUBDIV: GWEN OAKS 63 LOTS
PHONE : (910) 977-2562
PHONE :

STRUCTURE: 000 000 40X50 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3000000.00

SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/30/10 11/30/10	JH DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002012565 Premise Number: 45311378 The bottom of footing is not 12" below grade per code-----
B101 02	12/01/10 <u>12-1-10</u>	TI <u>APJH</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002013084 <i>T-pole didnt pass ground rod not driven</i>

COMMENTS AND NOTES
down all the way

ADDRESS . . : 34 DIVISION DR
 CONTRACTOR : GARY ROBINSON HOMES LLC
 OWNER . . . : 210 HIGHWAY DEVELOPMENT LLC
 PARCEL . . . : 01-0547- - -0024- -16-
 APPL NUMBER: 10-50025190 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 09/13/2010 03:40 PM JBROCK ----
 HWY 210 S TURN LEFT INTO S/D ONTO HONOR
 LN LOT 14

SUBDIV: GWEN OAKS 63 LOTS
 PHONE : (910) 977-2562
 PHONE :

STRUCTURE: 000 000 40X50 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00
 SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/30/10 11/30/10	JH DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002012565 Premise Number: 45311378 The bottom of footing is not 12" below grade per code-----
B101 02	12/01/10 12/01/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002013084 T-pole did not pass ground rod not all the way down-----
B103 01	12/06/10 <u>12-6</u>	TH <u>AP</u>	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002013696 T/S: 12/03/2010 12:38 PM DJOHNSON -----

Ground Not driven down

 COMMENTS AND NOTES

Harnett County

INSPECTOR: IVR

DATE 12/08/10

ADDRESS . . : 34 DIVISION DR
 CONTRACTOR : GARY ROBINSON HOMES LLC
 OWNER . . . : 210 HIGHWAY DEVELOPMENT LLC
 PARCEL . . . : 01-0547- - -0024- -16-
 APPL NUMBER: 10-50025190 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 09/13/2010 03:40 PM JBROCK ----
 HWY 210 S TURN LEFT INTO S/D ONTO HONOR
 LN LOT 14

SUBDIV: GWEN OAKS 63 LOTS
 PHONE : (910) 977-2562
 PHONE :

STRUCTURE: 000 000 40X50 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00
 SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/30/10 11/30/10	JH DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002012565 Premise Number: 45311378 The bottom of footing is not 12" below grade per code-----
B101 02	12/01/10 12/01/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002013084 T-pole did not pass ground rod not all the way down-----
B103 01	12/06/10 12/06/10	KS AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002013696 T/S: 12/03/2010 12:38 PM DJOHNSON ----- T/S: 12/06/2010 01:07 PM KSLATTUM ----- T-pole ground rod still not driven in ground
B105 01	12/08/10 <i>12-8-10</i>	TI <i>AP JV</i>	R*OPEN FLOOR VRU #: 002016285

COMMENTS AND NOTES -----

ADDRESS : 20 DIVISION DR SUBDIV: GWEN OAKS 63 LOTS
CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
OWNER : 210 HIGHWAY DEVELOPMENT LLC PHONE :
PARCEL : 01-0547- - -0024- -16-
APPL NUMBER: 10-50025190 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 09/13/2010 03:40 PM JBROCK ----
HWY 210 S TURN LEFT INTO S/D ONTO HONOR
LN LOT 14

STRUCTURE: 000 000 40X50 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/30/10 11/30/10	JH DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002012565 Premise Number: 45311378 The bottom of footing is not 12" below grade per code-----
B101 02	12/01/10 12/01/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002013084 T-pole did not pass ground rod not all the way down-----
B103 01	12/06/10 12/06/10	KS AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002013696 T/S: 12/03/2010 12:38 PM DJOHNSON ----- T/S: 12/06/2010 01:07 PM KSLATTUM ----- T-pole ground rod still not driven in ground
B105 01	12/08/10 12/08/10	JH AP	R*OPEN FLOOR VRU #: 002016285
A814 01	1/10/11 1/10/11	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002028199 20 division dr lot 14 bunnlevel 28323----- T/S: 01/10/2011 12:13 PM TWARD -----
R425 01	1/13/11 <u>1-13-11</u>	TI <i>DA JH</i>	FOUR TRADE ROUGH IN VRU #: 002028637

----- COMMENTS AND NOTES -----

ADDRESS : 20 DIVISION DR SUBDIV: GWEN OAKS 63 LOTS
 CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
 OWNER : 210 HIGHWAY DEVELOPMENT LLC PHONE :
 PARCEL : 01-0547- - -0024- -16-
 APPL NUMBER: 10-50025190 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 09/13/2010 03:40 PM JBROCK ----
 HWY 210 S TURN LEFT INTO S/D ONTO HONOR
 LN LOT 14

STRUCTURE: 000 000 40X50 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/30/10 11/30/10	JH DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002012565 Premise Number: 45311378 The bottom of footing is not 12" below grade per code-----
B101 02	12/01/10 12/01/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002013084 T-pole did not pass ground rod not all the way down-----
B103 01	12/06/10 12/06/10	KS AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002013696 T/S: 12/03/2010 12:38 PM DJOHNSON ----- T/S: 12/06/2010 01:07 PM KSLATTUM ----- T-pole ground rod still not driven in ground
B105 01	12/08/10 12/08/10	JH AP	R*OPEN FLOOR VRU #: 002016285
A814 01	1/10/11 1/10/11	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002028199 20 division dr lot 14 bunnlevel 28323----- T/S: 01/10/2011 12:13 PM TWARD -----
R425 01	1/13/11 1/13/11	JH DA	FOUR TRADE ROUGH IN VRU #: 002028637 ✓ Plumbing test frooze. 2) Need engineer letter for M1 & M1A roof truss for bearing on doble 2x4 leger & need uplift straps @ joint 5. 3) Nail guard on wire 12/2 @ top of stairs. 4) Fire caulk hole over pannel in garage. 5) Exhaust fans not wired. 6) Master bed, bed #2 & media room need a receptacle 6' from the door openings.
I129 01	1/19/11 <u>1-19-11</u>	TI <u>APJTB</u>	R*INSULATION INSPECTION VRU #: 002030393
R425 02	1/19/11 <u>1-19-11</u>	TI <u>APJTB</u>	FOUR TRADE ROUGH IN VRU #: 002030385

COMMENTS AND NOTES

Gary Robinson Homes, LLC.

5511 Ramsey Street, Suite 300

Fayetteville, NC 28311

(910) 401-5505

SCANNED

4-5-11
DATE

April, 4, 2011

Harnett County Permitting Dept,

This letter is to inform you that Custom Heating & Air (License #4508) will now be the HVAC Subcontractor for :

Colonial Hills Lot(s)

#27- Permit #06-50015941

#28- Permit #06-50015946

#40- Permit #06-50015958

#60- Permit #06-50016038

Gwen Oaks Lot(s)

#14- Permit #10-500-25190

#20- Permit #10-500-25191

#55- Permit #10-500-25193

#58- Permit #10-500-25001

All Around Heating will no Longer be the Contractor on these lots.

Please refer any questions to:

Billy Elmore (910) 728-1554



ADDRESS : 20 DIVISION DR SUBDIV: GWEN OAKS 63 LOTS
 CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
 OWNER : 210 HIGHWAY DEVELOPMENT LLC PHONE :
 PARCEL : 01-0547- - -0024- -16-
 APPL NUMBER: 10-50025190 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 09/13/2010 03:40 PM JBROCK ----
 HWY 210 S TURN LEFT INTO S/D ONTO HONOR
 LN LOT 14

STRUCTURE: 000 000 40X50 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/30/10 11/30/10	JH DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002012565 Premise Number: 45311378 The bottom of footing is not 12" below grade per code-----
B101 02	12/01/10 12/01/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002013084 T-pole did not pass ground rod not all the way down-----
B103 01	12/06/10 12/06/10	KS AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002013696 T/S: 12/03/2010 12:38 PM DJOHNSON ----- T/S: 12/06/2010 01:07 PM KSLATTUM ----- T-pole ground rod still not driven in ground
B105 01	12/08/10 12/08/10	JH AP	R*OPEN FLOOR VRU #: 002016285
A814 01	1/10/11 1/10/11	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002028199 ✓ 20 division dr lot 14 bunnlevel 28323----- T/S: 01/10/2011 12:13 PM TWARD -----
R425 01	1/13/11 1/13/11	JH DA	FOUR TRADE ROUGH IN VRU #: 002028637 1)Plumbing test frooze. 2)Need engineer letter for M1 & M1A roof truss for bearing on doble 2x4 leger & need uplift straps @ joint 5. 3)Nail guard on wire 12/2 @ top of stairs.4)Fire caulk hole over pannel in garage. 5)Exhaust fans not wired. 6)Master bed, bed #2 & media room need a receptacle 6' from the door openings.
I129 01	1/19/11 1/19/11	JH AP	R*INSULATION INSPECTION VRU #: 002030393
R425 02	1/19/11 1/19/11	JH AP	FOUR TRADE ROUGH IN VRU #: 002030385
E209 01	2/03/11 2/03/11	TI CA	R*ELEC TEMP POWER CERT VRU #: 002037125 Premise #: 45311378 T/S: 02/03/2011 07:25 AM NTART -----
H824 01	2/03/11 2/03/11	OT AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002037935 T/S: 02/04/2011 10:13 AM SZIMMER ----- T/S: 02/04/2011 10:14 AM SZIMMER -----
R429 01	2/03/11 2/03/11	TI CA	FOUR TRADE FINAL TIME: 17:00 VRU #: 002037489 T/S: 02/03/2011 07:30 AM NTART ----- T/S: 02/03/2011 07:34 AM NTART -----
R429 02	4/05/11	TI	FOUR TRADE FINAL VRU #: 002062461

4-5-11 *DAJB*

COMMENTS AND NOTES

ADDRESS . . : 20 DIVISION DR SUBDIV: GWEN OAKS 63 LOTS
 CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
 OWNER . . . : 210 HIGHWAY DEVELOPMENT LLC PHONE :
 PARCEL . . . : 01-0547- - -0024- -16-
 APPL NUMBER: 10-50025190 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 09/13/2010 03:40 PM JBROCK ----
 HWY 210 S TURN LEFT INTO S/D ONTO HONOR
 LN LOT 14

STRUCTURE: 000 000 40X50 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/30/10 11/30/10	JH DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002012565 Premise Number: 45311378 The bottom of footing is not 12" below grade per code-----
B101 02	12/01/10 12/01/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002013084 T-pole did not pass ground rod not all the way down-----
B103 01	12/06/10 12/06/10	KS AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002013696 T/S: 12/03/2010 12:38 PM DJOHNSON ----- T/S: 12/06/2010 01:07 PM KSLATTUM ----- T-pole ground rod still not driven in ground
B105 01	12/08/10 12/08/10	JH AP	R*OPEN FLOOR VRU #: 002016285
A814 01	1/10/11 1/10/11	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002028199 ✓20 division dr lot 14 bunnlevel 28323----- T/S: 01/10/2011 12:13 PM TWARD -----
R425 01	1/13/11 1/13/11	JH DA	FOUR TRADE ROUGH IN VRU #: 002028637 1)Plumbing test frooze. 2)Need engineer letter for M1 & M1A roof truss for bearing on doble 2x4 leger & need uplift straps @ joint 5. 3)Nail guard on wire 12/2 @ top of stairs.4)Fire caulk hole over pannel in garage. 5)Exhaust fans not wired. 6)Master bed, bed #2 & media room need a receptacle 6' from the door openings.
I129 01	1/19/11 1/19/11	JH AP	R*INSULATION INSPECTION VRU #: 002030393
R425 02	1/19/11 1/19/11	JH AP	FOUR TRADE ROUGH IN VRU #: 002030385
E209 01	2/03/11 2/03/11	TI CA	R*ELEC TEMP POWER CERT VRU #: 002037125 Premise #: 45311378 T/S: 02/03/2011 07:25 AM NTART -----
H824 01	2/03/11 2/03/11	OT AP	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002037935 T/S: 02/04/2011 10:13 AM SZIMMER ----- T/S: 02/04/2011 10:14 AM SZIMMER -----
R429 01	2/03/11 2/03/11	TI CA	FOUR TRADE FINAL TIME: 17:00 VRU #: 002037489 T/S: 02/03/2011 07:30 AM NTART ----- T/S: 02/03/2011 07:34 AM NTART -----
R429 02	4/05/11 4/05/11	JH DA	FOUR TRADE FINAL VRU #: 002062461 1)Need vent wells for vents on front & side of porch. 2)Label AHU in crawl. 3)Strap end of hard pipe duct in crawl. 4)Need receptacle on back of house accessible from

ADDRESS . : 20 DIVISION DR
 CONTRACTOR : GARY ROBINSON HOMES LLC
 OWNER . . : 210 HIGHWAY DEVELOPMENT LLC
 PARCEL . . : 01-0547- - -0024- -16-
 APPL NUMBER: 10-50025190 CP NEW RESIDENTIAL (SFD)

SUBDIV: GWEN OAKS 63 LOTS
 PHONE : (910) 977-2562
 PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R429 03	4/07/11 <u>4/7/11</u>	TI <u>AP DT</u>	grade. FOUR TRADE FINAL VRU #: 002063774 Premise Number: 45311398

----- COMMENTS AND NOTES -----

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: ___ Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Permit Numbers

Name: Gary Robinson Homes LLC

Building: _____

Electrical: _____

Address: 20 Division Dr
Bunnlevel, NC

Insulation: _____

Plumbing: _____

Mechanical: 10-50025190

MFG Home: _____

Date: 4/7/11

Building Official: [Signature]