
ADDRESS . . : 377 TACTICAL DR
 CONTRACTOR : GARY ROBINSON HOMES LLC
 OWNER . . . : 210 HIGHWAY DEVELOPMENT LLC
 PARCEL . . . : 01-0547- - -0024- -25-
 APPL NUMBER: 10-50025192 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 09/13/2010 03:40 PM JBROCK ----
 HWY 210 S TURN LEFT INTO S/D ONTO HONOR
 LN LOT 23

SUBDIV: GWEN OAKS 63 LOTS
 PHONE : (910) 977-2562
 PHONE :

STRUCTURE: 000 000 40X50 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00
 SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/22/10 <i>11-22-10</i>	TI <i>APJW</i>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002009481

COMMENTS AND NOTES

ADDRESS . : 377 TACTICAL DR SUBDIV: GWEN OAKS 63 LOTS
 CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
 OWNER . . : 210 HIGHWAY DEVELOPMENT LLC PHONE :
 PARCEL . . : 01-0547- - -0024- -25-
 APPL NUMBER: 10-50025192 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 09/13/2010 03:40 PM JBROCK ----
 HWY 210 S TURN LEFT INTO S/D ONTO HONOR
 LN LOT 23

STRUCTURE: 000 000 40X50 3BDR CRAWL W/ GARAGE & DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/22/10 11/22/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002009481
B103 01	11/30/10 11/30/10	JH CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 002012599 Premise Number: 08855387 per Billy
B103 02	12/01/10 <u>12-1-10</u>	TI <u>AP JH</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 002013092

COMMENTS AND NOTES

*T-pole didnt pass ground rod needs to
be driven all the way down*

ADDRESS . : 377 TACTICAL DR
CONTRACTOR : GARY ROBINSON HOMES LLC
OWNER . . : 210 HIGHWAY DEVELOPMENT LLC
PARCEL . . : 01-0547- - -0024- -25-
APPL NUMBER: 10-50025192 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 09/13/2010 03:40 PM JBROCK ----
HWY 210 S TURN LEFT INTO S/D ONTO HONOR
LN LOT 23

SUBDIV: GWEN OAKS 63 LOTS
PHONE : (910) 977-2562
PHONE :

STRUCTURE: 000 000 40X50 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3000000.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/22/10	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002009481
	11/22/10	AP	
B103 01	11/30/10	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 002012599
	11/30/10	CA	Premise Number: 08855387 per Billy
B103 02	12/01/10	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 002013092
	12/01/10	AP	T-pole did not pass ground rod not all the way down-----
B105 01	12/03/10	TI	R*OPEN FLOOR VRU #: 002013670

12-3-10 APJH T-pole ground Rod not all the way down

COMMENTS AND NOTES

ADDRESS . . : 377 TACTICAL DR SUBDIV: GWEN OAKS 63 LOTS
CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
OWNER . . . : 210 HIGHWAY DEVELOPMENT LLC PHONE :
PARCEL . . . : 01-0547- - -0024- -25-
APPL NUMBER: 10-50025192 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 09/13/2010 03:40 PM JBROCK -----
HWY 210 S TURN LEFT INTO S/D ONTO HONOR
LN LOT 23

STRUCTURE: 000 000 40X50 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/22/10 11/22/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002009481 -----
B103 01	11/30/10 11/30/10	JH CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 002012599 Premise Number: 08855387 per Billy -----
B103 02	12/01/10 12/01/10	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 002013092 T-pole did not pass ground rod not all the way down-----
B105 01	12/03/10 12/03/10	JH AP	R*OPEN FLOOR VRU #: 002013670 t-pole ground rod not all the way down-----
E207 01	12/06/10 <u>12-6</u>	TI <u>AP</u>	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 002015162 T/S: 12/03/2010 12:41 PM DJOHNSON -----

----- COMMENTS AND NOTES -----

ADDRESS . . : 377 TACTICAL DR SUBDIV: GWEN OAKS 63 LOTS
 CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
 OWNER . . . : 210 HIGHWAY DEVELOPMENT LLC PHONE :
 PARCEL . . . : 01-0547- - -0024- -25-
 APPL NUMBER: 10-50025192 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 09/13/2010 03:40 PM JBROCK ----
 HWY 210 S TURN LEFT INTO S/D ONTO HONOR
 LN LOT 23

STRUCTURE: 000 000 40X50 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/22/10 11/22/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002009481
B103 01	11/30/10 11/30/10	JH CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 002012599 Premise Number: 08855387 per Billy
B103 02	12/01/10 12/01/10	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 002013092 T-pole did not pass ground rod not all the way down-----
B105 01	12/03/10 12/03/10	JH AP	R*OPEN FLOOR VRU #: 002013670 t-pole ground rod not all the way down-----
E207 01	12/06/10 12/06/10	KS AP	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 002015162 T/S: 12/03/2010 12:41 PM DJOHNSON ----- T/S: 12/06/2010 01:08 PM KSLATTUM ----- need premise number
R427 01	1/13/11 1/13/11	JH CA	FOUR TRADE ROUGH IN >2500 VRU #: 002028629 per Billy
A814 01	1/13/11 1/14/11	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002028603 T/S: 01/14/2011 04:46 PM TWARD ----- 377 tactical dr lot 23 bunnlevel 28323 T/S: 01/14/2011 04:46 PM TWARD -----
R425 01	1/19/11 1/19/11	JH CA	FOUR TRADE ROUGH IN VRU #: 002030450 Per Billy
R425 02	1/20/11 <u>1/20/11</u>	TI <u>AP Dr</u>	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002031425 T/S: 01/19/2011 01:03 PM JBROCK -----

COMMENTS AND NOTES

ADDRESS : 377 TACTICAL DR SUBDIV: GWEN OAKS 63 LOTS
 CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
 OWNER : 210 HIGHWAY DEVELOPMENT LLC PHONE :
 PARCEL : 01-0547- - -0024- -25-
 APPL NUMBER: 10-50025192 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 09/13/2010 03:40 PM JBROCK ----
 HWY 210 S TURN LEFT INTO S/D ONTO HONOR
 LN LOT 23

STRUCTURE: 000 000 40X50 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/22/10 11/22/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002009481
B103 01	11/30/10 11/30/10	JH CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 002012599 Premise Number: 08855387 per Billy
B103 02	12/01/10 12/01/10	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 002013092 T-pole did not pass ground rod not all the way down-----
B105 01	12/03/10 12/03/10	JH AP	R*OPEN FLOOR VRU #: 002013670 t-pole ground rod not all the way down-----
E207 01	12/06/10 12/06/10	KS AP	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 002015162 T/S: 12/03/2010 12:41 PM DJOHNSON ----- T/S: 12/06/2010 01:08 PM KSLATTUM ----- need premise number
R427 01	1/13/11 1/13/11	JH CA	FOUR TRADE ROUGH IN >2500 VRU #: 002028629 per Billy
A814 01	1/13/11 1/14/11	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002028603 T/S: 01/14/2011 04:46 PM TWARD ----- 377 tactical dr lot 23 bunnlevel 28323 T/S: 01/14/2011 04:46 PM TWARD -----
R425 01	1/19/11 1/19/11	JH CA	FOUR TRADE ROUGH IN VRU #: 002030450 Per Billy
R425 02	1/20/11 1/20/11	DT AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002031425 T/S: 01/19/2011 01:03 PM JBROCK ----- T/S: 01/24/2011 01:39 PM NTART -----
I129 01	1/25/11 <i>1-25-11</i>	TI <i>QA JB</i>	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002033165 T/S: 01/24/2011 01:40 PM NTART -----
R225 01	1/25/11 <i>1-25-11</i>	TI <i>AP JB</i>	TWO TRADE ROUGH IN TIME: 17:00 VRU #: 002033173 T/S: 01/24/2011 01:40 PM NTART -----

Missing roof boots for plumbin

COMMENTS AND NOTES

ADDRESS : 377 TACTICAL DR
CONTRACTOR : GARY ROBINSON HOMES LLC
OWNER : 210 HIGHWAY DEVELOPMENT LLC
PARCEL : 01-0547- - -0024- -25-
APPL NUMBER: 10-50025192 CP NEW RESIDENTIAL (SFD)

SUBDIV: GWEN OAKS 63 LOTS
PHONE : (910) 977-2562
PHONE :

DIRECTIONS : T/S: 09/13/2010 03:40 PM JBROCK ----
HWY 210 S TURN LEFT INTO S/D ONTO HONOR
LN LOT 23

STRUCTURE: 000 000 40X50 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00
SEPTIC - EXISTING? : NEW
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/22/10 11/22/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002009481
B103 01	11/30/10 11/30/10	JH CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 002012599 Premise Number: 08855387 per Billy
B103 02	12/01/10 12/01/10	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 002013092 T-pole did not pass ground rod not all the way down-----
B105 01	12/03/10 12/03/10	JH AP	R*OPEN FLOOR VRU #: 002013670 t-pole ground rod not all the way down-----
E207 01	12/06/10 12/06/10	KS AP	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 002015162 T/S: 12/03/2010 12:41 PM DJOHNSON ----- T/S: 12/06/2010 01:08 PM KSLATTUM ----- need premise number
R427 01	1/13/11 1/13/11	JH CA	FOUR TRADE ROUGH IN >2500 VRU #: 002028629 per Billy
A814 01	1/13/11 1/14/11	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002028603 T/S: 01/14/2011 04:46 PM TWARD ----- 377 tactical dr lot 23 bunnlevel 28323 T/S: 01/14/2011 04:46 PM TWARD -----
R425 01	1/19/11 1/19/11	JH CA	FOUR TRADE ROUGH IN VRU #: 002030450 Per Billy
R425 02	1/20/11 1/20/11	DT AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002031425 T/S: 01/19/2011 01:03 PM JBROCK ----- T/S: 01/24/2011 01:39 PM NTART -----
I129 01	1/25/11 1/25/11	JH DA	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002033165 T/S: 01/24/2011 01:40 PM NTART ----- Missing roof boots
R225 01	1/25/11 1/25/11	JH AP	TWO TRADE ROUGH IN TIME: 17:00 VRU #: 002033173 T/S: 01/24/2011 01:40 PM NTART -----
I129 02	1/26/11 <u>1-26-11</u>	TI <u>AP JA</u>	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002033975 T/S: 01/25/2011 02:53 PM RDCONTE -----

COMMENTS AND NOTES

ADDRESS : * 377 TACTICAL DR
 CONTRACTOR : GARY ROBINSON HOMES LLC
 OWNER : 210 HIGHWAY DEVELOPMENT LLC
 PARCEL : 01-0547- - -0024- -25-
 APPL NUMBER: 10-50025192 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 09/13/2010 03:40 PM JBROCK ----
 HWY 210 S TURN LEFT INTO S/D ONTO HONOR
 LN LOT 23

SUBDIV: GWEN OAKS 63 LOTS
 PHONE : (910) 977-2562
 PHONE :

STRUCTURE: 000 000 40X50 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00
 SEPTIC - EXISTING? : NEW
 PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/22/10	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002009481
	11/22/10	AP	
B103 01	11/30/10	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 002012599
	11/30/10	CA	Premise Number: 08855387 per Billy
B103 02	12/01/10	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 002013092
	12/01/10	AP	T-pole did not pass ground rod not all the way down-----
B105 01	12/03/10	JH	R*OPEN FLOOR VRU #: 002013670
	12/03/10	AP	t-pole ground rod not all the way down-----
E207 01	12/06/10	KS	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 002015162
	12/06/10	AP	T/S: 12/03/2010 12:41 PM DJOHNSON ----- T/S: 12/06/2010 01:08 PM KSLATTUM ----- need premise number
R427 01	1/13/11	JH	FOUR TRADE ROUGH IN >2500 VRU #: 002028629
	1/13/11	CA	per Billy
A814 01	1/13/11	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002028603
	1/14/11	AP	T/S: 01/14/2011 04:46 PM TWARD ----- ✓ 377 tactical dr lot 23 bunnlevel 28323 T/S: 01/14/2011 04:46 PM TWARD -----
R425 01	1/19/11	JH	FOUR TRADE ROUGH IN VRU #: 002030450
	1/19/11	CA	Per Billy
			T/S: 01/19/2011 09:35 AM JHALL -----
R425 02	1/20/11	DT	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002031425
	1/20/11	AP	T/S: 01/19/2011 01:03 PM JBROCK ----- T/S: 01/24/2011 01:39 PM NTART -----
I129 01	1/25/11	JH	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002033165
	1/25/11	DA	T/S: 01/24/2011 01:40 PM NTART ----- Missing roof boots
R225 01	1/25/11	JH	TWO TRADE ROUGH IN TIME: 17:00 VRU #: 002033173
	1/25/11	AP	T/S: 01/24/2011 01:40 PM NTART -----
I129 02	1/26/11	JH	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002033975
	1/26/11	AP	T/S: 01/25/2011 02:53 PM RDCONTE -----
E209 01	2/03/11	TI	R*ELEC TEMP POWER CERT VRU #: 002037133
	2/03/11	CA	Premise #: 08855387 T/S: 02/03/2011 07:26 AM NTART -----
R429 01	2/03/11	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002037471

ADDRESS : 377 TACTICAL DR
CONTRACTOR : GARY ROBINSON HOMES LLC
OWNER : 210 HIGHWAY DEVELOPMENT LLC
PARCEL : 01-0547- - -0024- -25-
APPL NUMBER: 10-50025192 CP NEW RESIDENTIAL (SFD)

SUBDIV: GWEN OAKS 63 LOTS
PHONE : (910) 977-2562
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	2/03/11	CA	T/S: 02/03/2011 07:26 AM NTART ----- T/S: 02/03/2011 07:26 AM NTART ----- T/S: 02/03/2011 07:33 AM NTART -----
H824 01	2/14/11 2/14/11	OT AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002041853 T/S: 02/15/2011 10:14 AM SZIMMER ----- T/S: 02/16/2011 01:04 PM SSTEWART -----
R429 02	3/28/11 <u>3/28/11</u>	TI <u>TI</u>	FOUR TRADE FINAL VRU #: 002059418

----- COMMENTS AND NOTES -----

ADDRESS : 377 TACTICAL DR
 CONTRACTOR : GARY ROBINSON HOMES LLC
 OWNER : 210 HIGHWAY DEVELOPMENT LLC
 PARCEL : 01-0547- - -0024- -25-
 APPL NUMBER: 10-50025192 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 09/13/2010 03:40 PM JBROCK ----
 HWY 210 S TURN LEFT INTO S/D ONTO HONOR
 LN LOT 23

SUBDIV: GWEN OAKS 63 LOTS
 PHONE : (910) 977-2562
 PHONE :

STRUCTURE: 000 000 40X50 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00
 SEPTIC - EXISTING? : NEW
 PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/22/10	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002009481
	11/22/10	AP	
B103 01	11/30/10	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 002012599
	11/30/10	CA	Premise Number: 08855387 per Billy
B103 02	12/01/10	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 002013092
	12/01/10	AP	T-pole did not pass ground rod not all the way down-----
B105 01	12/03/10	JH	R*OPEN FLOOR VRU #: 002013670
	12/03/10	AP	t-pole ground rod not all the way down-----
E207 01	12/06/10	KS	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 002015162
	12/06/10	AP	T/S: 12/03/2010 12:41 PM DJOHNSON ----- T/S: 12/06/2010 01:08 PM KSLATTUM ----- need premise number
R427 01	1/13/11	JH	FOUR TRADE ROUGH IN >2500 VRU #: 002028629
	1/13/11	CA	per Billy
A814 01	1/13/11	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002028603
	1/14/11	AP	T/S: 01/14/2011 04:46 PM TWARD ----- √377 tactical dr lot 23 bunnlevel 28323 T/S: 01/14/2011 04:46 PM TWARD -----
R425 01	1/19/11	JH	FOUR TRADE ROUGH IN VRU #: 002030450
	1/19/11	CA	Per Billy
R425 02	1/20/11	DT	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002031425
	1/20/11	AP	T/S: 01/19/2011 01:03 PM JBROCK ----- T/S: 01/24/2011 01:39 PM NTART -----
I129 01	1/25/11	JH	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002033165
	1/25/11	DA	T/S: 01/24/2011 01:40 PM NTART ----- Missing roof boots
R225 01	1/25/11	JH	TWO TRADE ROUGH IN TIME: 17:00 VRU #: 002033173
	1/25/11	AP	T/S: 01/24/2011 01:40 PM NTART -----
I129 02	1/26/11	JH	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002033975
	1/26/11	AP	T/S: 01/25/2011 02:53 PM RDCONTE -----
E209 01	2/03/11	TI	R*ELEC TEMP POWER CERT VRU #: 002037133
	2/03/11	CA	Premise #: 08855387 T/S: 02/03/2011 07:26 AM NTART -----
R429 01	2/03/11	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002037471

CONTINUED ONTO NEXT PAGE

ADDRESS : 377 TACTICAL DR
CONTRACTOR : GARY ROBINSON HOMES LLC
OWNER : 210 HIGHWAY DEVELOPMENT LLC
PARCEL : 01-0547- - -0024- -25-
APPL NUMBER: 10-50025192 CP NEW RESIDENTIAL (SFD)

SUBDIV: GWEN OAKS 63 LOTS
PHONE : (910) 977-2562
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	2/03/11	CA	T/S: 02/03/2011 07:26 AM NTART T/S: 02/03/2011 07:26 AM NTART T/S: 02/03/2011 07:33 AM NTART
H824 01	2/14/11	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002041853
	2/14/11	AP	T/S: 02/15/2011 10:14 AM SZIMMER T/S: 02/16/2011 01:04 PM SSTEWARD
R429 02	3/28/11	DT	FOUR TRADE FINAL VRU #: 002059418
	3/28/11	CA	Per Billy T/S: 03/28/2011 10:09 AM DETAYLOR
R429 03	3/29/11	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002059806
	<u>3/29/11</u>	<u>ASDT</u>	T/S: 03/28/2011 12:43 PM VBROWN

COMMENTS AND NOTES

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: ___ Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Name: Gary Robinson Homes LLC

Address: 377 Tactical Dr
Bunnlevel, NC 28323

Date: 3/29/11

Building Official: [Signature]

Permit Numbers

Building: _____

Electrical: _____

Insulation: _____

Plumbing: _____

Mechanical: 10-50025192

MFG Home: _____