HTE# 10-5-25202

Harness County Department of Public sealth

Improvement Permit

26273

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: LASATER RD ISSUED TO: KEKH BULLOCK BUILDERS SUBDIVISION WALNUT GROTE LOT # 15 REPAIR EXPANSION Site Improvements required prior to Construction Authorization Issuance: Type of Structure: SEO (60'×60' Proposed Wastewater System Type: 25% REDUCTION SYSTEM 4 Number of Occupants: 8 Number of bedrooms: Basement Yes Pump Required: ☐Yes X No ☐ May be required based on final location and elevations of facilities Type of Water Supply:

Community Public Well Distance from well 100 feet Five years Permit valid for: Permit conditions: ■ No expiration SEE ATTACHED SITE SKETCH Authorized State Agent:: The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: KEITH BULLOCK BUILDERS PROPERTY LOCATION: LASATER RO Facility Type: SED (60 × 60') | New | Expansion | Repair

Basement? | Yes | No Basement Fixtures? | Yes | No

Type of Wastewater System** LOT # 15 Type of Wastewater System**

DESTO REDUCTION SYSTEM (Initial) Wastewater Flow: 480 GPD (See note below, if applicable) Installation Requirements/Conditions Number of trenches Exact length of each trench Septic Tank Size > 000 gallons Pump Tank Size _____ gallons Trenches shall be installed on contour at a Maximum Trench Depth of: 18-24 (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: ft. TDH vs. inches below pipe Aggregate Depth: ______ inches above pipe Conditions: inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provision of this permit. SEE ATTACHED SITE SKETCH Authorized State Agent: Construction Authorization Expiration Date: 4122

Harnett County Department of Public Health Site Sketch

Authorized State Agent:

PROPERTY LOCATON: LASATER BD

SUBDIVISION WALNUT GROVE

LOT # 15

DORMAS

