HTE# 10-5-25231

## Harnett County Department of Public realth

Improvement Permit

26279

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: LASATER ISSUED TO: HUGH SURLES BUILDER SUBDIVISION WALNUT GROVE REPAIR D EXPANS Site Improvements required prior to Construction Authorization Issuance: Type of Structure: Proposed Wastewater System Type: 25% REDUCTION SYSTEM Projected Daily Flow: 360 GPD Number of Occupants: \_\_\_\_ max Number of bedrooms: Basement Yes No X No ☐ May be required based on final location and elevations of facilities Pump Required: Tes Type of Water Supply: 

Community Public 

Well Distance from well 100 feet Five years Permit valid for: ☐ No expiration Permit conditions: SEE ATTACHED SITE SKETCH Authorized State Agent:: The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1954, .1955, .1956, .1955, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: HUGH SURLES BUILDER PROPERTY LOCATION: LASTER RO SUBDIVISION WALNUT GROVE Facility Type: 5FO (60×60') New Expansion 
Repair Basement? ☐ Yes 🔀 No Basement Fixtures? ☐ Yes Basement Fixtures? | Yes | X No 25% REDUCTION SYSTEM (Initial) Wastewater Flow: 360 Type of Wastewater System\*\* (See note below, if applicable 25% REDUCTION SYSTEM (Repair) Number of trenches \\_\_\_\ Installation Requirements/Conditions Exact length of each trench \ 50 feet Trench Spacing: 9 Feet on Center Septic Tank Size 1000 gallons Pump Tank Size gallons Trenches shall be installed on contour at a Maximum Trench Depth of: 18-24 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: \_\_\_\_\_ft. TDH vs. \_\_\_\_ GPM inches below pipe Aggregate Depth: inches above pipe inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. \*\* If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Authorized State Agent: Construction Authorization Expiration Date: 1014

294

## Harnett County Department of Public Health Site Sketch

