

SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:
 Address: Date Evaluated: 10/25/10
 Proposed Facility: 5 BEDROOMS Design Flow (.1949): 600 GPD
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1943 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1936 Sapro Class	.1944 Restr Horiz	
1	LS 5-7%	0-37	G S	VFN NS/NP					
		37-40	CR SEL	FR SS/NP					PS 6
		HARD 40" ROCK							
2		0-27	G S	VFN NS/NP					
		27-41	SBK SEL	FR SS/NP	10x27/2e41"				PS 5
3		0-26"	C S	VFN NS/NP					PS 8
		HARD 26" ROCKS							
4		0-24"	G S	VFN NS/NP					PS 8
		HARD 24" ROCKS							

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: CT Others Present: /
Available Space (.1943)	✓	✓	
System Type(s)	CON	CON	
Site LTAR	.55	.55	

4x90" e 18-24" 1500 gal ST
 = REPAIR