

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant:

Address:

Date Evaluated:

Proposed Facility:

Design Flow (.1949):

Property Size:

Location of Site:

Property Recorded:

Water Supply:

- Public                       Individual                       Well  
 Auger Boring                       Pit                       Cut  
 Sewage                       Industrial Process                       Mixed  
 Spring                       Other

Evaluation Method:

Type of Wastewater:

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (in.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Reste Horiz	
		0-10	G/LS	VH-NNP					
		10-24	SK/C	L-SP	10/27/120"				PS
		0-22	G/LS	VH-NNP					
		22-35	SK/SL	F-SSP	10/27/133"				PS.4
		0-31	G/LS	VH-NNP					
		31-34	SK/SL	F-SSP					PS.5
		0-50	G/LS	VH-NNP					
		30-42	SK/SL	VH-SSP					PS.4
		0-24	G/LS	VH-NNP					
		24-33	SK/SL	L-SSP					PS.4

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: BM Others Present: GP
Available Space (.1945)	25703	25703	
System Type(s)			
Site LTAR	14	14	