
ADDRESS . . : 414 MILLS HOUSE LN
CONTRACTOR :
OWNER . . . : MILLS TIMOTHY D
PARCEL . . . : 01-0534- - -0098- - -
APPL NUMBER: 10-50025511 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 11/02/2010 08:33 AM RDCONTE ---
414 MILLS HOUSE LANE
TAKE 401S, T/R PM E;;OPT BRIDGE RD.
TURN ON BETHEL BAPTIEST ROAD. TURN ON
MILLS HOUSE LANE.
SOUTH RIVER

SUBDIV:
PHONE :
PHONE :

STRUCTURE: 000 000 47X32 CRAWL 3BD/3.5BA W/GAR

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW SEPTIC

PROPOSED USE : SFD
WATER SUPPLY : EXISTING WELL

PERMIT: CPSF 00 CP * SFD

REQUESTED INSP DESCRIPTION
TYP/SQ COMPLETED RESULT RESULTS/COMMENTS

B101 01 11/19/10 TI R*BLDG FOOTING / TEMP SVC POLE VRU #: 002008621
11-19-10 APJV

COMMENTS AND NOTES

ADDRESS . . : 414 MILLS HOUSE LN
CONTRACTOR :
OWNER . . . : MILLS TIMOTHY D
PARCEL . . . : 01-0534- - -0098- - -
APPL NUMBER: 10-50025511 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 11/02/2010 08:33 AM RDCONTE ---
414 MILLS HOUSE LANE
TAKE 401S, T/R PM E;;OPT BRIDGE RD.
TURN ON BETHEL BAPTIST ROAD. TURN ON
MILLS HOUSE LANE.
SOUTH RIVER

SUBDIV:
PHONE :
PHONE :

STRUCTURE: 000 000 47X32 CRAWL 3BD/3.5BA W/GAR

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

SEPTIC - EXISTING? : NEW SEPTIC

PROPOSED USE : SFD

WATER SUPPLY : EXISTING WELL

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/19/10	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002008621
	11/19/10	AP	
A814 01	11/29/10	TI	ADDRESS CONFIRMATION VRU #: 002011633
B103 01	11/29/10	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 002011625

11-29-10 AP JH

COMMENTS AND NOTES

ADDRESS . . : 414 MILLS HOUSE LN
CONTRACTOR :
OWNER . . . : MILLS TIMOTHY D
PARCEL . . . : 01-0534- - -0098- - -
APPL NUMBER: 10-50025511 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 11/02/2010 08:33 AM RDCONTE ---
414 MILLS HOUSE LANE
TAKE 401S, T/R PM E;;OPT BRIDGE RD.
TURN ON BETHEL BAPTIST ROAD. TURN ON
MILLS HOUSE LANE.
SOUTH RIVER

SUBDIV:
PHONE :
PHONE :

STRUCTURE: 000 000 47X32 CRAWL 3BD/3.5BA W/GAR

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

SEPTIC - EXISTING? : NEW SEPTIC

PROPOSED USE : SFD

WATER SUPPLY : EXISTING WELL

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/19/10	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002008621
	11/19/10	AP	
A814 01	11/29/10	TI	ADDRESS CONFIRMATION VRU #: 002011633
B103 01	11/29/10	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 002011625
	11/29/10	AP	
B105 01	12/03/10	TI	R*OPEN FLOOR VRU #: 002014132

12-3-10 APTV

COMMENTS AND NOTES

ADDRESS : 414 MILLS HOUSE LN
CONTRACTOR :
OWNER : MILLS TIMOTHY D
PARCEL : 01-0534- - -0098- - -
APPL NUMBER: 10-50025511 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 11/02/2010 08:33 AM RDCONTE ---
414 MILLS HOUSE LANE
TAKE 401S, T/R PM E;;OPT BRIDGE RD.
TURN ON BETHEL BAPTIEST ROAD. TURN ON
MILLS HOUSE LANE.
SOUTH RIVER

SUBDIV:
PHONE :
PHONE :

STRUCTURE: 000 000 47X32 CRAWL 3BD/3.5BA W/GAR

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW SEPTIC
PROPOSED USE : SFD
WATER SUPPLY : EXISTING WELL

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/19/10	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002008621
	11/19/10	AP	
B103 01	11/29/10	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 002011625
	11/29/10	AP	
A814 01	11/29/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002011633
	12/16/10	AP	408 MILLS HOUSE LN SPRING LAKE 28390 T/S: 12/16/2010 05:06 PM TWARD
B105 01	12/03/10	JH	R*OPEN FLOOR VRU #: 002014132
	12/03/10	AP	T/S: 12/03/2010 12:07 PM JHALL
R427 01	3/01/11	TI	FOUR TRADE ROUGH IN >2500 VRU #: 002047058

3-1-11 *DA JH*

COMMENTS AND NOTES

ADDRESS : 414 MILLS HOUSE LN
CONTRACTOR :
OWNER : MILLS TIMOTHY D
PARCEL : 01-0534- - -0098- - -
APPL NUMBER: 10-50025511 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 11/02/2010 08:33 AM RDCONTE ---
414 MILLS HOUSE LANE
TAKE 401S, T/R PM E;;OPT BRIDGE RD.
TURN ON BETHEL BAPTIST ROAD. TURN ON
MILLS HOUSE LANE.
SOUTH RIVER

SUBDIV:
PHONE :
PHONE :

STRUCTURE: 000 000 47X32 CRAWL 3BD/3.5BA W/GAR

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW SEPTIC
PROPOSED USE : SFD
WATER SUPPLY : EXISTING WELL

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/19/10 11/19/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002008621
B103 01	11/29/10 11/29/10	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 002011625
A814 01	11/29/10 12/16/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002011633 408 MILLS HOUSE LN SPRING LAKE 28390 T/S: 12/16/2010 05:06 PM TWARD
B105 01	12/03/10 12/03/10	JH AP	R*OPEN FLOOR VRU #: 002014132 T/S: 12/03/2010 12:07 PM JHALL
R427 01	3/01/11 3/01/11	JH DA	FOUR TRADE ROUGH IN >2500 VRU #: 002047058 Nail guard on water line @ refrig. Fire caulk switch & receptacle wire @ top plate in dining room. Fire caulk light wire in half bath. Missing nails in floor truss hangers in living room & laundry room. Fire low voltage wires in laundry room @ top plate. Nail guard on master bath toilet water line. Need @ least 10D common nails in the 45 degree holes on roof truss hangers in stairs & front bedroom upstairs. Fire caulk water line & wires in storage room in bed 2. Nail guard on water line in storageroom in bed 2. Rafters in front dormers can not be wider than ridge beam.
R427 02	3/07/11 <i>3-7-11</i>	TI <i>APJD</i>	FOUR TRADE ROUGH IN >2500 VRU #: 002049393

COMMENTS AND NOTES

ADDRESS . : 414 MILLS HOUSE LN
CONTRACTOR :
OWNER . . : MILLS TIMOTHY D
PARCEL . . : 01-0534- - -0098- - -
APPL NUMBER: 10-50025511 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 11/02/2010 08:33 AM RDCONTE ---
414 MILLS HOUSE LANE
TAKE 401S, T/R PM E;;OPT BRIDGE RD.
TURN ON BETHEL BAPTIEST ROAD. TURN ON
MILLS HOUSE LANE.
SOUTH RIVER

SUBDIV:
PHONE :
PHONE :

STRUCTURE: 000 000 47X32 CRAWL 3BD/3.5BA W/GAR

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : EXISTING WELL

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/19/10	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002008621
	11/19/10	AP	-----
B103 01	11/29/10	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 002011625
	11/29/10	AP	-----
A814 01	11/29/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002011633
	12/16/10	AP	408 MILLS HOUSE LN SPRING LAKE 28390 ----- T/S: 12/16/2010 05:06 PM TWARD -----
B105 01	12/03/10	JH	R*OPEN FLOOR VRU #: 002014132
	12/03/10	AP	T/S: 12/03/2010 12:07 PM JHALL -----
R427 01	3/01/11	JH	FOUR TRADE ROUGH IN >2500 VRU #: 002047058
	3/01/11	DA	1)Nail guard on water line @ refrig. 2)Fire caulk switch & receptacle wire @ top plate in dining room.3)Fire caulk light wire in half bath. 4)Missing nails in floor truss hangers in living room & laundry room. 5)Fire low voltage wires in laundry room @ top plate. 6)Nail guard on master bath toilet water line. 7)Need @ least 10D common nails in the 45 degree holes on roof truss hangers in stairs & front bedroom upstairs. 8)Fire caulk water line & wires in storage room in bed 2. 9)Nail guard on water line in storageroom in bed 2. 10)Rafters in front dormers can not be wider than ridge beam.
R427 02	3/07/11	JH	FOUR TRADE ROUGH IN >2500 VRU #: 002049393
	3/07/11	AP	-----
I129 01	3/09/11	TI	R*INSULATION INSPECTION VRU #: 002051720
	<u>3-9-11</u>	<u>APJH</u>	

COMMENTS AND NOTES

ADDRESS . : 414 MILLS HOUSE LN SUBDIV:
CONTRACTOR : PHONE :
OWNER . . : MILLS TIMOTHY D PHONE :
PARCEL . . : 01-0534- - -0098- - -
APPL NUMBER: 10-50025511 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 11/02/2010 08:33 AM RDCONTE ---
414 MILLS HOUSE LANE
TAKE 401S, T/R PM E;;OPT BRIDGE RD.
TURN ON BETHEL BAPTIEST ROAD. TURN ON
MILLS HOUSE LANE.
SOUTH RIVER

STRUCTURE: 000 000 47X32 CRAWL 3BD/3.5BA W/GAR

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : EXISTING WELL

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/19/10 11/19/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002008621 -----
B103 01	11/29/10 11/29/10	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 002011625 -----
A814 01	11/29/10 12/16/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002011633 ✓ 408 MILLS HOUSE LN SPRING LAKE 28390 ----- T/S: 12/16/2010 05:06 PM TWARD -----
B105 01	12/03/10 12/03/10	JH AP	R*OPEN FLOOR VRU #: 002014132 T/S: 12/03/2010 12:07 PM JHALL -----
R427 01	3/01/11 3/01/11	JH DA	FOUR TRADE ROUGH IN >2500 VRU #: 002047058 1)Nail guard on water line @ refrig. 2)Fire caulk switch & receptacle wire @ top plate in dining room.3)Fire caulk light wire in half bath. 4)Missing nails in floor truss hangers in living room & laundry room. 5)Fire low voltage wires in laundry room @ top plate. 6)Nail guard on master bath toilet water line. 7)Need @ least 10D common nails in the 45 degree holes on roof truss hangers in stairs & front bedroom upstairs. 8)Fire caulk water line & wires in storage room in bed 2. 9)Nail guard on water line in storageroom in bed 2. 10)Rafters in front dormers can not be wider than ridge beam.
R427 02	3/07/11 3/07/11	JH AP	FOUR TRADE ROUGH IN >2500 VRU #: 002049393 -----
I129 01	3/09/11 3/09/11	JH AP	R*INSULATION INSPECTION VRU #: 002051720 -----
H824 01	4/12/11 4/12/11	OT AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002067189 T/S: 04/13/2011 10:15 AM SZIMMER ----- T/S: 04/13/2011 10:15 AM SZIMMER -----
R431 01	6/07/11 <u>6-7-11</u>	TI <u>DAJH</u>	FOUR TRADE FINAL >2500 VRU #: 002089902

----- COMMENTS AND NOTES -----

ADDRESS : 408 MILLS HOUSE LN
 CONTRACTOR :
 OWNER : MILLS TIMOTHY D
 PARCEL : 01-0534- - -0098- - -
 APPL NUMBER: 10-50025511 CP NEW RESIDENTIAL (SFD)

SUBDIV:
 PHONE :
 PHONE :

DIRECTIONS : 11/02/2010 08:33 AM RDCONTE ---
 414 MILLS HOUSE LANE
 TAKE 401S, T/R PM E;;OPT BRIDGE RD.
 TURN ON BETHEL BAPTIST ROAD. TURN ON
 MILLS HOUSE LANE.
 SOUTH RIVER

STRUCTURE: 000 000 47X32 CRAWL 3BD/3.5BA W/GAR

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00
 SEPTIC - EXISTING? : NEW SEPTIC
 PROPOSED USE : SFD
 WATER SUPPLY : EXISTING WELL

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/19/10	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002008621
	11/19/10	AP	
B103 01	11/29/10	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 002011625
	11/29/10	AP	
A814 01	11/29/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002011633
	12/16/10	AP	✓408 MILLS HOUSE LN SPRING LAKE 28390 T/S: 12/16/2010 05:06 PM TWARD
B105 01	12/03/10	JH	R*OPEN FLOOR VRU #: 002014132
	12/03/10	AP	T/S: 12/03/2010 12:07 PM JHALL
R427 01	3/01/11	JH	FOUR TRADE ROUGH IN >2500 VRU #: 002047058
	3/01/11	DA	1)Nail guard on water line @ refrig. 2)Fire caulk switch & receptacle wire @ top plate in dining room.3)Fire caulk light wire in half bath. 4)Missing nails in floor truss hangers in living room & laundry room. 5)Fire low voltage wires in laundry room @ top plate. 6)Nail guard on master bath toilet water line. 7)Need @ least 10D common nails in the 45 degree holes on roof truss hangers in stairs & front bedroom upstairs. 8)Fire caulk water line & wires in storage room in bed 2. 9)Nail guard on water line in storageroom in bed 2. 10)Rafters in front dormers can not be wider than ridge beam.
R427 02	3/07/11	JH	FOUR TRADE ROUGH IN >2500 VRU #: 002049393
	3/07/11	AP	
I129 01	3/09/11	JH	R*INSULATION INSPECTION VRU #: 002051720
	3/09/11	AP	
H824 01	4/12/11	OT	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002067189
	4/12/11	AP	T/S: 04/13/2011 10:15 AM SZIMMER T/S: 04/13/2011 10:15 AM SZIMMER
R431 01	6/07/11	JH	FOUR TRADE FINAL >2500 VRU #: 002089902
	6/07/11	DA	✓House numbers. ✓Seal @ kitchen sink. ✓Seal all plumbing fixtures. ✓Need lock out on water heater. ✓Label AHU in attic & crawl space. ✓Seal sleeve @ condensing units. ✓Need 100 percent 6 mill poly in crawl.
R431 02	6/13/11	TI	FOUR TRADE FINAL >2500 TIME: 17:00 VRU #: 002093607

PREPARED 6/10/11, 15:00:26
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 2
DATE 6/13/11

ADDRESS . : 408 MILLS HOUSE LN SUBDIV:
CONTRACTOR : PHONE :
OWNER . . : MILLS TIMOTHY D PHONE :
PARCEL . . : 01-0534- - -0098- - -
APPL NUMBER: 10-50025511 CP NEW RESIDENTIAL (SFD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	6-13-11	APJH	T/S: 06/10/2011 02:59 PM NTART

----- COMMENTS AND NOTES -----

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: _____ Occupancy:

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD
Name: Timothy Mills
Address: 408 Mills House Ln

Permit Numbers

Building: _____
Electrical: _____
Insulation: _____
Plumbing: _____
Mechanical: _____
MFG Home: _____

1158005-01

Date: 6-13-11 Building Official: James T. Hall