

COMMENTS:

ON FEB 1ST System was installed by ADCOCK BROTHERS - NEEDED
WATER LINE TO BE INSTALLED AS WELL AS POWER (PANTIN) - I DISCUSSED
MEASURES TO KEEP REPAIR AREA DRY AND HOW TO RUN W/L
IN 2 DIFFERENT AREAS TO ENSURE PROPER PLACEMENT DUE TO SPACE
MR BRYANT AGREED TO RUN THE WATERLINE IN EITHER OF THE TWO
WAYS WE DISCUSSED TO AVOID 10' ENCROACHMENT ON DRAIN LINES AND
REPAIR AREA. ON 2-18-11 NOTES - VOICEMAIL AND FILE WERE
ON MY DESK PERTAINING TO MR BRYANT AND HIS FIRM. HE ALSO
CAME IN THE OFFICE, ASKED TO SPEAK TO ME & TOLD ME
THAT WATER LINE WAS IN AND READY FOR FURN. I
~~TOLD HIM THAT~~ I WOULD CORE STRAIGHT OUT TO INSPECT.
9:30 I WENT OUT TO FURN & LOOK FOR FURN AND MR BRYANT RUN
THE WATER LINE IN A MANNER THAT WAS NOT DISCUSSED
AS ALLOWABLE. THE INSTALL SEEMED TO BE 10' OFF OF DRAIN LINES
AND I EXPLAINED WHAT HIS MISTAKE HAD DONE
AND IT WOULD DAMAGE REPAIR AREA AND REQUIRE
~~A PUMP TO REPAIR THE SEPTIC BECAUSE OF~~
THE PLACEMENT OF THE W/L HE INSTALLED.
CLIENT WAS INFORMED W/L AND DRAIN
~~DISTURBED~~ REPAIR AREA.