
ADDRESS . . : CITATION DR
 CONTRACTOR :
 OWNER . . : WASFY KAZUKO & SHERIF
 PARCEL . . : 03-9586- - -0083- - -
 APPL NUMBER: 10-50025684 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 12/01/2010 11:56 AM JBROCK -----
 HWY 24/27 FROM LILLINGTON TO BUFFALO
 LAKE RD TAKE LEFT TURN RIGHT ONTO
 ROBERTS RD LOT IN LEFT

SUBDIV:
 PHONE :
 PHONE : (408) 642-0403

STRUCTURE: 000 000 58X59 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00
 SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/14/11 <u>1-14-11</u>	TI <u>AP-MR</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002028850

COMMENTS AND NOTES -----

ADDRESS : CITATION DR

SUBDIV:

CONTRACTOR :

PHONE :

OWNER : WASFY KAZUKO & SHERIF

PHONE : (408) 642-0403

PARCEL : 03-9586- - -0083- - -

APPL NUMBER: 10-50025684 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : T/S: 12/01/2010 11:56 AM JBROCK ----
HWY 24/27 FROM LILLINGTON TO BUFFALO
LAKE RD TAKE LEFT TURN RIGHT ONTO
ROBERTS RD LOT IN LEFT

STRUCTURE: 000 000 58X59 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3000000.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/14/11	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002028850
	1/14/11	AP	T/S: 01/14/2011 10:08 AM MREARIC -----
A814 01	1/21/11	TI	ADDRESS CONFIRMATION VRU #: 002031680
B103 01	1/21/11	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 002031698
	<u>1-21-11</u>	<u>AP-MR</u>	

COMMENTS AND NOTES

ADDRESS : CITATION DR

SUBDIV:

CONTRACTOR :

PHONE :

OWNER : WASFY KAZUKO & SHERIF

PHONE : (408) 642-0403

PARCEL : 03-9586- - -0083- - -

APPL NUMBER: 10-50025684 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : T/S: 12/01/2010 11:56 AM JBROCK ----
HWY 24/27 FROM LILLINGTON TO BUFFALO
LAKE RD TAKE LEFT TURN RIGHT ONTO
ROBERTS RD LOT IN LEFT

STRUCTURE: 000 000 58X59 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3000000.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/14/11	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002028850
	1/14/11	AP	T/S: 01/14/2011 10:08 AM MREARIC -----
A814 01	1/21/11	TI	ADDRESS CONFIRMATION VRU #: 002031680
B103 01	1/21/11	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002031698
	1/21/11	AP	T/S: 01/21/2011 12:49 PM MREARIC -----
B105 01	1/26/11	TI	R*OPEN FLOOR VRU #: 002033462
	<u>126-11</u>	<u>DA-MR</u>	

COMMENTS AND NOTES

HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DATE: 01-26-11

PERMIT # 10-50025684

ADDRESS: citation (Roberts rd).

CORRECTIONS NEEDED:

1. Double joist needed under wall (at kitchen cook-top area)

Mike Rearic cell# (910) 984- 4772

ADDRESS . . : 185 ROBERTS RD
 CONTRACTOR :
 OWNER . . . : WASFY KAZUKO & SHERIF
 PARCEL . . . : 03-9586- - -0083- - -
 APPL NUMBER: 10-50025684 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 12/01/2010 11:56 AM JBROCK ----
 HWY 24/27 FROM LILLINGTON TO BUFFALO
 LAKE RD TAKE LEFT TURN RIGHT ONTO
 ROBERTS RD LOT IN LEFT

STRUCTURE: 000 000 58X59 3BDR CRAWL W/ GARAGE & DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00
 SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/14/11	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002028850
	1/14/11	AP	T/S: 01/14/2011 10:08 AM MREARIC -----
B103 01	1/21/11	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002031698
	1/21/11	AP	T/S: 01/21/2011 12:49 PM MREARIC -----
A814 01	1/21/11	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002031680
	1/25/11	AP	T/S: 01/25/2011 02:34 PM TWARD ----- 185 ROBERTS RD SANFORD 27332 T/S: 01/25/2011 02:35 PM TWARD -----
B105 01	1/26/11	MR	R*OPEN FLOOR VRU #: 002033462
	1/26/11	DA	T/S: 01/26/2011 12:02 PM MREARIC ----- joist needed under parallel kitchen wall
B105 02	1/27/11	TI	R*OPEN FLOOR VRU #: 002034284

1-27-11 AP-MR

----- COMMENTS AND NOTES -----

ADDRESS : 185 ROBERTS RD
CONTRACTOR :
OWNER : WASFY KAZUKO & SHERIF
PARCEL : 03-9586- - -0083- - -
APPL NUMBER: 10-50025684 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 12/01/2010 11:56 AM JBROCK ----
HWY 24/27 FROM LILLINGTON TO BUFFALO
LAKE RD TAKE LEFT TURN RIGHT ONTO
ROBERTS RD LOT IN LEFT

STRUCTURE: 000 000 58X59 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00
SEPTIC - EXISTING? : NEW
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/14/11	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002028850
	1/14/11	AP	T/S: 01/14/2011 10:08 AM MREARIC -----
B103 01	1/21/11	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002031698
	1/21/11	AP	T/S: 01/21/2011 12:49 PM MREARIC -----
A814 01	1/21/11	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002031680
	1/25/11	AP	T/S: 01/25/2011 02:34 PM TWARD ----- 185 ROBERTS RD SANFORD 27332 T/S: 01/25/2011 02:35 PM TWARD -----
B105 01	1/26/11	MR	R*OPEN FLOOR VRU #: 002033462
	1/26/11	DA	T/S: 01/26/2011 12:02 PM MREARIC ----- joist needed under parallel kitchen wall
B105 02	1/27/11	MR	R*OPEN FLOOR VRU #: 002034284
	1/27/11	AP	T/S: 01/27/2011 01:04 PM MREARIC -----
R427 01	2/14/11	TI	FOUR TRADE ROUGH IN >2500 VRU #: 002040251

2-14-11 DA-MR

COMMENTS AND NOTES

HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DATE: 02-14-11

PERMIT # 10-50025684

ADDRESS: 185 roberts rd.

CORRECTIONS NEEDED:

- 1. Finish plumbing**
- 2. Toe nail all hangers which require it.**
- 3. Nail all hangers for lateral movement (sideways)**
- 4. Fireblock over fireplace**

Mike Rearic cell# (910) 984- 4772

ADDRESS : 185 ROBERTS RD
 CONTRACTOR :
 OWNER : WASFY KAZUKO & SHERIF
 PARCEL : 03-9586- - -0083- - -
 APPL NUMBER: 10-50025684 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 12/01/2010 11:56 AM JBROCK ----
 HWY 24/27 FROM LILLINGTON TO BUFFALO
 LAKE RD TAKE LEFT TURN RIGHT ONTO
 ROBERTS RD LOT IN LEFT

STRUCTURE: 000 000 58X59 3BDR CRAWL W/ GARAGE & DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00
 SEPTIC - EXISTING? : NEW
 PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/14/11	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002028850
	1/14/11	AP	T/S: 01/14/2011 10:08 AM MREARIC -----
B103 01	1/21/11	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002031698
	1/21/11	AP	T/S: 01/21/2011 12:49 PM MREARIC -----
A814 01	1/21/11	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002031680
	1/25/11	AP	T/S: 01/25/2011 02:34 PM TWARD ----- 185 ROBERTS RD SANFORD 27332 T/S: 01/25/2011 02:35 PM TWARD -----
B105 01	1/26/11	MR	R*OPEN FLOOR VRU #: 002033462
	1/26/11	DA	T/S: 01/26/2011 12:02 PM MREARIC ----- joist needed under parallel kitchen wall
B105 02	1/27/11	MR	R*OPEN FLOOR VRU #: 002034284
	1/27/11	AP	T/S: 01/27/2011 01:04 PM MREARIC -----
R427 01	2/14/11	MR	FOUR TRADE ROUGH IN >2500 VRU #: 002040251
	2/14/11	DA	T/S: 02/14/2011 12:42 PM MREARIC ----- finish plumbing toe nail all hangers nail all truss hangers for lateral support fire block over fireplace
R427 02	2/16/11	TI	FOUR TRADE ROUGH IN >2500 VRU #: 002041598
	2-16-11	DA-MR	

COMMENTS AND NOTES

Nail Hangers in back BR

HARNETT COUNTY

**Building Inspections Dept.
108 E. Front St.
Lillington, NC 27546
910-893-7525**

DATE: 02-16-11

PERMIT # 10-50025684

ADDRESS: 185 roberts

CORRECTIONS NEEDED:

- 1. The truss hangers in the rear bedroom on the left side of the house are not nailed for lateral movement.**
- 2. You can insulate**

Mike Rearic cell# (910) 984- 4772

ADDRESS . . : 185 ROBERTS RD
 CONTRACTOR :
 OWNER . . . : WASFY KAZUKO & SHERIF
 PARCEL . . . : 03-9586- - -0083- - -
 APPL NUMBER: 10-50025684 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 12/01/2010 11:56 AM JBROCK ----
 HWY 24/27 FROM LILLINGTON TO BUFFALO
 LAKE RD TAKE LEFT TURN RIGHT ONTO
 ROBERTS RD LOT IN LEFT

STRUCTURE: 000 000 58X59 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00
 SEPTIC - EXISTING? : NEW
 PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/14/11	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002028850
	1/14/11	AP	T/S: 01/14/2011 10:08 AM MREARIC -----
B103 01	1/21/11	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002031698
	1/21/11	AP	T/S: 01/21/2011 12:49 PM MREARIC -----
A814 01	1/21/11	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002031680
	1/25/11	AP	T/S: 01/25/2011 02:34 PM TWARD ----- 185 ROBERTS RD SANFORD 27332 T/S: 01/25/2011 02:35 PM TWARD -----
B105 01	1/26/11	MR	R*OPEN FLOOR VRU #: 002033462
	1/26/11	DA	T/S: 01/26/2011 12:02 PM MREARIC ----- joist needed under parallel kitchen wall
B105 02	1/27/11	MR	R*OPEN FLOOR VRU #: 002034284
	1/27/11	AP	T/S: 01/27/2011 01:04 PM MREARIC -----
R427 01	2/14/11	MR	FOUR TRADE ROUGH IN >2500 VRU #: 002040251
	2/14/11	DA	T/S: 02/14/2011 12:42 PM MREARIC ----- finish plumbing toe nail all hangers nail all truss hangers for lateral support fireblock over fireplace
H824 01	2/15/11	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002042380
	2/15/11	AP	T/S: 02/16/2011 09:30 AM SZIMMER ----- +T/S: 02/16/2011 09:30 AM SZIMMER -----
R427 02	2/16/11	MR	FOUR TRADE ROUGH IN >2500 VRU #: 002041598
	2/16/11	DA	T/S: 02/16/2011 12:19 PM MREARIC ----- truss hangers over rear bedroom are not nailed for lateral movement ok to insulate
I129 01	2/21/11	TI	R*INSULATION INSPECTION VRU #: 002043016
	<u>2-21-11</u>	<u>DA/JH</u>	
R427 03	2/21/11	TI	FOUR TRADE ROUGH IN >2500 VRU #: 002043008
	<u>2-21-11</u>	<u>DA/JH</u>	<i>missing header at entry door from garage to house</i> <i>missing 6 windows</i>

COMMENTS AND NOTES

ADDRESS . : 185 ROBERTS RD SUBDIV:
CONTRACTOR : PHONE :
OWNER . . : WASFY KAZUKO & SHERIF PHONE : (408) 642-0403
PARCEL . . : 03-9586- - -0083- - -
APPL NUMBER: 10-50025684 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 12/01/2010 11:56 AM JBROCK ----
HWY 24/27 FROM LILLINGTON TO BUFFALO
LAKE RD TAKE LEFT TURN RIGHT ONTO
ROBERTS RD LOT IN LEFT

STRUCTURE: 000 000 58X59 3BDR CRAWL W/ GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/14/11	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002028850
	1/14/11	AP	T/S: 01/14/2011 10:08 AM MREARIC -----
B103 01	1/21/11	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002031698
	1/21/11	AP	T/S: 01/21/2011 12:49 PM MREARIC -----
A814 01	1/21/11	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002031680
	1/25/11	AP	T/S: 01/25/2011 02:34 PM TWARD ----- 185 ROBERTS RD SANFORD 27332 T/S: 01/25/2011 02:35 PM TWARD -----
B105 01	1/26/11	MR	R*OPEN FLOOR VRU #: 002033462
	1/26/11	DA	T/S: 01/26/2011 12:02 PM MREARIC ----- joist needed under parallel kitchen wall
B105 02	1/27/11	MR	R*OPEN FLOOR VRU #: 002034284
	1/27/11	AP	T/S: 01/27/2011 01:04 PM MREARIC -----
R427 01	2/14/11	MR	FOUR TRADE ROUGH IN >2500 VRU #: 002040251
	2/14/11	DA	T/S: 02/14/2011 12:42 PM MREARIC ----- finish plumbing toe nail all hangers nail all truss hangers for lateral support fireblock over fireplace
H824 01	2/15/11	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002042380
	2/15/11	AP	T/S: 02/16/2011 09:30 AM SZIMMER ----- +T/S: 02/16/2011 09:30 AM SZIMMER -----
R427 02	2/16/11	MR	FOUR TRADE ROUGH IN >2500 VRU #: 002041598
	2/16/11	DA	T/S: 02/16/2011 12:19 PM MREARIC ----- truss hangers over rear bedroom are not nailed for lateral movement ok to insulate
I129 01	2/21/11	JH	R*INSULATION INSPECTION VRU #: 002043016
	2/21/11	DA	1)Missing header over entry door from garage to house. 2) Missing 6 windows they need to be in before insulation is passed.
R427 03	2/21/11	JH	FOUR TRADE ROUGH IN >2500 VRU #: 002043008
	2/21/11	DA	1 Missing header over entry door from garage to house. 2 Missing 6 windows they need to be in before insulation is passed.
I129 02	2/24/11	TI	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002044950

ADDRESS . . : 185 ROBERTS RD
CONTRACTOR :
OWNER . . . : WASFY KAZUKO & SHERIF
PARCEL . . . : 03-9586- - -0083- - -
APPL NUMBER: 10-50025684 CP NEW RESIDENTIAL (SFD)

SUBDIV:
PHONE :
PHONE : (408) 642-0403

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R427 04	<u>2-24-11</u> 2/24/11	<u>AP JV</u> TI	T/S: 02/22/2011 04:28 PM NTART ----- FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 002045144 T/S: 02/22/2011 02:14 PM DJOHNSON ----- T/S: 02/22/2011 04:28 PM NTART -----

----- COMMENTS AND NOTES -----

ADDRESS . . : 185 ROBERTS RD
 CONTRACTOR :
 OWNER . . : WASFY KAZUKO & SHERIF
 PARCEL . . : 03-9586- - -0083- - -
 APPL NUMBER: 10-50025684 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 12/01/2010 11:56 AM JBROCK ----
 HWY 24/27 FROM LILLINGTON TO BUFFALO
 LAKE RD TAKE LEFT TURN RIGHT ONTO
 ROBERTS RD LOT IN LEFT

STRUCTURE: 000 000 58X59 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00
 SEPTIC - EXISTING? : NEW
 PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/14/11	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002028850
	1/14/11	AP	T/S: 01/14/2011 10:08 AM MREARIC -----
B103 01	1/21/11	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002031698
	1/21/11	AP	T/S: 01/21/2011 12:49 PM MREARIC -----
A814 01	1/21/11	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002031680
	1/25/11	AP	T/S: 01/25/2011 02:34 PM TWARD ----- ✓ 185 ROBERTS RD SANFORD 27332 T/S: 01/25/2011 02:35 PM TWARD -----
B105 01	1/26/11	MR	R*OPEN FLOOR VRU #: 002033462
	1/26/11	DA	T/S: 01/26/2011 12:02 PM MREARIC ----- joist needed under parallel kitchen wall
B105 02	1/27/11	MR	R*OPEN FLOOR VRU #: 002034284
	1/27/11	AP	T/S: 01/27/2011 01:04 PM MREARIC -----
R427 01	2/14/11	MR	FOUR TRADE ROUGH IN >2500 VRU #: 002040251
	2/14/11	DA	T/S: 02/14/2011 12:42 PM MREARIC ----- finish plumbing toe nail all hangers nail all truss hangers for lateral support fireblock over fireplace
H824 01	2/15/11	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002042380
	2/15/11	AP	T/S: 02/16/2011 09:30 AM SZIMMER ----- +T/S: 02/16/2011 09:30 AM SZIMMER -----
R427 02	2/16/11	MR	FOUR TRADE ROUGH IN >2500 VRU #: 002041598
	2/16/11	DA	T/S: 02/16/2011 12:19 PM MREARIC ----- truss hangers over rear bedroom are not nailed for lateral movement ok to insulate
I129 01	2/21/11	JH	R*INSULATION INSPECTION VRU #: 002043016
	2/21/11	DA	1)Missing header over entry door from garage to house. 2) Missing 6 windows they need to be in before insulation is passed.
R427 03	2/21/11	JH	FOUR TRADE ROUGH IN >2500 VRU #: 002043008
	2/21/11	DA	1)Missing header over entry door from garage to house. 2) Missing 6 windows they need to be in before insulation is passed.
I129 02	2/24/11	JH	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002044950

CONTINUED ONTO NEXT PAGE

ADDRESS . . : 185 ROBERTS RD
CONTRACTOR :
OWNER . . . : WASFY KAZUKO & SHERIF
PARCEL . . . : 03-9586- - -0083- - -
APPL NUMBER: 10-50025684 CP NEW RESIDENTIAL (SFD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	2/24/11	AP	T/S: 02/22/2011 04:28 PM NTART -----
R427 04	2/24/11	JH	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 002045144
	2/24/11	AP	T/S: 02/22/2011 02:14 PM DJOHNSON ----- T/S: 02/22/2011 04:28 PM NTART -----
R431 01	3/25/11 <u>3-25-11</u>	TI <u>DP-MR</u>	FOUR TRADE FINAL >2500 VRU #: 002058105

----- COMMENTS AND NOTES -----

HARNETT COUNTY

Building Inspections Dept.
108 E. Front St.
Lillington, NC 27546
910-893-7525

DATE: 03-25-11

PERMIT # 10-50025684

ADDRESS: 185 roberts dr..

CORRECTIONS NEEDED:

1. Grade must go down 6" in 10' all around house
2. No drain to daylight in crawlspace
3. Pipes in garae are not insulated
4. Install anti-tip device on stove
5. Fee 50

Mike Rearic cell# (910) 984- 4772

ADDRESS : 185 ROBERTS RD SUBDIV:
CONTRACTOR : PHONE :
OWNER : WASFY KAZUKO & SHERIF PHONE : (408) 642-0403
PARCEL : 03-9586- - -0083- - -
APPL NUMBER: 10-50025684 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 12/01/2010 11:56 AM JBROCK ----
HWY 24/27 FROM LILLINGTON TO BUFFALO
LAKE RD TAKE LEFT TURN RIGHT ONTO
ROBERTS RD LOT IN LEFT

STRUCTURE: 000 000 58X59 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/14/11	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002028850
	1/14/11	AP	T/S: 01/14/2011 10:08 AM MREARIC -----
B103 01	1/21/11	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002031698
	1/21/11	AP	T/S: 01/21/2011 12:49 PM MREARIC -----
A814 01	1/21/11	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002031680
	1/25/11	AP	T/S: 01/25/2011 02:34 PM TWARD ----- ✓ 185 ROBERTS RD SANFORD 27332 T/S: 01/25/2011 02:35 PM TWARD -----
B105 01	1/26/11	MR	R*OPEN FLOOR VRU #: 002033462
	1/26/11	DA	T/S: 01/26/2011 12:02 PM MREARIC ----- joist needed under parallel kitchen wall
B105 02	1/27/11	MR	R*OPEN FLOOR VRU #: 002034284
	1/27/11	AP	T/S: 01/27/2011 01:04 PM MREARIC -----
R427 01	2/14/11	MR	FOUR TRADE ROUGH IN >2500 VRU #: 002040251
	2/14/11	DA	T/S: 02/14/2011 12:42 PM MREARIC ----- finish plumbing toe nail all hangers nail all truss hangers for lateral support fireblock over fireplace
H824 01	2/15/11	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002042380
	2/15/11	AP	T/S: 02/16/2011 09:30 AM SZIMMER ----- +T/S: 02/16/2011 09:30 AM SZIMMER -----
R427 02	2/16/11	MR	FOUR TRADE ROUGH IN >2500 VRU #: 002041598
	2/16/11	DA	T/S: 02/16/2011 12:19 PM MREARIC ----- truss hangers over rear bedroom are not nailed for lateral movement ok to insulate
I129 01	2/21/11	JH	R*INSULATION INSPECTION VRU #: 002043016
	2/21/11	DA	1)Missing header over entry door from garage to house. 2) Missing 6 windows they need to be in before insulation is passed.
R427 03	2/21/11	JH	FOUR TRADE ROUGH IN >2500 VRU #: 002043008
	2/21/11	DA	1)Missing header over entry door from garage to house. 2) Missing 6 windows they need to be in before insulation is passed.
I129 02	2/24/11	JH	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002044950

----- CONTINUED ONTO NEXT PAGE -----

ADDRESS . . : 185 ROBERTS RD
 CONTRACTOR :
 OWNER . . : WASFY KAZUKO & SHERIF
 PARCEL . . : 03-9586- - -0083- - -
 APPL NUMBER: 10-50025684 CP NEW RESIDENTIAL (SFD)

SUBDIV:
 PHONE :
 PHONE : (408) 642-0403

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	2/24/11	AP	T/S: 02/22/2011 04:28 PM NTART -----
R427 04	2/24/11	JH	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 002045144
	2/24/11	AP	T/S: 02/22/2011 02:14 PM DJOHNSON -----
			T/S: 02/22/2011 04:28 PM NTART -----
R431 01	3/25/11	MR	FOUR TRADE FINAL >2500 VRU #: 002058105
	3/25/11	DP	T/S: 03/25/2011 01:50 PM NTART -----
			T/S: 03/25/2011 01:50 PM NTART -----
			T/S: 03/25/2011 02:08 PM MREARIC -----
			grade around house is not ready
			drain pipe from crawl space
			pipes in garage sink insulate
			install anti-tip on oven
			grade must be lower than foundation vents
R431 02	3/28/11	TI	FOUR TRADE FINAL >2500 TIME: 17:00 VRU #: 002059533
	<u>3-28-11</u>	<u>AP-MR</u>	T/S: 03/25/2011 01:58 PM NTART -----

COMMENTS AND NOTES

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: X Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: R-3

Permit Numbers

Name: Wasfy

Building: 10-5 00 25684

Address: 185 Roberts Rd,

Electrical: 11

Insulation: 11

Plumbing: 11

Mechanical: 11

MFG Home: _____

Date: 3-28-11

Building Official: T. Michael Ream