

ADDRESS : 416 FIFTY CALIBER DR

SUBDIV: PATTONS POINT

CONTRACTOR : BILL CLARK HOMES LLC

PHONE : (252) 355-5805

OWNER : BILL CLARK HOMES

PHONE : (910) 263-9026

PARCEL : 03-9597- - -0039- -26-

APPL NUMBER: 11-50025887 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : T/S: 01/13/2011 01:28 PM JBROCK ----
27 TOWARD HWY 87 TURN LEFT ON TINGEN RD
TURN LEFT INTO S/D ON STRIKE EAGLE DR
THEN TURN LEFT ON BUNKER BISTER & THEN
LEFT ON FIFTY CALIBER DR LOT IS ON
RIGHT LOT 30

STRUCTURE: 000 000 68X34 3BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3000000.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
--------	------------------------	----------------	---------------------------------

B101 01	2/10/11 <u>2-10-11</u>	TI <u>AP-MR</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002039048
---------	---------------------------	--------------------	---

COMMENTS AND NOTES

ADDRESS . : 416 FIFTY CALIBER DR
 CONTRACTOR : BILL CLARK HOMES LLC
 OWNER . . : BILL CLARK HOMES
 PARCEL . . : 03-9597- - -0039- -26-
 APPL NUMBER: 11-50025887 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 01/13/2011 01:28 PM JBROCK ----
 27 TOWARD HWY 87 TURN LEFT ON TINGEN RD
 TURN LEFT INTO S/D ON STRIKE EAGLE DR
 THEN TURN LEFT ON BUNKER BISTER & THEN
 LEFT ON FIFTY CALIBER DR LOT IS ON
 RIGHT LOT 30

STRUCTURE: 000 000 68X34 3BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00
 SEPTIC - EXISTING? : NEW
 PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/10/11	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002039048
	2/10/11	AP	T/S: 02/10/2011 01:04 PM MREARIC -----
A814 01	2/23/11	TI	ADDRESS CONFIRMATION VRU #: 002044964
B103 01	2/23/11 <i>2-23-11</i>	TI <i>ADJH</i>	R*BLDG FOUND & TEMP SVC POLE VRU #: 002044972 PLEASE GO AFTER LUNCH IF POSSIBLE....

----- COMMENTS AND NOTES -----

ADDRESS . : 416 FIFTY CALIBER DR
 CONTRACTOR : BILL CLARK HOMES LLC
 OWNER . . : BILL CLARK HOMES
 PARCEL . . : 03-9597- - -0039- -26-
 APPL NUMBER: 11-50025887 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 01/13/2011 01:28 PM JBROCK ----
 27 TOWARD HWY 87 TURN LEFT ON TINGEN RD
 TURN LEFT INTO S/D ON STRIKE EAGLE DR
 THEN TURN LEFT ON BUNKER BISTER & THEN
 LEFT ON FIFTY CALIBER DR LOT IS ON
 RIGHT LOT 30

STRUCTURE: 000 000 68X34 3BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00
 SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/10/11	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002039048
	2/10/11	AP	T/S: 02/10/2011 01:04 PM MREARIC -----
B103 01	2/23/11	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 002044972
	2/23/11	AP	PLEASE GO AFTER LUNCH IF POSSIBLE....
A814 01	2/23/11	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002044964
	2/23/11	AP	416 FIFTY CALIBER DR LOT 30 BROADWAY 27505
			T/S: 02/23/2011 09:55 AM TWARD -----
P309 01	3/03/11	TI	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002047983
	<u>3-3-11</u>	<u>AP MR</u>	T/S: 03/01/2011 03:55 PM NTART -----

----- COMMENTS AND NOTES -----

ADDRESS : 416 FIFTY CALIBER DR SUBDIV: PATTONS POINT
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
OWNER : BILL CLARK HOMES PHONE : (910) 263-9026
PARCEL : 03-9597- - -0039- -26-
APPL NUMBER: 11-50025887 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 01/13/2011 01:28 PM JBROCK ----
27 TOWARD HWY 87 TURN LEFT ON TINGEN RD
TURN LEFT INTO S/D ON STRIKE EAGLE DR
THEN TURN LEFT ON BUNKER BISTER & THEN
LEFT ON FIFTY CALIBER DR LOT IS ON
RIGHT LOT 30

STRUCTURE: 000 000 68X34 3BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/10/11	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002039048
	2/10/11	AP	T/S: 02/10/2011 01:04 PM MREARIC -----
B103 01	2/23/11	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 002044972
	2/23/11	AP	PLEASE GO AFTER LUNCH IF POSSIBLE....
A814 01	2/23/11	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002044964
	2/23/11	AP	416 FIFTY CALIBER DR LOT 30 BROADWAY 27505 T/S: 02/23/2011 09:55 AM TWARD -----
P309 01	3/03/11	MR	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002047983
	3/03/11	AP	T/S: 03/01/2011 03:55 PM NTART ----- T/S: 03/03/2011 12:13 PM MREARIC -----
B111 01	3/04/11	TI	R*BLDG SLAB INSP VRU #: 002048901

3-4-11 AP-MB

----- COMMENTS AND NOTES -----

get letter

ADDRESS . : 416 FIFTY CALIBER DR SUBDIV: PATTONS POINT
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
OWNER . . : BILL CLARK HOMES PHONE : (910) 263-9026
PARCEL . . : 03-9597- - -0039- -26-
APPL NUMBER: 11-50025887 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 01/13/2011 01:28 PM JBROCK ----
27 TOWARD HWY 87 TURN LEFT ON TINGEN RD
TURN LEFT INTO S/D ON STRIKE EAGLE DR
THEN TURN LEFT ON BUNKER BISTER & THEN
LEFT ON FIFTY CALIBER DR LOT IS ON
RIGHT LOT 30

STRUCTURE: 000 000 68X34 3BDR SLAB W/ GARAGE
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/10/11	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002039048
	2/10/11	AP	T/S: 02/10/2011 01:04 PM MREARIC -----
B103 01	2/23/11	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 002044972
	2/23/11	AP	PLEASE GO AFTER LUNCH IF POSSIBLE....
A814 01	2/23/11	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002044964
	2/23/11	AP	416 FIFTY CALIBER DR LOT 30 BROADWAY 27505 T/S: 02/23/2011 09:55 AM TWARD -----
P309 01	3/03/11	MR	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002047983
	3/03/11	AP	T/S: 03/01/2011 03:55 PM NTART ----- T/S: 03/03/2011 12:13 PM MREARIC -----
B111 01	3/04/11	MR	R*BLDG SLAB INSP VRU #: 002048901
	3/03/11	AP	T/S: 03/04/2011 12:17 PM MREARIC ----- need res-chek
R425 01	3/23/11	TI	FOUR TRADE ROUGH IN VRU #: 002056737
	<u>3:33:11</u>	<u>AP-MR</u>	

----- COMMENTS AND NOTES -----

Bill Clark Homes of Fayetteville
200 E Arlington Blvd
200 E Arlington Blvd
Greenville, NC 27858

03/08/2011

Attention : JJ Brenning

RE: Daily Field Report for 03/02/2011
Lot 30 @ Patton's Point, Bill Clark Homes
KAM Project No : 11-0062

Ladies and Gentlemen:

On this date, representative(s) of KAM Engineering Services, P.C. were present to perform construction material testing services at this project site. Our testing and observations for this date include the following:

ST-2 : In place field density testing was performed for Slab on Grade. The field density testing was performed in general accordance with ASTM D1556, using the results of field one-point Proctors and laboratory Proctors for compaction comparison. One(1) in-place field density test was performed on this date. The testing results indicate that in-place compaction and moisture content at the location and depth tested meet or exceed the specified requirements outlined in the project plans and specifications. For additional details of our testing, please refer to the attached Field Density Test Report.

Comment 1 : Note that only a small area of the building pad was ready for testing.

Closing

The testing and observations identified above have been reviewed by our project manager. If you have questions regarding this information, please do not hesitate to contact us.

Respectfully Submitted,
KAM Engineering Services, P.C.

Enclosures : ST-2

Rachael Heath

Submitted By

Project: Lot 30 @ Patton's Point, Bill Clark Homes
 11-0062
 Technician : F. Lucas

Client: Bill Clark Homes of Fayetteville
 200 E Arlington Blvd
 200 E Arlington Blvd
 Greenville, NC 27858

Distribution List: jbreuning@billclarkhomes.com

Test No	Re-Test Stamp	Dry Density (pcf)	Moisture Content % ASTM D 4959	Maximum Dry Density (pcf)	Optimum Moisture Content %	Compaction %	Required Compaction %	USCS	Proctor Type	ASTM Method	Location of Tests	Depth
1		117.6	11.2	119	12	99%	98%	SC-SM	ASTM D-698	ASTM D1556	Slab on Grade : Retest ST-1-1 from 2-25-11 8' North : 12' West from SE Corner	FSG

Richard Heath

Reviewed By



Engineering Services, P.C.

EVENT NO. ST-2

03/02/2011

Project: Lot 30 @ Patton's Point, Bill Clark Homes
11-0062
Technician : F. Lucas

Client: Bill Clark Homes of Fayetteville
200 E Arlington Blvd
200 E Arlington Blvd
Greenville, NC 27858

Distribution List: jbreming@billclarkhomes.com

Comments

Note that only a small area of the building pad was ready for testing.

03/08/2011

09:59:35

Radial Heath

Reviewed By

ADDRESS . : 416 FIFTY CALIBER DR SUBDIV: PATTONS POINT
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
OWNER . . : BILL CLARK HOMES PHONE : (910) 263-9026
PARCEL . . : 03-9597- - -0039- -26-
APPL NUMBER: 11-50025887 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 01/13/2011 01:28 PM JBROCK ----
27 TOWARD HWY 87 TURN LEFT ON TINGEN RD
TURN LEFT INTO S/D ON STRIKE EAGLE DR
THEN TURN LEFT ON BUNKER BISTER & THEN
LEFT ON FIFTY CALIBER DR LOT IS ON
RIGHT LOT 30

STRUCTURE: 000 000 68X34 3BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/10/11	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002039048
	2/10/11	AP	T/S: 02/10/2011 01:04 PM MREARIC -----
B103 01	2/23/11	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 002044972
	2/23/11	AP	PLEASE GO AFTER LUNCH IF POSSIBLE....
A814 01	2/23/11	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002044964
	2/23/11	AP	416 FIFTY CALIBER DR LOT 30 BROADWAY 27505 T/S: 02/23/2011 09:55 AM TWARD -----
P309 01	3/03/11	MR	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002047983
	3/03/11	AP	T/S: 03/01/2011 03:55 PM NTART ----- T/S: 03/03/2011 12:13 PM MREARIC -----
B111 01	3/04/11	MR	R*BLDG SLAB INSP VRU #: 002048901
	3/03/11	AP	T/S: 03/04/2011 12:17 PM MREARIC ----- need res-chek
R425 01	3/23/11	MR	FOUR TRADE ROUGH IN VRU #: 002056737
	3/23/11	AP	T/S: 03/23/2011 02:04 PM MREARIC -----
I129 01	3/28/11	TI	R*INSULATION INSPECTION VRU #: 002059462

3-28-11 AP MR

----- COMMENTS AND NOTES -----

ADDRESS : 416 FIFTY CALIBER DR SUBDIV: PATTONS POINT
 CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
 OWNER : BILL CLARK HOMES PHONE : (910) 263-9026
 PARCEL : 03-9597- - -0039- -26-
 APPL NUMBER: 11-50025887 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 01/13/2011 01:28 PM JBROCK ----
 27 TOWARD HWY 87 TURN LEFT ON TINGEN RD
 TURN LEFT INTO S/D ON STRIKE EAGLE DR
 THEN TURN LEFT ON BUNKER BISTER & THEN
 LEFT ON FIFTY CALIBER DR LOT IS ON
 RIGHT LOT 30

STRUCTURE: 000 000 68X34 3BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/10/11	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002039048
	2/10/11	AP	T/S: 02/10/2011 01:04 PM MREARIC -----
B103 01	2/23/11	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 002044972
	2/23/11	AP	PLEASE GO AFTER LUNCH IF POSSIBLE....
A814 01	2/23/11	<u>TW</u>	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002044964
	2/23/11	<u>AP</u>	416 FIFTY CALIBER DR LOT 30 BROADWAY 27505
			T/S: 02/23/2011 09:55 AM TWARD -----
P309 01	3/03/11	MR	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002047983
	3/03/11	AP	T/S: 03/01/2011 03:55 PM NTART -----
			T/S: 03/03/2011 12:13 PM MREARIC -----
B111 01	3/04/11	MR	R*BLDG SLAB INSP/TEMP SVC POLE VRU #: 002048901
	3/03/11	AP	T/S: 03/04/2011 12:17 PM MREARIC -----
			need res-chek
R425 01	3/23/11	MR	FOUR TRADE ROUGH IN VRU #: 002056737
	3/23/11	AP	T/S: 03/23/2011 02:04 PM MREARIC -----
I129 01	3/28/11	MR	R*INSULATION INSPECTION VRU #: 002059462
	3/28/11	AP	T/S: 03/28/2011 01:28 PM MREARIC -----
H824 01	4/11/11	<u>OT</u>	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002066439
	4/11/11	<u>AP</u>	T/S: 04/12/2011 09:51 AM SZIMMER -----
			T/S: 04/12/2011 09:51 AM SZIMMER -----
R429 01	5/19/11	DT	FOUR TRADE FINAL VRU #: 002082338
	5/19/11	CA	Per Paul
			T/S: 05/19/2011 10:03 AM DETAYLOR -----
R429 02	5/25/11	TI	FOUR TRADE FINAL VRU #: 002084895
	<u>5/25/11</u>	<u>AP DT</u>	

COMMENTS AND NOTES

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: ___ Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Name: Bill Clark Home

Address: 416 Fifty Caliber Dr
Broadway, NC 27505

Date: 5/25/11

Building Official: [Signature]

Permit Numbers

Building: _____
Electrical: _____
Insulation: _____
Plumbing: _____
Mechanical: 11-5005887
MFG Home: _____