

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:

Address: Date Evaluated: 1/31/10

Proposed Facility: 3 bedrooms Design Flow (.1949): 360 gpd

Location of Site: Property Recorded: Property Size:

Water Supply: Public Individual Well Spring Other

Evaluation Method: Auger Boring Pit Cut

Type of Wastewater: Sewage Industrial Process Mixed

Profile #	.1940 Landscape Position/Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/Color	.1943 Soil Depth (IN.)	.1936 Sapro Class	.1944 Restr Horiz.	
1	5 3.7%	0-30"	GS	VFU NS/HP					PS.35
		30-45"	SBK CL	FR SS/SP					
2		0-20"	GS	VFU NS/HP					PS.35
		20-45"	SBK CL	FR SS/SP					
3		0-30"	GS	VFU NS/HP					PS.35
		30-45"	SBK CL	FR SS/SP					

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: OS Others Present:
Available Space (.1943)	✓	✓	
System Type(s)	3.5/2.0	2.5/2.0	
Site LTAR	.35	.35	