HTE#11-5-25916

Harnett County Department of Public Health

Improvement Permit

26400

A building permit cannot be issued with only an Improvement Permit ISSUED TO: CUMBERLAND HOMES SUBDIVISION TINCEN PLACE Site Improvements required prior to Construction Authorization Issuance: Type of Structure: 5年〇 (38 トラヘ Proposed Wastewater System Type: Conventional Projected Daily Flow: 360 GPD Number of Occupants: 6 max Number of bedrooms: _ 3 Basement TYes ☐ No ☐ May be required based on final location and elevations of facilities Pump Required: □Yes Type of Water Supply:

Community Public

Well Distance from well 100 feet Five years Permit valid for: ■ No expiration Permit conditions: < RE1715 Date: ___ Authorized State Agent:: _ The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit... Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: CUMBERLAND HOMES PROPERTY LOCATION: MICRO TOWER RO SUBDIVISION TINGEN PLACE New 🗆 Expansion 🗆 Repair Basement Fixtures? ☐ Yes 🔀 No Basement? Yes No (Initial) Wastewater Flow: 360 CONVENTIONAL Type of Wastewater System** (See note below, if applicable □) 25% REDUCTION SYSTEM (Repair) Number of trenches 2 Installation Requirements/Conditions Trench Spacing: Feet on Center Septic Tank Size 1000 gallons Soil Cover: _ \2 inches Pump Tank Size _____ gallons Trenches shall be installed on contour at a Maximum Trench Depth of: 24 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Aggregate Depth: _____ inches below pipe inches above pipe _____ inches total Pump Requirements: _____ ft. TDH vs. ____ GPM Conditions: WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH REYS Authorized State Agent: __ Construction Authorization Expiration Date:

HTF#	11-5-25916	
1115-77		

Permit # __ 2Q400

Harnett County Department of Public Health Site Sketch

PROPERTY LOCATON: MICRO TOWER RO	10
ISSUED TO: CUMBERLAND HOMES SUBDIVISION TINGEN PLACE LOT #	<u> </u>
Authorized State Agent: Date: 291)	

