

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: _____ Applicant: _____
 Address: _____ Date Evaluated: 2/7/11
 Proposed Facility: 3 bedrooms Design Flow (.1949): 360 gpd
 Location of Site: _____ Property Recorded: _____
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 2-5%	0-24"	G S	VR2 NS/NP					
		28-48"	SBL** SCL	FR SS/NP					PS .5
2		0-26"	G S	VR2 NS/NP					
		26-48"	SBL** SCL	FR SS/NP					PS .5

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: OT Others Present: BM
Available Space (.1945)	✓	✓	
System Type(s)	25% a	25% a & b	
Site LTAR	.5	.5	

2790 @ 24"
 = Repair