

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated: 2/7/11
 Proposed Facility: 3 SEDUCOR Design Flow (.1949): 360 gpd
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 2-5%	0-21"	G S	VFN NS/NP					
		21-28"	SBK SCL	FR SS/SP					PS .4
2		0-23"	G S	VFN NS/NP					
		23-48"	SBK SCL	FR SS/SP					PS .4
		0-23"	G S	VFN NS/NP					
		23-48"	SBK SCL	FR SS/SP					PS .5

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: [Signature] Others Present: 03
Available Space (.1945)	✓	✓	
System Type(s)	.25	.25	
Site LTAR	.5	.5	