

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:

Address:

Date Evaluated: 2/1/11
 Design Flow (.1949): 360 gpd

Property Size:

Proposed Facility: 3 bedrooms

Location of Site:

Property Recorded:

Water Supply:

- Public Individual Well Spring Other
 Auger Boring Pit Cut

Evaluation Method:

Type of Wastewater:

- Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (in.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1936 Sapro Class	.1944 Restr. Horiz.	
1	1/5-10%	0-17	GS	VFR NS/HP					
		17-48	SBK SCL	FR SS/SP					PS SS
2		0-24	GS	VFR NS/HP					
		24-48	SBK SCL	FR SS/HP					PS SS
3		0-10	GS	VFR NS/HP					
		10-24"	SBK CL	FR S/SP	10/12 7/20 24"				PS .3
4		0-24"	GS	VFR NS/HP					
		24-48"	SBK SCL	FR SS/HP					PS SS
5		0-12"	GS	VFR NS/HP					
		12-24"	SBK CL	FR S/SP	10/12 7/20 23"				PS

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: [Signature] Others Present: -
Available Space (.1945)	✓	✓	
System Type(s)	25' 20' 20' →		
Site LTAR	SS	SS	