

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant:  
 Address:                      Date Evaluated: 2/21/11  
 Proposed Facility: 3 BEDROOMS      Design Flow (.1949): 360 gpd  
 Location of Site:                      Property Recorded:                      Property Size:  
 Water Supply:                       Public       Individual       Well       Spring       Other  
 Evaluation Method:                       Auger Boring       Pit       Cut  
 Type of Wastewater:                       Sewage       Industrial Process       Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (in.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz.	
1	LS 0-2%	0-19	G SL	VFR NS/NP					
		19-38	SBK SCL	FR SS/SP					PS.6
		32-72"	G S	VFR NS/NP					
2		0-72"	G S	VFR NS/NP					S.8
3		0-20"	G SL	VFR NS/NP					
		20-32"	SBK SCL	FR SS/SP					PS.6
		32-72"	G S	VFR NS/NP					

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: [Signature] Others Present: -
Available Space (.1943)	✓	✓	
System Type(s)	CON	CON	
Site LTAR	.6	.6	

4x50' e 36-48"