HTE# 11-5-25767

Harnett County Department of Public Health

Improvement Permit

26470

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: SUBDIVISION CARBLINA OAKS ISSUED TO: BILL CLARK Homes NEW 🔀 REPAIR 🗆 Site Improvements required prior to Construction Authorization Issuance: Type of Structure: 550 (59' x34') Proposed Wastewater System Type: CONVENTIONAL Projected Daily Flow: 360 Number of Occupants: 6 max Number of bedrooms: _ Basement □Yes Pump Required: ☐Yes ►No ☐ May be required based on final location and elevations of facilities Type of Water Supply: □ Community ➤ Public □ Well Distance from well \⊙ ○ feet Permit valid for: Five years Permit conditions: ☐ No expiration REHS Date: The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: BILL CLARK HOMES PROPERTY LOCATION: SUBDIVISION CAROLINA OAKS ☐ Expansion ☐ Repair Basement?

Yes No Basement Fixtures?

Yes

No (Initial) Wastewater Flow: 360 GPD CONVENTIONAL Type of Wastewater System** (See note below, if applicable □) COMENTIONAL Installation Requirements/Conditions Number of trenches Exact length of each trench ______ feet Trench Spacing: _____ Feet on Center Septic Tank Size 1000 gallons Trenches shall be installed on contour at a Soil Cover: 12 inches Pump Tank Size _____ gallons Maximum Trench Depth of: 24 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: ft. TDH vs. GPM Aggregate Depth: WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Authorized State Agent: _

Construction Authorization Expiration Date:

Harnett County Department of Public Health Site Sketch

_		PROPERTY LOCATON:		
ISSUED TO: BILL C	LACK Homes	SUBDIVISION CAR	DLINA OAKS	LOT # 54
			` `	1
Authorized State Agent:	430 Miller 1 W	SCOLIVER TOLKSDON	医) Date: 2/2	2/11
0				

