

**SOIL/SITE EVALUATION**  
**for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant:  
 Address:                      Date Evaluated:  
 Proposed Facility: 3 @ 2000 Design Flow (.1949): 360 gpd                      Property Size:  
 Location of Site:                      Property Recorded:  
 Water Supply:                       Public                       Individual                       Well                       Spring                       Other  
 Evaluation Method:                       Auger Boring                       Pit                       Cut  
 Type of Wastewater:                       Sewage                       Industrial Process                       Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Witness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz.	
1		0-6"	FILL						
		6-14"	G SL	VFIL NS/NP					
		14-20"	SBK SL	FIL SS/NP	10 YR 7/2 @ 3C				P5-55
2		0-21"	G SL	VFIL NS/NP					
		21-32"	SBK SFL	FIL SS/NP					P5-55
		32"	G S	VFIL NS/NP					
3		0-24"	G SL	VFIL NS/NP					
		24-44"	SBK S.CL	FIL SS/NP	10 YR 7/2 @ 4C				P5-55

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): P5 Evaluated By: OS Others Present:
Available Space (.1943)	✓	✓	
System Type(s)	CON	CON	
Site LTAR	55	55	

CON- 1X220 @ 24"