

HTE# 11-526000

Harnett County Department of Public Health Improvement Permit

26463

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: CAPE FEAR BUILDERS PROPERTY LOCATION: KATHLEEN RD
 SUBDIVISION HIGHLAND HILLS LOT # 108
 NEW REPAIR EXPANSION
 Type of Structure: SFO (37'x47')
 Proposed Wastewater System Type: CONVENTIONAL
 Projected Daily Flow: 240 GPD
 Number of bedrooms: 2 Number of Occupants: 4 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well 100 feet
 Permit conditions: _____ Permit valid for: Five years
 No expiration

Authorized State Agent: [Signature] REHS Date: 2/18/11 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit..

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: CAPE FEAR BUILDERS PROPERTY LOCATION: KATHLEEN RD
 SUBDIVISION HIGHLAND HILLS LOT # 108
 Facility Type: SFO (37'x47') New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** CONVENTIONAL (Initial) Wastewater Flow: 240 GPD
 (See note below, if applicable
CONVENTIONAL (Repair)

| | | |
|--|---|--|
| Installation Requirements/Conditions | Number of trenches <u>3</u> | |
| Septic Tank Size <u>1000</u> gallons | Exact length of each trench <u>60</u> feet | Trench Spacing: <u>9</u> Feet on Center |
| Pump Tank Size _____ gallons | Trenches shall be installed on contour at a Maximum Trench Depth of: <u>24</u> inches (Trench bottoms shall be level to +/-1/4" in all directions) | Soil Cover: <u>12</u> inches (Maximum soil cover shall not exceed 36" above the trench bottom) |
| Pump Requirements: _____ ft. TDH vs. _____ GPM | | Aggregate Depth: <u>6</u> inches below pipe <u>2</u> inches above pipe <u>12</u> inches total |
| Conditions: _____ | | |

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____
 This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] REHS Date: 2/18/11
 Construction Authorization Expiration Date: 2/18/16

HTE# 11-5-26000

Permit # 26463

Harnett County Department of Public Health Site Sketch

ISSUED TO: CAPE FEAR BUILDERS PROPERTY LOCATOR: KATHLEEN RD
SUBDIVISION HIGHLAND HILLS LOT # 108

Authorized State Agent: ~~REDACTED~~ PENN (OLIVER TOLKSDORF) Date: 2/18/11

