HTE# 11-5-26176

Harnett County Department of Public Health

Improvement Permit

26486

PROPERTY LOCATION: BELLA BRIOGE RD
ISSUED TO: JIM EXIM SUBDIVISION LOT #
NEW REPAIR EXPANSION Site Improvements required prior to Construction Authorization Issuance:
Type of Structure: つテロ(ちゃくちょう)
Proposed Wastewater System Type: 25% REDUCTION SYSTEM
Projected Daily Flow: GPD
Number of bedrooms: 3 Number of Occupants: 6 max
Basement
Type of Water Supply: Community Public Well Distance from well O feet Permit valid for: Five years
Permit conditions:
Authorized State Agent:: SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.
Construction Authorization
(Required for Building Permit)
The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.
ISSUED TO: JIMEKIN PROPERTY LOCATION: BELLA BRIOCE RO
ISSUED TO:
Facility Type: 5FO (SO'X5O') New Expansion Repair
Basement? U Yes 🖎 No Basement Fixtures? 🗆 Yes 🔀 No
Type of Wastewater System** 25% REDUCTION SYSTEM (Initial) Wastewater Flow: 360 GPD
(See note below, if applicable [])
Pump To 25% RED SYSTEM (Repair)
Installation Requirements/Conditions Number of trenches
Septic Tank Size 1000 gallons Exact length of each trench 205 feet Trench Spacing: Feet on Center
Pump Tank Size gallons Trenches shall be installed on contour at a Soil Cover: Gallons inches
Maximum Trench Depth of: 18 inches (Maximum soil cover shall not exceed
(Trench bottoms shall be level to +/-1/4" 36" above the trench bottom)
in all directions)
Pump Requirements: inches below pipe inches below pipe
Conditions: MEST ON SITE FOR FINAL DOANNFIELD LAYOUT. Aggregate Depth: inches above pipe inches total
WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.
**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.
Owner/Legal Representative Signature:
This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This
Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.
Authorized State Agent: Date: 3 5 1 Construction Authorization Expiration Date: 3 15 15 15 15 15 15 15
Construction Authorization Expiration Date: 3 15 15

Harnett County Department of Public Health Site Sketch

