

SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:

Address:

Date Evaluated:

Proposed Facility:

Design Flow (.1949):

Property Size:

Location of Site:

Property Recorded:

Water Supply:

- Public Individual Well Spring Other
 Auger Boring Pit Cut
 Sewage Industrial Process Mixed

Evaluation Method:

Type of Wastewater:

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1936 Sapro Class	.1944 Restr Horiz.	
1	LS 2-5%	0-10"	G SL	VFN NS/NP					
		10-34"	SBK C	FR S/SP	2.57	7/2030"			PS ₄
2		0-8"	G ^{loose} L	VFN NS/NP					
		8-34"	SBK CL	FR S/P	2.57	6/2019"			US
3		0-19"	G SL	VFN NS/NP					
		19-38"	SBK CL	FR S/SP					PS ₄
4		0-20"	G SL	VFN NS/NP					
		20-36"	SBK CL	FR S/SP					PS ₄
5		0-22"	G SL	VFN NS/NP					
		22-36"	SBK CL	FR S/SP					PS ₂₁
C		0-16"	G SL	VFN NS/NP					
		16-36"	SBK CL	FR S/SP					PS ₂₁

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: CT Others Present: -
Available Space (.1945)	✓	✓	
System Type(s)	20%	25%	
Site LTAR	.21	.4	

1x225' x 18"