

Harnett County Government Complex
307 Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7547
fax: 910-893-9371

April 20, 2011

Wynn Construction
2550 Capital Drive
Creedmoor, NC 27522

Re: Status of Improvement Permit Application HTE # 11-5-26247


Dear Mr. Averett,

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

1. Use pink flags to mark property lines. All irons that are set by surveyor need to be visible. (*\$25.00 fee incurred*)
2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
3. Directions not clear to property (*\$25.00 fee incurred*)
4. Property needs only brush or vegetation removed
5. Backhoe pits required
6. **Other- A site evaluation was done on 4/18/11. Not enough usable soil was located on the lot for an initial and repair area. The final soil report for the subdivision contained a proposed area for off-site septic easements. Please submit a proposal with a recorded septic easement for evaluation by the HCHD.**

Your application will be put on hold until the selected items above have been addressed. When completed please contact 910-893-7547 to confirm that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



REMS

Oliver Tolksdorf, R.E.H.S.
Environmental Health Soil Scientist
Harnett County Department of Public Health
Environmental Health

OT/sez
Copy: Central Permitting