Department of Environment, Health and Natural Resources
Division of Environmental Health
On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:
Address:
Proposed Facility: 3 BEDROOM
Location of Site:
Water Supply: ☒ Public ☐ Individual ☐ Well ☐ Spring ☐ Other
Evaluation Method: ☒ Auger Boring ☐ Pit ☐ Cut
Type of Wastewater: ☒ Sewage ☐ Industrial Process ☐ Mixed

Date Evaluated:
Design Flow (.1949): 360 gpd
Property Recorded:
Property Size:

PROFILE #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz.	
1	LS 2-5%	0-30	G S	VFI NS/NP					
		30-48	SBK SCL	FM SS/SP					
									PS, 4
2		0-27	G S	VFI NS NP					
		27-48	SBK SCL	FM SS/SP					
									PS, 2

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	25%	PANELBLOCK
Site LTAR	4	2

Other Factors (.1946):
Site Classification (.1948): PS
Evaluated By: DT
Others Present:

1 x 225' @ 24"