HTE# 11-5-26468R

Harnett County Department of Public Health

Improvement Permit

26574

A building permit cannot be issued with only an Improvement Permit

PROPERTY LOCATION: KINSMAN COURT

SUBDIVISION FOREST TRANS

LOT # 100 NEW

REPAIR □ EXE

Type of Structure: SFO(40×45 Site Improvements required prior to Construction Authorization Issuance: Proposed Wastewater System Type: PANE BLOCK Projected Daily Flow: 480 GPD Number of Occupants: __ \& max Number of bedrooms: Basement □Yes Pump Required: □Yes □ No ➤ May be required based on final location and elevations of facilities Type of Water Supply:


Community Public

Well Distance from well 100 feet Five years Permit valid for: Permit conditions: ☐ No expiration RENS Date: _ Authorized State Agent:: SEE ATTACHED SITE SKETCH The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. **Construction Authorization** (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: RICHARD BUTLER PROPERTY LOCATION: KINSMAN COURT
SUBDIVISION FOREST TRAILS Facility Type: SFOCHOX45 | New | Expansion | Repair

Basement? | Yes | No | Basement Fixtures? | Yes | No

Type of Wastewater System** | Panel Type of Wastewater System** (See note below, if applicable □) PANEL BLOCK Number of trenches Installation Requirements/Conditions Exact length of each trench 50 feet Trench Spacing: 8 Feet on Center Septic Tank Size 1000 gallons Pump Tank Size _____ gallons Trenches shall be installed on contour at a Soil Cover: 6 Maximum Trench Depth of: 30 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: ______ft. TDH vs. _____ GPM _____ inches below pipe Conditions: ALL MANUFACTURERS INSTALLATION SPECIFICATIONS F ______ inches above pipe CUIDELINES MUST BE FOLLOWED. WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: _ This Construction Authorization is subject to revocation if the site of plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the providence at the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH REHS Authorized State Agent: Construction Authorization Expiration Date:

Harnett County Department of Public Health Site Sketch



*MEET ON SITE WITH ANY QUESTIONS PRIOR TO INSTALLATION.