

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Jonathan Keith Green PROPERTY LOCATION: Hwy 42
 NEW REPAIR EXPANSION SUBDIVISION: James A Norris LOT # 2
 Type of Structure: SFD Site Improvements required prior to Construction Authorization Issuance:
 Proposed Wastewater System Type: 25% REDUCED Manifee
 Projected Daily Flow: 480 GPD
 Number of bedrooms: 4 Number of Occupants: 8 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well _____ feet Permit valid for: Five years
 Permit conditions: Contractor to meet on SETB Prior to INSTALL No expiration

Authorized State Agent: James E. Markant Date: 8-5-11 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Jonathan Keith Green PROPERTY LOCATION: Hwy 42
 SUBDIVISION: James A Norris LOT # 2
 Facility Type: SFD New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** Manifee to 25% REDUCED System (Initial) Wastewater Flow: 480 GPD
 (See note below, if applicable) Manifee to 25% Reduct (Repair) System

Installation Requirements/Conditions Number of trenches 3
 Septic Tank Size 1200 gallons Exact length of each trench 120 feet Trench Spacing: 7 Feet on Center
 Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Soil Cover: 6 inches
 Maximum Trench Depth of: 24" inches (Maximum soil cover shall not exceed 36" above the trench bottom)
 Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: 6 inches below pipe
 Conditions: Contractor to meet on SETB Prior to Installation 2 inches above pipe
12 inches total

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: James E. Markant Date: 8-5-11
 Construction Authorization Expiration Date: 8-5-16

HTE# 11-5-2654012

Permit # 26645

Harnett County Department of Public Health Site Sketch

ISSUED TO: Josanna Keith Gaden PROPERTY LOCATION: Hwy 42
SUBDIVISION: James A. Norris LOT # 2

Authorized State Agent: James E. Mahant Date: 8-5-11

- * 15' off of Basement.
- * 150'-200' of supply to Get Fall from Basement
- * AREA for DRAIN LINES to be cleared and contractor to meet on site prior to install
- * Full STORAGE ON DRAIN LINES is obtainable

