

**SOIL/SITE EVALUATION**  
 for ON-SITE WASTEWATER SYSTEM

Owner: \_\_\_\_\_ Applicant: \_\_\_\_\_  
 Address: \_\_\_\_\_  
 Proposed Facility: 3 Bedrooms  
 Location of Site: \_\_\_\_\_  
 Water Supply: \_\_\_\_\_  
 Evaluation Method: \_\_\_\_\_  
 Type of Wastewater: \_\_\_\_\_

Date Evaluated: \_\_\_\_\_  
 Design Flow (.1949): 360 gpd

Property Recorded: \_\_\_\_\_  
 Property Size: \_\_\_\_\_  
 Public  Individual  Well  Spring  Other  
 Auger Boring  Pit  Cut  
 Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz.	
1	LS 5-10%	0-18"	G S	VFR 25 NP					
		18-30"	SBL 2L	FR 25 NP					PS 5
			Hard c. 30" - Rock						
2		0-38"	SBL 2L	FR 25 NP					PS 5
		0-24"	G S	VFR 25 NP					
		24-30"	SBL 2L	FR 25 NP					PS 5

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: [Signature] Others Present: [Signature]
Available Space (.1943)	25%	25%	
System Type(s)	1.5	1.5	
Site LTAR	1x180 e 18"		