HTE#17-5-26933

Harnett County Department of Public Health

Improvement Permit

26663

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: OVERNIUS RD STONE CROSS LLC SUBDIVISION STONE CROSS ISSUED TO: NEW 🔀 REPAIR EXPANSION Site Improvements required prior to Construction Authorization Issuance: Type of Structure: SFO (40750' Proposed Wastewater System Type: Punk To 25% REDUCTION Projected Daily Flow: 360 Number of bedrooms: 3 Number of Occupants: __ Basement Yes No Pump Required: XYes ☐ May be required based on final location and elevations of facilities ☐ No Type of Water Supply:
Community A Public Well Distance from well 100 feet Permit valid for: Five years Permit conditions: ☐ No expiration 26175 Date: The issuance of this permit by the Health Department in no way guarantees the Issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. **Construction Authorization** (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: STONE CROSS LLC PROPERTY LOCATION: OVERSHIPS RD SUBDIVISION 5-ONE CROSS LOT # 11H Facility Type: SFD (40×50') 🔀 New □ Expansion ☐ Repair Basement? Yes No Basement Fixtures?

Yes Pume To 25% PROUSION STOTEM (Initial) Wastewater Flow: 360 GPD Type of Wastewater System** (See note below, if applicable □) ume to 0.5% REDUCTION (Repair) Installation Requirements/Conditions Number of trenches 1 Septic Tank Size 1000 gallons Exact length of each trench 130 Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Soil Cover: Maximum Trench Depth of: \\8 (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: _____ft. TDH vs. ____ _ inches below pipe Aggregate Depth: ______ inches above pipe Conditions: PERMTT BASED ON PROPOSAL FROM APPLICANTS inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Authorized State Agent: Construction Authorization Expiration Date:

Harnett County Department of Public Health Site Sketch

