

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: ___ Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Permit Numbers

Name: Caviness Land Dev

Building: _____

Electrical: _____

Address: 55 Parkview Ln

Insulation: _____

Lillington, NC 27546

Plumbing: _____

Mechanical: _____

MFG Home: _____

Date: 1/20/12

Building Official: [Signature]

11-50026966

ADDRESS : 55 PARKVIEW LN SUBDIV: ROSEMONT PH2 19LOTS
 CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
 OWNER : WATERS KATHRYN G PHONE : (910) 339-6330
 PARCEL : 01-0536- - -0028- -92-
 APPL NUMBER: 11-50026966 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 06/21/2011 07:51 AM JBROCK ----
 FROM 87 S MAKE A LEFT ONTO NURSERY RD
 AND THEN CONT TO THE LEFT ON NURSERY RD
 MAKE A RIGHT ONTO PARKVIEW LN LOT IS
 THE SECOND LOT ON THE LEFT LOT 3

STRUCTURE: 000 000 51X38 3BDR MONO W/ GARAGE PORCH

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/05/11	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002119166
	8/05/11	AP	
B103 01	8/18/11	MR	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002124857
	8/18/11	AP	T/S: 08/17/2011 10:48 AM VBROWN ----- T/S: 08/18/2011 11:07 AM MREARIC ----- eng report needed on fill under slab
P309 01	9/01/11	DT	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002131043
	9/01/11	AP	T/S: 08/31/2011 08:14 AM VBROWN -----
A814 01	9/08/11	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002133650
	9/08/11	AP	T/S: 09/07/2011 10:29 AM VBROWN ----- 55 PARKVIEW LN LOT 3 LILLINGTON 27546 ----- T/S: 09/08/2011 03:06 PM TWARD -----
B111 01	9/08/11	JH	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002133668
	9/08/11	DA	T/S: 09/07/2011 10:30 AM VBROWN ----- Need engineer compaction test on soil under slab the fill is over 24". is over 24".
B111 02	9/09/11	DT	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002134492
	9/09/11	AP	
R425 01	9/30/11	MR	FOUR TRADE ROUGH IN VRU #: 002142728
	9/30/11	DA	T/S: 09/30/2011 12:16 PM MREARIC ----- 1. no plans, no truss specs, 3. anchors afasteners are not installed correctly 4. master bath has a leak at vanity fitting, 5. riser has no water. 6. truss hangers are nailed with short nails, 7. flash tyvek over porch to shed water over flashing 8. could not continue T/S: 09/30/2011 12:24 PM MREARIC ----- disregard above info 1. anchors in sill not to code
R425 02	10/06/11	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002145050
	10/06/11	DP	T/S: 10/05/2011 09:43 AM VBROWN ----- T/S: 10/06/2011 12:56 PM MREARIC ----- 1. still no water in riser ok to side but not insulate
R425 03	10/11/11	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002147171
	10/11/11	AP	T/S: 10/10/2011 01:56 PM DJOHNSON -----

PREPARED 1/19/12, 14:07:04
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 20
DATE 1/20/12

ADDRESS : 55 PARKVIEW LN
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER : WATERS KATHRYN G
PARCEL : 01-0536- - -0028- -92-
APPL NUMBER: 11-50026966 CP NEW RESIDENTIAL (SFD)

SUBDIV: ROSEMONT PH2 19LOTS
PHONE : (919) 481-0503
PHONE : (910) 339-6330

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
I129 01	10/14/11	MR	T/S: 10/11/2011 12:01 PM MREARIC ----- R*INSULATION INSPECTION VRU #: 002148367
	10/14/11	AP	T/S: 10/14/2011 12:06 PM MREARIC -----
H824 01	11/01/11	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002156701
	11/01/11	AP	T/S: 11/02/2011 09:55 AM SZIMMER ----- T/S: 11/02/2011 09:56 AM SZIMMER -----
R429 01	1/18/12	MR	FOUR TRADE FINAL VRU #: 002181908
	1/18/12	DP	T/S: 01/18/2012 10:16 AM MREARIC ----- have house unlocked provide ladder attach ground wire to house at meter
R429 02	1/20/12	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002183358
	1/20/12	AP DT	T/S: 01/19/2012 10:42 AM VBROWN -----

----- COMMENTS AND NOTES -----