HTE#11-527067

## Harnett County Department of Public Health

**Improvement Permit** 

26700

A building permit cannot be issued with only an Improvement Permit ISSUED TO: MOSS HOME BUILDERS SUBDIVISION MCDOUGALO PLACE NEW 🔀 REPAIR 🗆 EXPANSION Site Improvements required prior to Construction Authorization Issuance: Type of Structure: SEO (80 260)
Proposed Wastewater System Type: 25% REDUKION SYSTEM Projected Daily Flow: 360 Number of bedrooms: Number of Occupants: Basement Yes Pump Required: □Yes ➤ No ☐ May be required based on final location and elevations of facilities Type of Water Supply: 

Community Public 

Well Distance from well 

Community feet Permit valid for: Five years Permit conditions: ☐ No expiration site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. **Construction Authorization** (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: MOSS HOME BUILDERS PROPERTY LOCATION: McDougald Ro SUBDIVISION McDougald PLACE Facility Type: SEO (50'×50') | New | Expansion | Repair Basement? | Yes | No Basement Fixtures? | Yes | No | No |
Type of Wastewater System\*\* | 25% | REDUCTION 575 | Em | (Initial) Wastewater Flow: 360 | GPD (See note below, if applicable X) 25% REDUCTION SYSTEM (Repair) Number of trenches Installation Requirements/Conditions Exact length of each trench 180 feet Trench Spacing: 9 Feet on Center Septic Tank Size 1000 gallons Soil Cover: 12-18 inches Pump Tank Size \_\_\_\_\_ gallons Trenches shall be installed on contour at a Maximum Trench Depth of: 24-30 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: \_\_\_\_\_ft. TDH vs. \_\_\_\_ GPM \_\_\_\_\_inches below pipe Aggregate Depth: \_\_\_\_\_\_ inches above pipe inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. \*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Authorized State Agent: Construction Authorization Expiration Date:

## Harnett County Department of Public Health Site Sketch

PROPERTY LOCATON: McDoughlo Roses Subdivision McDoughlo Place Moss Home BUILDERS Authorized State Agent: רנו ' 258° 50'×50' ← 35'→ 个 38 DR-ND

EXIE PLACE OF