

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address:
 Proposed Facility: 3850200m Date Evaluated:
 Location of Site: Design Flow (.1949): 360 gpd Property Size:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 5-7%	0-30	GLS	VFA NS/MP					
		30-35	SBK SCL	FR SS/SP					PS .5
			HAS 235" ROCK						
2		0-25"	G SL	VFA NS/MP					
		25"	SBK C	FR S/P					PS .35
3		0-24"	G S	VFA NS/MP					
		24"	SBK SCL	FR SS/SP	ROCK @ 27"				PS .4
4		0-12"	G S	VFA NS/MP					
		12"	SBK C	FR S/P	107R7/2 @ 18"				US
5		0-30"	G S	VFA NS/MP					
		30-36"	SBK SCL	FR SS/SP	107R7/2 @ 34"				PS.24
6		0-34"	G S	VFA NS/MP					
		34"	SBK SCL	FR SS/SP	107R7/2 @ 36"				PS.11

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: OK Others Present: -
Available Space (.1945)	✓	✓	
System Type(s)	P/NP DS P/O		
Site LTAR	.35	.35	