HTE#_11-5-27156

Harnett County Department of Public Health

Improvement Permit

26674

A building permit cannot be issued with only an Improvement Permit	
	MILL LUCAS RO CAROLINA ORKS LOT # 24
NEW REPAIR EXPANSION Type of Structure: SFD (53744)	Site Improvements required prior to Construction Authorization Issuance:
Proposed Wastewater System Type: 25% REDUCTION 5 YOTEM	
Projected Daily Flow: 360 GPD	
Number of bedrooms: 3 Number of Occupants: 6 max	
Basement	
Pump Required: □Yes X No □ May be required based on final location and eleva	tions of facilities
Type of Water Supply: Community Public Well Distance from well 10 Permit conditions:	Permit valid for: Five years ———————————————————————————————————
THE RE-	
Authorized State Agent: Date:	8/2/11 SEE ATTACHED SITE SKETCH
Authorized State Agent: The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.	
Construction Au	thorization
(Required for Buildi	ng Permit)
The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 ar with the attached system layout.	e incorporated by references into this permit and shall be met. Systems shall be installed in accordance
ISSUED TO: BILL CLACK HOMES PROPERTY SUBDIVISION	LOCATION: WILL LUCKS RD
SUBDIVISIO	ON CAROLINA OAKS LOT # 24
Facility Type: SFOCS3×497 New Expans	ion 🗆 Repair
Basement? Yes No Basement Fixtures? Pes No	2.62
Type of Wastewater System** 25% KEOUCTION SYSTE	(Initial) Wastewater Flow: 360 GPD
(See note below, if applicable 🖄)	
25% REDUCTION SYSTEM	_(Repair)
Installation Requirements/Conditions Number of trenches 3	
Septic Tank Size 1000 gallons Exact length of each trench	feet Trench Spacing: Feet on Center ontour at a Soil Cover: 12-18 inches
Pump Tank Size gallons Trenches shall be installed on co	ontour at a Soil Cover: 12-18 inches
Maximum Trench Depth of: 🕰	$\frac{1}{1}$ inches (Maximum soil cover shall not exceed
(Trench bottoms shall be level t	
in all directions)	,
Pump Requirements:ft. TDH vs GPM	inches below pipe
	Aggregate Depth: inches above pipe
Conditions:	inches total
WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF S	EPTIC SYSTEM OR REPAIR AREA.
NO UTILITIES ÀLLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.	
**If applicable: / understand the system type specified is different from the type specifie	ed on the application I accept the specifications of this permit
1 applicable. I understand the system type specified is unievent from the type specified on the application. I accept the specifications of this permit.	
Owner/Legal Representative Signature:	
This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This	
Construction Authorization is subject to compliance what the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH	
	1 1
Authorized State Agent: Date: R 2 11	
Authorized State Agent: Date: R 2 10 Construction Authorization Expiration Date: 8 2 14	

Harnett County Department of Public Health Site Sketch

Authorized State Agent:

PROPERTY LOCATON: WILL LUCAS RO
SUBDIVISION CAROLINA OAX3 LOT # 24

