HTE#17-5-27158

## Harnett County Department of Public Health

**Improvement Permit** 

26677

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: TINGEN RD ISSUED TO: 81LL CLARK HOMES PROPERTY LOCATION: 11NGEN KD
SUBDIVISION PATTONS POINT Site Improvements required prior to Construction Authorization Issuance: NFW 😿 Type of Structure: SEO (46×50) Proposed Wastewater System Type: 25% REQUESTON SYSTEM 360 Projected Daily Flow: Number of bedrooms: 3 Number of Occupants: 6 max Basement Yes No ☐ No May be required based on final location and elevations of facilities Pump Required: □Yes Type of Water Supply: 🗆 Community 💢 Public 🗀 Well Distance from well 💢 feet Permit valid for: Five years Permit conditions: ☐ No expiration REMS Date: \_ 8/3/11 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. **Construction Authorization** (Required for Building Permit) The construction and installation requirements of Rules .1950, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: BILL CLARK HOMES PROPERTY LOCATION: TINCEN RO
SUBDIVISION PATIONS POINT Facility Type: 5FD (24C\*XSOT) ☐ Expansion ☐ Repair Basement? Yes No Basement Fixtures? 

Yes 

No 25% REDUCTION STOTEM (Initial) Wastewater Flow: 360 GPD Type of Wastewater System\*\* (See note below, if applicable □) Rump To 25% REDUCTION (Repair) Installation Requirements/Conditions Number of trenches \ Exact length of each trench 200 feet Trench Spacing: \_\_\_\_\_ Feet on Center Soil Cover: 6-12 inches Pump Tank Size \_\_\_\_\_ gallons Trenches shall be installed on contour at a Maximum Trench Depth of: 18-24 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: \_\_\_\_\_\_ft. TDH vs. \_\_\_\_ GPM Conditions: FIMAL SYSTEM LATIOUT TO BE DETERMINED RETER inches above pipe inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. \*\*If applicable: / understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Authorized State Agent: Construction Authorization Expiration Date:

HTE#	١	)	-5	$\mathcal{A}$	1	5	8	
------	---	---	----	---------------	---	---	---	--

Permit # 24677

## Harnett County Department of Public Health Site Sketch

	PROPERTY LOCATION: TIMEEN RO	
ISSUED TO: BILL CLARK HOMES	SUBDIVISION PATTONS POINT	LOT # <u>35</u>
	REHE COLIVER TOLKSDORD) Date: 8 3 11	
Authorized State Agent:	CENT OF LANGE LOTHES Date: 8 3 11	

