

ADDRESS : 15 DOUGLAS ACRES DR SUBDIV: TINGEN PLACE PH3 21LOTS
 CONTRACTOR : WESTAN CONSTRUCTION, LLC PHONE : (910) 818-9378
 OWNER : LDS HOMES LLC PHONE : (910) 892-4345
 PARCEL : 03-9597- - -0227- -14-
 APPL NUMBER: 11-50027179 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 07/20/2011 10:09 AM JBROCK ----
 TAKE 27 W FROM LILLINGTON TURN LEFT ON
 TINGEN RD TURN LEFT ON MICRO TOWER RD
 TURN LEFT ON DOUGLAS ACRES RD INTO S/D
 TURN RIGHT ON TOWER DR LOT ON LEFT LOT
 25

STRUCTURE: 000 000 29.6X46 3BDR SLAB W/ GARAGE & PATIO
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B103 01	11/07/12 11/07/12	DJ AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002300556 T/S: 11/07/2012 11:39 AM DJOHNSON ----- TSP INSPECTION ONLY T/S: 11/07/2012 11:39 AM DJOHNSON ----- APPROVED INSPECTION FOR MIKE REARIC
P309 01	11/07/12 11/07/12	DJ AP	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002300044 T/S: 11/06/2012 11:27 AM VBROWN ----- T/S: 11/07/2012 11:37 AM DJOHNSON ----- SIGNED OFF APPROVED FOR MIKE REARIC
A814 01	11/08/12 11/14/12	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002300531 T/S: 11/07/2012 11:34 AM DJOHNSON ----- 15 DOUGLAS ACRES DR LOT 25 BROADWAY 275057 T/S: 11/14/2012 10:35 AM TWARD -----
B111 01	11/08/12 11/09/12	MR AP	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002300549 T/S: 11/07/2012 11:35 AM DJOHNSON ----- T/S: 11/09/2012 12:37 PM MREARIC -----
B104 01	11/29/12 11/29/12	JB AP	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 002310175
R425 01	11/30/12 11/30/12	MR DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002310183 T/S: 11/30/2012 02:30 PM MREARIC ----- truss strapping on baloon wall to be doubled
I129 01	12/05/12 12/05/12	MR DA	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002312080 T/S: 12/05/2012 11:15 AM MREARIC ----- insulation over garage must be in contact with the floor above or the perimeter of the area of the floor trusses must be insulated
R425 02	12/05/12 12/05/12	MR AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002312106
I129 02	12/06/12 12/06/12	DT AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002312700 T/S: 12/06/2012 10:35 AM DETAYLOR -----
H824 01	1/10/13 1/10/13	OT AP	ENVIR: OPERATIONS PERMIT TIME: 17:00 VRU #: 002327450 T/S: 01/15/2013 08:25 AM SSTEWARD ----- T/S: 01/15/2013 08:26 AM SSTEWARD -----
R429 01	1/22/13 1/22/13	MR CA	FOUR TRADE FINAL TIME: 17:00 VRU #: 002329233 T/S: 01/18/2013 12:05 PM DJOHNSON -----

PREPARED 1/22/13, 14:12:02
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 5
DATE 1/23/13

ADDRESS : 15 DOUGLAS ACRES DR
CONTRACTOR : WESTAN CONSTRUCTION, LLC
OWNER : LDS HOMES LLC
PARCEL : 03-9597- - -0227- -14-
APPL NUMBER: 11-50027179 CP NEW RESIDENTIAL (SFD)

SUBDIV: TINGEN PLACE PH3 21LOTS
PHONE : (910) 818-9378
PHONE : (910) 892-4345

REQUESTED INSP DESCRIPTION
TYP/SQ COMPLETED RESULT RESULTS/COMMENTS

R429 02 1/23/13 TI FOUR TRADE FINAL T/S: 01/22/2013 12:01 PM MREARIC
123-13 AP-MR TIME: 17:00 VRU #: 002330041
T/S: 01/22/2013 12:09 PM VBROWN

----- COMMENTS AND NOTES -----

ADDRESS : 15 DOUGLAS ACRES DR SUBDIV: TINGEN PLACE PH3 21LOTS
 CONTRACTOR : WESTAN CONSTRUCTION, LLC PHONE : (910) 818-9378
 OWNER : LDS HOMES LLC PHONE : (910) 892-4345
 PARCEL : 03-9597- - -0227- -14-
 APPL NUMBER: 11-50027179 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 07/20/2011 10:09 AM JBROCK ----
 TAKE 27 W FROM LILLINGTON TURN LEFT ON
 TINGEN RD TURN LEFT ON MICRO TOWER RD
 TURN LEFT ON DOUGLAS ACRES RD INTO S/D
 TURN RIGHT ON TOWER DR LOT ON LEFT LOT
 25

STRUCTURE: 000 000 29.6X46 3BDR SLAB W/ GARAGE & PATIO
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B103 01	11/07/12 11/07/12	DJ AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002300556 T/S: 11/07/2012 11:39 AM DJOHNSON ---- TSP INSPECTION ONLY T/S: 11/07/2012 11:39 AM DJOHNSON ---- APPROVED INSPECTION FOR MIKE REARIC
P309 01	11/07/12 11/07/12	DJ AP	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002300044 T/S: 11/06/2012 11:27 AM VBROWN ---- T/S: 11/07/2012 11:37 AM DJOHNSON ---- SIGNED OFF APPROVED FOR MIKE REARIC
A814 01	11/08/12 11/14/12	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002300531 T/S: 11/07/2012 11:34 AM DJOHNSON ---- 15 DOUGLAS ACRES DR LOT 25 BROADWAY 27505 T/S: 11/14/2012 10:35 AM TWARD ----
B111 01	11/08/12 11/09/12	MR AP	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002300549 T/S: 11/07/2012 11:35 AM DJOHNSON ---- T/S: 11/09/2012 12:37 PM MREARIC ----
B104 01	11/29/12 11/29/12	JB AP	R*BLDG FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 002310175
R425 01	11/30/12 11/30/12	MR DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002310183 T/S: 11/30/2012 02:30 PM MREARIC ---- truss strapping on baloon wall to be doubled
I129 01	12/05/12 12/05/12	MR DA	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002312080 T/S: 12/05/2012 11:15 AM MREARIC ---- insulation over garage must be in contact with the floor above or the perimeter of the area of the floor trusses must be insulated
R425 02	12/05/12 12/05/12	MR AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002312106
I129 02	12/06/12 12/06/12	DT AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002312700 T/S: 12/06/2012 10:35 AM DETAYLOR ----
H824 01	1/10/13 1/10/13	OT AV	ENVIRONMENTAL OPERATIONS PERMIT TIME: 17:00 VRU #: 002327450 T/S: 01/15/2013 08:25 AM SSTEWARD ---- T/S: 01/15/2013 08:26 AM SSTEWARD ----
R429 01	1/22/13 1-22-13	TI SA-MR	FOUR TRADE FINAL TIME: 17:00 VRU #: 002329233 T/S: 01/18/2013 12:05 PM DJOHNSON ----

COMMENTS AND NOTES

ADDRESS : 15 DOUGLAS ACRES DR
 CONTRACTOR : WESTAN CONSTRUCTION, LLC
 OWNER : LDS HOMES LLC
 PARCEL : 03-9597- - -0227- -14-
 APPL NUMBER: 11-50027179 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 07/20/2011 10:09 AM JBROCK ----
 TAKE 27 W FROM LILLINGTON TURN LEFT ON
 TINGEN RD TURN LEFT ON MICRO TOWER RD
 TURN LEFT ON DOUGLAS ACRES RD INTO S/D
 TURN RIGHT ON TOWER DR LOT ON LEFT LOT
 25

SUBDIV: TINGEN PLACE PH3 21LOTS
 PHONE : (910) 818-9378
 PHONE : (910) 892-4345

STRUCTURE: 000 000 29.6X46 3BDR SLAB W/ GARAGE & PATIO
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00
 SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B103 01	11/07/12 11/07/12	DJ AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002300556 T/S: 11/07/2012 11:39 AM DJOHNSON ----- TSP INSPECTION ONLY T/S: 11/07/2012 11:39 AM DJOHNSON ----- APPROVED INSPECTION FOR MIKE REARIC
P309 01	11/07/12 11/07/12	DJ AP	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002300044 T/S: 11/06/2012 11:27 AM VBROWN ----- T/S: 11/07/2012 11:37 AM DJOHNSON ----- SIGNED OFF APPROVED FOR MIKE REARIC
A814 01	11/08/12 11/14/12	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002300531 T/S: 11/07/2012 11:34 AM DJOHNSON ----- 15 DOUGLAS ACRES DR LOT 25 BROADWAY 27505 T/S: 11/14/2012 10:35 AM TWARD -----
B111 01	11/08/12 11/09/12	MR AP	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002300549 T/S: 11/07/2012 11:35 AM DJOHNSON ----- T/S: 11/09/2012 12:37 PM MREARIC -----
B104 01	11/29/12 11/29/12	JB AP	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 002310175
R425 01	11/30/12 11/30/12	MR DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002310183 T/S: 11/30/2012 02:30 PM MREARIC ----- truss strapping on baloon wall to be doubled
I129 01	12/05/12 12/05/12	MR DA	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002312080 T/S: 12/05/2012 11:15 AM MREARIC ----- insulation over garage must be in contact with the floor above or the perimeter of the area of the floor trusses must be insulated
R425 02	12/05/12 12/05/12	MR AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002312106
I129 02	12/06/12 <u>12/16/12</u>	TI <u>APDF</u>	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002312700

COMMENTS AND NOTES

ADDRESS : 15 DOUGLAS ACRES DR
 CONTRACTOR : WESTAN CONSTRUCTION, LLC
 OWNER : LDS HOMES LLC
 PARCEL : 03-9597- - -0227- -14-
 APPL NUMBER: 11-50027179 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 07/20/2011 10:09 AM JBROCK ----
 TAKE 27 W FROM LILLINGTON TURN LEFT ON
 TINGEN RD TURN LEFT ON MICRO TOWER RD
 TURN LEFT ON DOUGLAS ACRES RD INTO S/D
 TURN RIGHT ON TOWER DR LOT ON LEFT LOT
 25

SUBDIV: TINGEN PLACE PH3 21LOTS
 PHONE : (910) 818-9378
 PHONE : (910) 892-4345

STRUCTURE: 000 000 29.6X46 3BDR SLAB W/ GARAGE & PATIO

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00
 SEPTIC - EXISTING? : NEW
 PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B103 01	11/07/12 11/07/12	DJ AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002300556 T/S: 11/07/2012 11:39 AM DJOHNSON ----- TSP INSPECTION ONLY T/S: 11/07/2012 11:39 AM DJOHNSON ----- APPROVED INSPECTION FOR MIKE REARIC
P309 01	11/07/12 11/07/12	DJ AP	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002300044 T/S: 11/06/2012 11:27 AM VBROWN ----- T/S: 11/07/2012 11:37 AM DJOHNSON ----- SIGNED OFF APPROVED FOR MIKE REARIC
A814 01	11/08/12 11/14/12	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002300531 T/S: 11/07/2012 11:34 AM DJOHNSON ----- 15 DOUGLAS ACRES DR LOT 25 BROADWAY 27505 T/S: 11/14/2012 10:35 AM TWARD -----
B111 01	11/08/12 11/09/12	MR AP	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002300549 T/S: 11/07/2012 11:35 AM DJOHNSON ----- T/S: 11/09/2012 12:37 PM MREARIC -----
B104 01	11/29/12 11/29/12	JB AP	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 002310175
R425 01	11/30/12 11/30/12	MR DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002310183 T/S: 11/30/2012 02:30 PM MREARIC ----- truss strapping on baloon wall to be doubled
I129 01	12/05/12	TI	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002312080
R425 02	<u>12-5-12</u> 12/05/12	<u>DA-MR</u> TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002312106
	<u>12-9-12</u>	<u>AP-MR</u>	

COMMENTS AND NOTES

HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DATE: 12/5/2012

PERMIT # 12-50027179

ADDRESS: 15 douglas acres

- 1. The insulation over the garage must be in contact with the floor above or insulate the perimeter area between the insulation and the above floor**

Mike Rearic cell# (910) 984- 4772

ADDRESS : 15 DOUGLAS ACRES DR
CONTRACTOR : WESTAN CONSTRUCTION, LLC
OWNER : LDS HOMES LLC
PARCEL : 03-9597- - -0227- -14-
APPL NUMBER: 11-50027179 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 07/20/2011 10:09 AM JBROCK ----
TAKE 27 W FROM LILLINGTON TURN LEFT ON
TINGEN RD TURN LEFT ON MICRO TOWER RD
TURN LEFT ON DOUGLAS ACRES RD INTO S/D
TURN RIGHT ON TOWER DR LOT ON LEFT LOT
25

SUBDIV: TINGEN PLACE PH3 21LOTS
PHONE : (910) 818-9378
PHONE : (910) 892-4345

STRUCTURE: 000 000 29.6X46 3BDR SLAB W/ GARAGE & PATIO

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00
SEPTIC - EXISTING? : NEW
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B103 01	11/07/12 11/07/12	DJ AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002300556 T/S: 11/07/2012 11:39 AM DJOHNSON ----- TSP INSPECTION ONLY T/S: 11/07/2012 11:39 AM DJOHNSON ----- APPROVED INSPECTION FOR MIKE REARIC
P309 01	11/07/12 11/07/12	DJ AP	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002300044 T/S: 11/06/2012 11:27 AM VBROWN ----- T/S: 11/07/2012 11:37 AM DJOHNSON ----- SIGNED OFF APPROVED FOR MIKE REARIC
A814 01	11/08/12 11/14/12	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002300531 T/S: 11/07/2012 11:34 AM DJOHNSON ----- 15 DOUGLAS ACRES DR LOT 25 BROADWAY 27505 T/S: 11/14/2012 10:35 AM TWARD -----
B111 01	11/08/12 11/09/12	MR AP	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002300549 T/S: 11/07/2012 11:35 AM DJOHNSON ----- T/S: 11/09/2012 12:37 PM MREARIC -----
B104 01	11/29/12 11/29/12	JB AP	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 002310175
R425 01	11/30/12 <u>11-30-12</u>	TI <u>DA-MR</u>	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002310183

COMMENTS AND NOTES

HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DATE: 11/30/2012

PERMIT # 11-50027179

ADDRESS: 15 douglas acres

- 1. The trusses with the double "v" need to be double strapped on wall adjacent to the stairs**
- 2. Will check on insulation**
- 3. Have back door in on insulation inspection**
- 4. Sheath the inside of garage wing walls and nail on 4" centers**

Mike Rearic cell# (910) 984- 4772

Harnett County

INSPECTOR: IVR

DATE 11/07/12

ADDRESS : 15 DOUGLAS ACRES DR
CONTRACTOR : WESTAN CONSTRUCTION, LLC
OWNER : LDS HOMES LLC
PARCEL : 03-9597- - -0227- -14-

SUBDIV: TINGEN PLACE PH3 21LOTS
PHONE : (910) 818-9378
PHONE : (910) 892-4345

APPL NUMBER: 11-50027179 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : T/S: 07/20/2011 10:09 AM JBROCK ----
TAKE 27 W FROM LILLINGTON TURN LEFT ON
TINGEN RD TURN LEFT ON MICRO TOWER RD
TURN LEFT ON DOUGLAS ACRES RD INTO S/D
TURN RIGHT ON TOWER DR LOT ON LEFT LOT
25

STRUCTURE: 000 000 29.6X46 3BDR SLAB W/ GARAGE & PATIO

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3000000.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED	INSP	DESCRIPTION
	COMPLETED	RESULT	RESULTS/COMMENTS

P309 01	11/07/12	TI	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002300044
	<u>11-7-12</u>	<u>AP-MR</u>	T/S: 11/06/2012 11:27 AM VBROWN

COMMENTS AND NOTES

ADDRESS . . : 15 DOUGLAS ACRES DR SUBDIV: TINGEN PLACE PH3 21LOTS
 CONTRACTOR : WESTAN CONSTRUCTION, LLC PHONE : (910) 818-9378
 OWNER . . : LDS HOMES LLC PHONE : (910) 892-4345
 PARCEL . . : 03-9597- - -0227- -14-
 APPL NUMBER: 11-50027179 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 07/20/2011 10:09 AM JBROCK ----
 TAKE 27 W FROM LILLINGTON TURN LEFT ON
 TINGEN RD TURN LEFT ON MICRO TOWER RD
 TURN LEFT ON DOUGLAS ACRES RD INTO S/D
 TURN RIGHT ON TOWER DR LOT ON LEFT LOT
 25

STRUCTURE: 000 000 29.6X46 3BDR SLAB W/ GARAGE & PATIO
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B103 01	11/07/12	DJ	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002300556
	11/07/12	AP	T/S: 11/07/2012 11:39 AM DJOHNSON ----- TSP INSPECTION ONLY T/S: 11/07/2012 11:39 AM DJOHNSON ----- APPROVED INSPECTION FOR MIKE REARIC
P309 01	11/07/12	DJ	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002300044
	11/07/12	AP	T/S: 11/06/2012 11:27 AM VBROWN ----- T/S: 11/07/2012 11:37 AM DJOHNSON ----- SIGNED OFF APPROVED FOR MIKE REARIC
A814 01	11/08/12	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002300531
			T/S: 11/07/2012 11:34 AM DJOHNSON -----
B111 01	11/08/12	TI	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002300549
			T/S: 11/07/2012 11:35 AM DJOHNSON -----
			11-9-12 AP-MR 11-9-12

----- COMMENTS AND NOTES -----