Department of Environment, Health and Natural Resources
Division of Environmental Health
On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:
Address: Date Evaluated:
Proposed Facility: 3BED 800m Design Flow (.1949): 360 gpd Property Size:
Location of Site: Property Recorded:
Water Supply: ☒ Public ☐ Individual ☐ Well ☐ Spring ☐ Other
Evaluation Method: ☒ Auger Boring ☐ Pit ☐ Cut
Type of Wastewater: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 0-2%	0-18"	C LS	VFR NS/NP					
		18-35"	SCL	FR SS/SP	10YR 7/2 & 3/1"				PS .45
2		0-20"	C LS	VFR NS/NP					
		20-36"	SCL	FR SS/SP	10YR 7/2 & 5/4"				PS .45

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	30%	→
Site LTAR	.45	.45

Other Factors (.1946):
Site Classification (.1948): PS
Evaluated By: CT
Others Present: —