

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: x Occupancy: x

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: R-3

Permit Numbers

Name: Wynn Construction

Building: 11-50027232

Electrical: 11

Address: 20 Omaha Dr.

Insulation: 11

Plumbing: 11

Mechanical: 11

MFG Home: _____

Date: 11-7-11

Building Official: T. Mark Reami

PREPARED 11/04/11, 14:05:24
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 19
DATE 11/07/11

ADDRESS : 20 OMAHA DR SUBDIV: TINGEN POINTE 86LOTS
CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
OWNER : HARNETT DEVELOPERS LLC PHONE :
PARCEL : 03-9576- - -0088- -01-
APPL NUMBER: 11-50027232 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 07/27/2011 08:25 AM JBROCK ----
HWY 27 W LEFT ON OMAHA 1ST LOT ON RIGHT
LOT 1

STRUCTURE: 000 000 50X60 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	9/12/11	MR	R*PLUMB UNDER SLAB VRU #: 002134112
	9/12/11	DA	T/S: 09/12/2011 01:07 PM MREARIC ----- plumbing not ready PREMISE # 28549720
P309 02	9/13/11	MR	R*PLUMB UNDER SLAB VRU #: 002135572
	9/13/11	AP	T/S: 09/13/2011 11:34 AM MREARIC -----
B114 01	9/14/11	MR	R*BLDG MONO SLAB/TEMP SVC POLE VRU #: 002136067
	9/14/11	AP	T/S: 09/14/2011 01:03 PM MREARIC -----
A814 01	9/14/11	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002136075
	9/14/11	AP	20 OMAHA DR LOT 1 BROADWAY 27505 ----- T/S: 09/14/2011 08:22 AM TWARD -----
R425 01	9/30/11	MR	FOUR TRADE ROUGH IN VRU #: 002142354
	9/30/11	AP	T/S: 09/30/2011 12:20 PM MREARIC -----
I129 01	10/04/11	MR	R*INSULATION INSPECTION VRU #: 002143907
	10/04/11	AP	T/S: 10/04/2011 01:02 PM MREARIC -----
H824 01	10/07/11	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002146900
	10/07/11	AP	T/S: 10/10/2011 10:23 AM SZIMMER ----- T/S: 10/10/2011 10:23 AM SZIMMER -----
R429 01	11/03/11	MR	FOUR TRADE FINAL VRU #: 002157006
	11/03/11	DP	T/S: 11/03/2011 12:55 PM MREARIC ----- need ladder where is pressure reducing valve? main water shut-off?,caulk over meter at siding,install house numbers finish grading away from house on north side
R429 02	11/07/11	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002157931

11-7-11 AP-MR

COMMENTS AND NOTES

2854 9720