

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: X Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: R-3

Permit Numbers

Name: American Homesmith

Building: 11-50027259

Electrical: 11

Address: 664 Omaha Dr.

Insulation: 11

Plumbing: 11

Mechanical: 11

MFG Home: _____

Date: 12-15-11

Building Official: T. Michael Reavis

PREPARED 12/14/11, 14:17:37
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 9
DATE 12/15/11

ADDRESS . . : 664 OMAHA DR SUBDIV: TINGEN POINTE 86LOTS
CONTRACTOR : AMERICAN HOMESMITH LLC PHONE : (919) 422-4128
OWNER . . : AMERICAN HOMESMITH #74 PHONE : (919) 600-8988
PARCEL . . : 03-9576- - -0088- -74-
APPL NUMBER: 11-50027259 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 08/02/2011 08:32 AM JBROCK ----
HWY 27 W FROM LILLINGTON TURN LEFT ON
OMAHA DR LOT 74
PRE #43270252

STRUCTURE: 000 000 49X35 3BDR CRAWL W/ GARAGE & PATIO

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/16/11	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002136799
	9/16/11	AP	T/S: 09/16/2011 12:25 PM MREARIC -----
B103 01	9/27/11	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002141033
	9/27/11	AP	T/S: 09/27/2011 12:50 PM MREARIC -----
B105 01	9/29/11	MR	R*OPEN FLOOR VRU #: 002142194
	9/29/11	AP	T/S: 09/29/2011 01:09 PM MREARIC -----
A814 01	10/20/11	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002150803
	10/19/11	AP	664 OMAHA DR LOT 74 BROADWAY 27505----- T/S: 10/19/2011 10:12 AM TWARD -----
R425 01	10/20/11	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002150837
	10/25/11	AP	T/S: 10/19/2011 10:15 AM VBROWN ----- T/S: 10/25/2011 12:53 PM MREARIC -----
I129 01	10/25/11	MR	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002152338
	10/25/11	DA	T/S: 10/21/2011 04:26 PM VBROWN ----- T/S: 10/25/2011 01:24 PM MREARIC ----- either remove the ac ducts from the bonus area or modify the plans to show additional area and insulate it
I129 02	11/01/11	MR	R*INSULATION INSPECTION VRU #: 002155937
	11/01/11	AP	T/S: 11/01/2011 11:58 AM MREARIC -----
H824 01	11/14/11	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002162709
	11/14/11	AP	T/S: 11/17/2011 10:08 AM SZIMMER ----- T/S: 11/17/2011 10:09 AM SZIMMER -----
R429 01	12/14/11	MR	FOUR TRADE FINAL VRU #: 002171676
	12/14/11	DP	T/S: 12/14/2011 11:33 AM MREARIC ----- install ac zone system install foundation drain install plastic under house
R429 02	12/15/11	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002172807

12-15-11 AP-MR

----- COMMENTS AND NOTES -----