

September 8, 2011

Harnett County Government Complex
307 Cornelius Harnett Boulevard
Lillington, NC 27546

Atlantic Construction
7 East Doris Avenue
Jacksonville, NC 28540

ph: 910-893-7547
fax: 910-893-9371

**Re: Status of Improvement Permit Application #11-5-27418, 11-5-27419, 11-5-27420
#11-5-27421, 11-5-27422, 11-5-27423, 11-5-27424**


To Whom It May Concern,

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use **pink flags to mark property lines and irons that are set by surveyor need to be visible** (\$25.00 fee incurred for each lot)
- 2. Use orange flags to mark house corners (\$25.00 fee incurred)
- 3. Directions not clear to property (\$25.00 fee incurred)
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. Other

Your application will be put on hold until the selected items above have been addressed. When completed please call 910-893-7547 to confirm that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Bryan Mc Swain, R.E.H.S.
On-Site Waster Water Program Specialist
Harnett County Department of Public Health
Environmental Health Section

BM/sgs
Copy: Central Permitting